



**Generation Interconnection  
Feasibility Study Report  
for  
Queue Project AE2-262  
MOSHANNON-MILESBURG 230 KV  
50 MW Capacity / 83.6 MW Energy**

July, 2019

# Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	5
3.1	Point of Interconnection .....	6
3.1.1	Primary POI .....	6
3.2	Cost Summary.....	6
4	Transmission Owner Scope of Work.....	7
5	Attachment Facilities .....	7
6	Direct Connection Cost Estimate.....	8
7	Non-Direct Connection Cost Estimate.....	8
8	System Reinforcement Cost Estimates .....	9
9	Schedule.....	11
10	Transmission Owner Analysis.....	12
10.1	Power Flow Analysis .....	12
11	Interconnection Customer Requirements.....	13
11.1	System Protection.....	13
11.2	Compliance Issues and Interconnection Customer Requirements .....	13
11.3	Power Factor Requirements.....	14
12	Revenue Metering and SCADA Requirements .....	15
12.1	PJM Requirements .....	15
12.1.1	Meteorological Data Reporting Requirement.....	15
12.2	FE Requirements.....	15
13	Network Impacts.....	16
13.1	Generation Deliverability .....	18
13.2	Multiple Facility Contingency .....	18
13.3	Contribution to Previously Identified Overloads.....	18
13.4	Potential Congestion due to Local Energy Deliverability.....	19
13.5	System Reinforcements.....	20
13.6	Flow Gate Details.....	22
13.6.1	Index 1 .....	23
13.6.2	Index 2 .....	25

13.6.3	Index 3 .....	27
13.6.4	Index 4 .....	29
13.6.5	Index 5 .....	31
13.6.6	Index 6 .....	33
13.6.7	Index 7 .....	35
13.6.8	Index 8 .....	37
13.7	Affected Systems .....	40
13.7.1	LG&E .....	40
13.7.2	MISO .....	40
13.7.3	TVA .....	40
13.7.4	Duke Energy Progress .....	40
13.7.5	NYISO .....	40
13.8	Contingency Descriptions .....	41
13.9	Short Circuit .....	44
14	Attachment 1 – One Line .....	45
15	Attachment 2 – Project Location .....	46

## 1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Pennsylvania Electric Company (PENELEC).

## 2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model.

The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

### 3 General

The Interconnection Customer (IC) has proposed a Solar generating facility located in Centre County, Pennsylvania. The installed facilities will have a total capability of 83.6 MW with 50 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is June 20, 2022. This study does not imply a Transmission Owner (TO) commitment to this in-service date.

<b>Queue Number</b>	<b>AE2-262</b>
<b>Project Name</b>	MOSHANNON-MILESBERG 230 KV
<b>Interconnection Customer</b>	
<b>State</b>	Pennsylvania
<b>County</b>	Centre
<b>Transmission Owner</b>	PENELEC
<b>MFO</b>	83.6
<b>MWE</b>	83.6
<b>MWC</b>	50
<b>Fuel</b>	Solar
<b>Basecase Study Year</b>	2022

### 3.1 Point of Interconnection

#### 3.1.1 Primary POI

The interconnection of the project at the Primary POI will be accomplished by constructing a new 230 kV three breaker ring bus substation and looping the Moshannon - Milesburg 230 kV line into the new station. The new substation will be located approximately 15.7 miles from Moshannon substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection switching station and the associated facilities. The IC will also be responsible for the rough grade of the property and an access road to the proposed three breaker ring bus site.

Attachment 1 shows a one-line diagram of the proposed primary direct connection facilities for the AE2-262 generation project to connect to the FirstEnergy (“FE”) transmission system. Attachment 2 provides the proposed location for the point of interconnection. IC will be responsible for constructing all of the facilities on its side of the POI, including the attachment facilities which connect the generator to the FE transmission system’s direct connection facilities.

### 3.2 Cost Summary

The AE2-262 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$805,932
Direct Connection Network Upgrade	\$8,148,868
Non Direct Connection Network Upgrades	\$838,700
<b>Total Costs</b>	<b>\$9,793,500</b>

In addition, the AE2-262 project may be responsible for a contribution to the following costs

Description	Total Cost
System Upgrades	\$179,400,000

Cost allocations for these upgrades will be provided in the System Impact Study Report.

The costs provided above exclude the Contribution in Aid of Construction (“CIAC”) Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

The required Attachment Facilities and Direct and Non-Direct Connection work for the interconnection of the AE2-262 generation project to the FE Transmission System is detailed in the following sections. The associated one-line with the generation project Attachment Facilities and the Primary Direct and Non-Direct Connection facilities are shown in Attachment 1.

#### 4 Transmission Owner Scope of Work

The interconnection of the project at the Primary POI will be accomplished by constructing a new 230 kV three breaker ring bus substation and looping the Moshannon - Milesburg 230 kV line into the new station. The new substation will be located approximately 15.7 miles from Moshannon substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection switching station and the associated facilities. The IC will also be responsible for the rough grade of the property and an access road to the proposed three breaker ring bus site.

Attachment 1 shows a one-line diagram of the proposed primary direct connection facilities for the AE2-262 generation project to connect to the FirstEnergy (“FE”) transmission system. Attachment 2 provides the proposed location for the point of interconnection. IC will be responsible for constructing all of the facilities on its side of the POI, including the attachment facilities which connect the generator to the FE transmission system’s direct connection facilities.

#### 5 Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Install Dead-End Structure, Foundations and Disconnect Switch for AE2-262 Terminal	\$805,932
<b>Total Attachment Facility Costs</b>	<b>\$805,932</b>

## 6 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Construct 3 Breaker Ring Bus	\$8,148,868
<b>Total Direct Connection Facility Costs</b>	<b>\$8,148,868</b>

## 7 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Install Wideband Wavetrap at Moshannon	\$93,100
Install Wideband Wavetrap at Milesburg	\$93,100
Install Wideband Wavetrap at Shingletown	\$93,100
Loop in the Moshannon – Milesburg 230 kV Line	\$559,400
<b>Total Non-Direct Connection Facility Costs</b>	<b>\$838,700</b>

## 8 System Reinforcement Cost Estimates

Facility	Upgrade Description	Cost
26WARREN 230.0 kV - 26ERIE S TIE 230.0 kV Ckt 1	PN-0012 (800) : Upgrade 1033 ASCR bus conductor at Glade and Warren substations Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months	\$130,000
AE2-113 TAP 115.0 kV - 26FARM VLY 115.0 kV Ckt 1	PN-0007 (793) : Reconductor line with high temperature conductor (5.55 miles - 336 ACSS; 6.79 miles 636 ACSS). Project Type : FAC Cost : \$22,100,000 Time Estimate : 20.0 Months	\$22,100,000
01KISSNG 138.0 kV - 01KARNSC 138.0 kV Ckt 1	WP-0008 (183) : Replace 556 Line Conductor Project Type : FAC Cost : \$13,000,000 Time Estimate : 9.0 Months	\$13,000,000
26TOWANDA 115.0 kV - 26NO MESHO 115.0 kV Ckt 1	PN-0009a (795) : At East Towanda, replace the breaker disconnect, line trap and relaying. At North Meshoppen, replace the relaying and bus conductor. Project Type : FAC Cost : \$650,000 Time Estimate : 12.0 Months  PN-0009b (796) : Reconductor line with high temperature conductor (636 ACSS - 2.45 miles; 477 ACSS - 20.12 miles). Project Type : FAC Cost : \$40,300,000 Time Estimate : 36.0 Months	\$40,950,000
AE1-071 TAP 115.0 kV - 26ROXBURY 115.0 kV Ckt 1	PN-0002 (788) : Reconductor line with 336 ACSS high temperature conductor (6.4 miles). Project Type : FAC Cost : \$13,000,000 Time Estimate : 20.0 Months	\$13,000,000

Facility	Upgrade Description	Cost
01KARNSC 138.0 kV - 01BUTLER 138.0 kV Ckt 1	<p>WP-0007 (178) : Reconductor 336 ACSR Line Project Type : FAC Cost : \$26,000,000 Time Estimate : 30.0 Months</p> <p>WP-0007a (179) : Replace line and bus side disconnect switches at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p> <p>WP-0007b (180) : Replace Bus Side Disconnect Switches at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p> <p>WP-0007c (181) : Replace Wavetrap at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p> <p>WP-0007d (182) : Replace Wavetrap Leads at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p>	\$26,520,000
26ERIE W 345.0 kV - 02AT 345.0 kV Ckt 1	<p><u>ATSI</u> CEI-001A (285) : Reconductor the ATSI owned portion of the Erie West-Ashtabula 3-point tap 345 kV Line (~ 15 miles from Ashtabula to structure 13083). The existing conductor is (2) 954 ACSR conductor and the new conductor is (2) 954 kcmil ACSS conductor. Project Type : FAC Cost : \$42,900,000 Time Estimate : 36.0 Months</p> <p><u>PENELEC</u> PN-0004 (790) : Reconductor line with high temperatre conductor (MAIT Portion - 7.17 miles) Project Type : FAC Cost : \$20,800,000 Time Estimate : 20.0 Months</p>	\$63,700,000
	TOTAL COST	\$179,400,000

## 9 Schedule

Based on the scope of work for the Attachment Facilities and the Direct and Non-Direct Connection facilities, it is expected to take a minimum of 28 months after the signing of an Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the IC to make a preliminary payment that compensates FE for the first three months of the engineering design work that is related to the construction of the interconnection substation. This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection and network upgrades, and that all transmission system outages will be allowed when requested.

The schedule for the required Network Impact Reinforcements will be more clearly identified in future study phases. The estimate elapsed time to complete each of the required reinforcements is identified in the “System Reinforcements” section of the report. Full initial deposit will be required for the Non-Direct Connection and Network Upgrade work.

## 10 Transmission Owner Analysis

### 10.1 Power Flow Analysis

FE performed an analysis of its underlying transmission <100 kV system. The AE2-262 project did not contribute to any overloads on the FE transmission <100 kV system.

## 11 Interconnection Customer Requirements

### 11.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

The IC has requested a non-standard GSU transformer winding configuration. This transformer is in violation of section 14.2.6 of FE's "Requirements for Transmission Connected Facilities" document and will not be accepted. The GSU transformer must have a grounded wye connection on the high (utility) side and a delta connection on the low (generator) side.

### 11.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 230 kV circuit breaker to protect the AE2-262 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AE2-262 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits.

Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

### **11.3 Power Factor Requirements**

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system.

## 12 Revenue Metering and SCADA Requirements

### 12.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

#### 12.1.1 Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

### 12.2 FE Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

### **13 Network Impacts**

The Queue Project AE2-262 was evaluated as an 83.6 MW (Capacity 50.0 MW) injection tapping the Moshannon to Milesburg 230kV line in the PENELEC area. Project AE2-262 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-262 was studied with a commercial probability of 53%. Potential network impacts were as follows:

# Summer Peak Load Flow

### 13.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308731	200599	26ERIEW	PENELEC	238547	02AT	ATSI	1	235104 01CABOT 500 239280 02CRNBRY 500 1	single	1900.0	99.89	100.09	DC	8.43

### 13.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7307387	235248	01SHINGL	AP	200513	26LEWISTWN	PENELEC	1	AP-P2-2-WP-230-001T	bus	554.0	86.87	94.73	DC	43.55
7308159	235248	01SHINGL	AP	200513	26LEWISTWN	PENELEC	1	AP-P2-3-WP-230-446T	breaker	554.0	87.05	94.91	DC	43.55
7308160	235248	01SHINGL	AP	200513	26LEWISTWN	PENELEC	1	AP-P2-3-WP-230-443T *	breaker	554.0	86.88	94.74	DC	43.55
7308161	235248	01SHINGL	AP	200513	26LEWISTWN	PENELEC	1	AP-P2-2-WP-230-001T	breaker	554.0	86.87	94.73	DC	43.55

### 13.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7307944	200674	26TOWANDA	PENELEC	200677	26NOMESHO	PENELEC	1	PN-P2-3-PN-230-3C	breaker	172.0	117.99	119.1	DC	4.24
7308123	200811	26WARREN	PENELEC	200918	26ERIE S TIE	PENELEC	1	PN-P2-3-PN-345-003A	breaker	621.0	101.61	102.13	DC	7.07
7308569	235197	01KARNSC	AP	235152	01BUTLER	AP	1	PN-P1-2-PN-345-107T	single	179.0	129.56	130.3	DC	2.91
7308570	235197	01KARNSC	AP	235152	01BUTLER	AP	1	ATSI-P1-2-CEI-345-700T	single	179.0	129.56	130.3	DC	2.91
7308954	235203	01KISSNG	AP	235197	01KARNSC	AP	1	ATSI-P1-2-CEI-345-700T	single	268.0	104.04	104.56	DC	3.07
7308955	235203	01KISSNG	AP	235197	01KARNSC	AP	1	PN-P1-2-PN-345-107T	single	268.0	104.04	104.56	DC	3.07
7307286	938380	AE1-071 TAP	PENELEC	200520	26ROXBURY	PENELEC	1	PL:10:P22:100582	bus	160.0	105.09	107.29	DC	7.8
7307287	938380	AE1-071 TAP	PENELEC	200520	26ROXBURY	PENELEC	1	PN-P2-2-PN-230-006AT	bus	160.0	103.75	105.95	DC	7.8
7308119	941190	AE2-113 TAP	PENELEC	200668	26FARMVLY	PENELEC	1	PN-P2-3-PN-230-8M_SUM_WIN	breaker	160.0	101.3	103.07	DC	6.25

### 13.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308571	235197	01KARNSC	AP	235152	01BUTLER	AP	1	PN-P1-2-PN-345-107T	operation	179.0	92.81	94.04	DC	4.87
7308572	235197	01KARNSC	AP	235152	01BUTLER	AP	1	ATSI-P1-2-CEI-345-700T	operation	179.0	92.81	94.04	DC	4.87

## 13.5 System Reinforcements

ID	Index	Facility	Upgrade Description	Cost
7308123	4	26WARREN 230.0 kV - 26ERIE S TIE 230.0 kV Ckt 1	PN-0012 (800) : Upgrade 1033 ASCR bus conductor at Glade and Warren substations Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months	\$130,000
7307387,7308159,7308161,7308160	2	01SHINGL 230.0 kV - 26LEWISTWN 230.0 kV Ckt 1	<u>7308159,7308160,7308161</u> No violation. <sup>1</sup> Post queue loading less than 100%.  <u>7307387</u> No violation. <sup>1</sup> Penelec Side Ratings: [Rate A: 520, Rate B: 621, Rate C: 621]	\$0
7308119	8	AE2-113 TAP 115.0 kV - 26FARM VLY 115.0 kV Ckt 1	PN-0007 (793) : Reconductor line with high temperature conductor (5.55 miles - 336 ACSS; 6.79 miles 636 ACSS). Project Type : FAC Cost : \$22,100,000 Time Estimate : 20.0 Months	\$22,100,000
7308955,7308954	6	01KISSNG 138.0 kV - 01KARNSC 138.0 kV Ckt 1	WP-0008 (183) : Replace 556 Line Conductor Project Type : FAC Cost : \$13,000,000 Time Estimate : 9.0 Months	\$13,000,000
7307944	3	26TOWANDA 115.0 kV - 26NO MESHO 115.0 kV Ckt 1	PN-0009a (795) : At East Towanda, replace the breaker disconnect, line trap and relaying. At North Meshoppen, replace the relaying and bus conductor. Project Type : FAC Cost : \$650,000 Time Estimate : 12.0 Months  PN-0009b (796) : Reconductor line with high temperature conductor (636 ACSS - 2.45 miles; 477 ACSS - 20.12 miles). Project Type : FAC Cost : \$40,300,000 Time Estimate : 36.0 Months	\$40,950,000

<sup>1</sup> If “No violation” was provided as the Upgrade Description for a facility in the System Reinforcements table then that facility met one of the following conditions:

- The loading on the facility at your queue position was less than 100%; therefore, the facility is not yet overloaded, but may be overloaded by end of the AE2 queue.
- The TO reviewed their ratings on the facility and determined that the current rating was greater than the rating in PJM’s model. This new rating was greater than the loading at your queue position making the violation invalid.
- The TO reviewed the contingency and determined that contingency was not valid; therefore the violation is invalid. Any contingency corrections will be assessed and corrected in the AE2 impact study phase.

ID	Index	Facility	Upgrade Description	Cost
7307286,7307287	7	AE1-071 TAP 115.0 kV - 26ROXBURY 115.0 kV Ckt 1	<p>PN-0002 (788) : Reconductor line with 336 ACSS high temperature conductor (6.4 miles). Project Type : FAC Cost : \$13,000,000 Time Estimate : 20.0 Months</p> <p><u>7307287</u> No Violation.<sup>1</sup> Post queue loading less than 100%.</p>	\$13,000,000
7308570,7308569	5	01KARNSC 138.0 kV - 01BUTLER 138.0 kV Ckt 1	<p>WP-0007 (178) : Reconductor 336 ACSR Line Project Type : FAC Cost : \$26,000,000 Time Estimate : 30.0 Months</p> <p>WP-0007a (179) : Replace line and bus side disconnect switches at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p> <p>WP-0007b (180) : Replace Bus Side Disconnect Switches at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p> <p>WP-0007c (181) : Replace Wavetrap at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p> <p>WP-0007d (182) : Replace Wavetrap Leads at Butler Project Type : FAC Cost : \$130,000 Time Estimate : 9.0 Months</p>	\$26,520,000
7308731	1	26ERIE W 345.0 kV - 02AT 345.0 kV Ckt 1	<p><u>ATSI</u> CEI-001A (285) : Reconductor the ATSI owned portion of the Erie West-Ashtabula 3-point tap 345 kV Line (~ 15 miles from Ashtabula to structure 13083). The existing conductor is (2) 954 ACSR conductor and the new conductor is (2) 954 kcmil ACSS conductor. Project Type : FAC Cost : \$42,900,000 Time Estimate : 36.0 Months</p> <p><u>PENELEC</u> PN-0004 (790) : Reconductor line with high temperatre conductor (MAIT Portion - 7.17 miles) Project Type : FAC Cost : \$20,800,000 Time Estimate : 20.0 Months</p>	\$63,700,000
			<b>TOTAL COST</b>	<b>\$179,400,000</b>

### 13.6 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

—

### 13.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308731	200599	26ERIE W	PENELEC	238547	02AT	ATSI	1	235104 01CABOT 500 239280 02CRNBRY 500 1	single	1900.0	99.89	100.09	DC	8.43

Bus #	Bus	MW Impact
200608	26PINEY #1	0.9
200642	26SENECA#1	8.51
200643	26SENECA#2	9.07
200644	26SENECA#3	0.68
200662	26SCRUB GR	3.42
200805	26COLVER13	16.2
200823	26MHP_X3-003	8.36
200828	26HNSMLK 1	2.35
200829	26HNSMLK 2	2.35
200830	26HNSMLK 3	2.35
200831	26HNSMLK 4	2.35
200832	26HNSMLK 5	2.35
200849	26LAKVU GN	0.3
201201	26WRREN CT	2.44
903643	W3-099 C OP1	5.85
914101	Y2-055	10.17
915951	Y3-092 FTIR	565.19
916351	Z1-091	3.37
919201	AA1-144 O1	26.75
919491	AA2-000	81.51
920341	AA2-132	3.68
930411	AB1-082	4.63
930511	AB1-092	2.99
932571	AC2-077	4.27
935191	AD1-154	3.88
936421	AD2-055	6.16
936991	AD2-133 C	2.7
938951	AE1-123	4.14
939171	AE1-147 C	1.84
939291	AE1-160 C	4.5
939381	AE1-169 C O1	17.52
940201	AE2-001 C	1.83
940681	AE2-055 C	1.78
940801	AE2-067 C	2.79
940861	AE2-074 C O1	3.52
941191	AE2-113 C O1	14.84
941251	AE2-119 C	2.11
941261	AE2-120 C	1.83
941271	AE2-121 C	0.98

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
941321	AE2-126 C	2.37
941331	AE2-129 C	1.94
941351	AE2-131 C	1.94
941421	AE2-139 C O1	10.39
941491	AE2-146 C	16.84
942351	AE2-248 C	1.44
942491	AE2-262 C	8.43
942501	AE2-263 C	7.92
942811	AE2-299 C	14.14
942961	AE2-316 C	8.18
943151	AE2-344 C O1	33.57
BLUEG	BLUEG	22.89
CALDERWOOD	CALDERWOOD	1.97
CANNELTON	CANNELTON	1.37
CATAWBA	CATAWBA	1.01
CBM-N	CBM-N	8.29
CHEOAH	CHEOAH	1.8
CHILHOWEE	CHILHOWEE	0.65
COFFEEN	COFFEEN	2.45
COTTONWOOD	COTTONWOOD	8.39
DUCKCREEK	DUCKCREEK	5.5
EDWARDS	EDWARDS	2.53
ELMERSMITH	ELMERSMITH	2.34
FARMERCITY	FARMERCITY	1.59
G-007A	G-007A	11.81
GIBSON	GIBSON	0.96
HAMLET	HAMLET	1.49
NEWTON	NEWTON	6.37
NYISO	NYISO	36.24
PRAIRIE	PRAIRIE	11.53
SANTEETLA	SANTEETLA	0.53
SMITHLAND	SMITHLAND	0.88
TATANKA	TATANKA	2.93
TILTON	TILTON	3.0
TRIMBLE	TRIMBLE	2.55
TVA	TVA	6.82
UNIONPOWER	UNIONPOWER	2.98
VFT	VFT	32.36

### 13.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308161	235248	01SHINGL	AP	200513	26LEWISTWN	PENELEC	1	AP-P2-2-WP-230-001T	breaker	554.0	86.87	94.73	DC	43.55

Bus #	Bus	MW Impact
200665	26SHAWVL 3	9.75
200666	26SHAWVL 4	9.52
200715	26SHAWVL 1	6.01
200722	26SHAWVL 2	6.15
200894	26K02	13.02
200905	26Q36	0.24
200913	26SHAW-D	0.25
236828	01GRAYMONT	2.38
290086	Q-036 E	7.81
917072	Z2-011	0.38
918682	AA1-082 E	6.13
919201	AA1-144 O1	18.82
919491	AA2-000	169.28
925512	AC1-025 E	0.92
930511	AB1-092	6.22
936421	AD2-055	12.8
936991	AD2-133 C	3.51
936992	AD2-133 E	16.06
939171	AE1-147 C	7.1
939172	AE1-147 E	4.74
940201	AE2-001 C	7.12
940202	AE2-001 E	4.75
940681	AE2-055 C	7.38
940682	AE2-055 E	4.92
941251	AE2-119 C	4.08
941252	AE2-119 E	2.72
941261	AE2-120 C	7.13
941262	AE2-120 E	4.75
941271	AE2-121 C	3.76
941272	AE2-121 E	2.51
941321	AE2-126 C	2.78
941322	AE2-126 E	1.86
941331	AE2-129 C	3.12
941332	AE2-129 E	2.08
941351	AE2-131 C	3.12
941352	AE2-131 E	2.08
942351	AE2-248 C	5.82
942352	AE2-248 E	3.88
942491	AE2-262 C	26.05
942492	AE2-262 E	17.5
942501	AE2-263 C	24.48

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
942502	AE2-263 E	16.35
CATAWBA	CATAWBA	0.01
CBM-N	CBM-N	1.32
CBM-S1	CBM-S1	0.38
CBM-W1	CBM-W1	1.36
CBM-W2	CBM-W2	3.4
CIN	CIN	0.47
G-007	G-007	0.89
HAMLET	HAMLET	0.04
IPL	IPL	0.31
LGEE	LGEE	0.13
MEC	MEC	0.84
MECS	MECS	1.13
NYISO	NYISO	5.67
O-066	O-066	5.22
WEC	WEC	0.14

### 13.6.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7307944	200674	26TOWANDA	PENELEC	200677	26NO MESHO	PENELEC	1	PN-P2-3-PN-230-3C	breaker	172.0	117.99	119.1	DC	4.24

Bus #	Bus	MW Impact
200887	26ARMNA MT	0.41
200894	26K02	8.27
200949	26X1-109	18.42
203261	26BLOSSBCT	0.34
203283	26MANOR_T86	0.04
203999	P-047 E	13.55
916201	Z1-069 C	0.17
916202	Z1-069 E	6.01
916361	Z1-092	0.42
916541	Z1-110	0.4
917072	Z2-011	0.4
918682	AA1-082 E	11.36
919201	AA1-144 O1	31.63
919491	AA2-000	44.62
930411	AB1-082	1.58
930511	AB1-092	1.64
931091	AB1-160 C	0.05
931092	AB1-160 E	1.72
932571	AC2-077	2.15
934801	AD1-108	0.03
934811	AD1-109	0.02
935061	AD1-142	0.02
936421	AD2-055	3.37
940861	AE2-074 C O1	1.2
940862	AE2-074 E O1	1.58
941191	AE2-113 C O1	3.45
941192	AE2-113 E O1	3.72
941421	AE2-139 C O1	13.76
941422	AE2-139 E O1	9.17
941491	AE2-146 C	7.25
941492	AE2-146 E	10.22
942491	AE2-262 C	2.54
942492	AE2-262 E	1.71
942501	AE2-263 C	2.39
942502	AE2-263 E	1.59
CBM-N	CBM-N	1.27
CBM-S1	CBM-S1	1.96
CBM-S2	CBM-S2	0.76
CBM-W1	CBM-W1	4.16
CBM-W2	CBM-W2	14.95
CIN	CIN	1.66

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
CPLE	CPLE	0.27
G-007	G-007	1.95
IPL	IPL	1.07
LGEE	LGEE	0.47
MEC	MEC	3.09
MECS	MECS	2.8
NYISO	NYISO	5.43
O-066	O-066	13.54
WEC	WEC	0.46

### 13.6.4 Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308123	200811	26WARREN	PENELEC	200918	26ERIE S TIE	PENELEC	1	PN-P2-3-PN-345-003A	breaker	621.0	101.61	102.13	DC	7.07

Bus #	Bus	MW Impact
200642	26SENECA#1	7.63
200643	26SENECA#2	8.12
200644	26SENECA#3	0.61
200649	26PENNTech	0.71
200894	26K02	2.99
201201	26WRREN CT	2.23
236828	01GRAYMONT	0.29
290086	Q-036 E	2.39
914101	Y2-055	9.33
915952	Y3-092 FTWR	51.58
915953	Y3-092 NFTWR	51.58
916202	Z1-069 E	4.25
919491	AA2-000	35.13
923821	AB2-019	2.89
925512	AC1-025 E	0.11
930411	AB1-082	2.08
930511	AB1-092	1.29
931092	AB1-160 E	1.22
932571	AC2-077	1.46
936421	AD2-055	2.66
936991	AD2-133 C	1.08
936992	AD2-133 E	4.92
939171	AE1-147 C	0.89
939172	AE1-147 E	0.59
940201	AE2-001 C	0.89
940202	AE2-001 E	0.59
940681	AE2-055 C	0.85
940682	AE2-055 E	0.56
940861	AE2-074 C O1	1.58
940862	AE2-074 E O1	2.08
941191	AE2-113 C O1	8.24
941192	AE2-113 E O1	8.87
941251	AE2-119 C	1.02
941252	AE2-119 E	0.68
941261	AE2-120 C	0.88
941262	AE2-120 E	0.59
941271	AE2-121 C	0.47
941272	AE2-121 E	0.32
941321	AE2-126 C	1.31
941322	AE2-126 E	0.88
941331	AE2-129 C	0.86

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
941332	AE2-129 E	0.57
941351	AE2-131 C	0.86
941352	AE2-131 E	0.57
941491	AE2-146 C	6.58
941492	AE2-146 E	9.28
942351	AE2-248 C	0.69
942352	AE2-248 E	0.46
942491	AE2-262 C	4.23
942492	AE2-262 E	2.84
942501	AE2-263 C	3.98
942502	AE2-263 E	2.66
942813	AE2-299 BAT	17.61
942961	AE2-316 C	3.27
942962	AE2-316 E	4.66
BLUEG	BLUEG	5.17
CALDERWOOD	CALDERWOOD	0.45
CANNELTON	CANNELTON	0.31
CATAWBA	CATAWBA	0.24
CBM-N	CBM-N	1.01
CHEOAH	CHEOAH	0.41
CHILHOWEE	CHILHOWEE	0.15
COFFEEN	COFFEEN	0.55
COTTONWOOD	COTTONWOOD	1.91
DUCKCREEK	DUCKCREEK	1.24
EDWARDS	EDWARDS	0.57
ELMERSMITH	ELMERSMITH	0.53
FARMERCITY	FARMERCITY	0.36
G-007A	G-007A	2.38
GIBSON	GIBSON	0.22
HAMLET	HAMLET	0.35
NEWTON	NEWTON	1.44
NYISO	NYISO	4.33
PRAIRIE	PRAIRIE	2.61
SANTEETLA	SANTEETLA	0.12
SMITHLAND	SMITHLAND	0.2
TATANKA	TATANKA	0.66
TILTON	TILTON	0.68
TRIMBLE	TRIMBLE	0.57
TVA	TVA	1.55
UNIONPOWER	UNIONPOWER	0.68
VFT	VFT	6.5

### 13.6.5 Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308570	235197	01KARNSC	AP	235152	01BUTLER	AP	1	ATSI-P1-2-CEI-345-700T	single	179.0	129.56	130.3	DC	2.91

Bus #	Bus	MW Impact
200608	26PINEY #1	0.63
200642	26SENECA#1	2.06
200643	26SENECA#2	2.2
200644	26SENECA#3	0.17
200662	26SCRUB GR	1.32
200805	26COLVER13	7.31
200828	26HNSMLK 1	0.62
200829	26HNSMLK 2	0.62
200830	26HNSMLK 3	0.62
200831	26HNSMLK 4	0.62
200832	26HNSMLK 5	0.62
200849	26LAKVU GN	0.05
201201	26WRREN CT	0.53
235030	01MHNG-T155	0.14
903643	W3-099 C OP1	1.03
914101	Y2-055	2.21
915951	Y3-092 FTIR	85.82
919491	AA2-000	26.52
930411	AB1-082	1.22
930511	AB1-092	0.97
932571	AC2-077	1.12
935191	AD1-154	2.38
936421	AD2-055	2.0
936991	AD2-133 C	0.92
938951	AE1-123	2.87
939171	AE1-147 C	0.62
939291	AE1-160 C	1.54
939381	AE1-169 C O1	6.35
940201	AE2-001 C	0.62
940861	AE2-074 C O1	0.93
941191	AE2-113 C O1	4.25
941251	AE2-119 C	0.75
941261	AE2-120 C	0.62
941271	AE2-121 C	0.33
941321	AE2-126 C	0.8
941331	AE2-129 C	0.67
941351	AE2-131 C	0.67
941491	AE2-146 C	4.43
942351	AE2-248 C	0.48
942491	AE2-262 C	2.91
942501	AE2-263 C	2.74

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
942811	AE2-299 C	2.52
942961	AE2-316 C	4.42
943151	AE2-344 C O1	6.23
BLUEG	BLUEG	3.44
CALDERWOOD	CALDERWOOD	0.32
CANNELTON	CANNELTON	0.21
CATAWBA	CATAWBA	0.18
CBM-N	CBM-N	1.7
CHEOAH	CHEOAH	0.29
CHILHOWEE	CHILHOWEE	0.11
COFFEEN	COFFEEN	0.36
COTTONWOOD	COTTONWOOD	1.31
DUCKCREEK	DUCKCREEK	0.8
EDWARDS	EDWARDS	0.37
ELMERSMITH	ELMERSMITH	0.35
FARMERCITY	FARMERCITY	0.24
G-007A	G-007A	1.67
GIBSON	GIBSON	0.14
HAMLET	HAMLET	0.27
NEWTON	NEWTON	0.94
NYISO	NYISO	7.42
PRAIRIE	PRAIRIE	1.73
SANTEETLA	SANTEETLA	0.09
SMITHLAND	SMITHLAND	0.13
TATANKA	TATANKA	0.43
TILTON	TILTON	0.44
TRIMBLE	TRIMBLE	0.38
TVA	TVA	1.08
UNIONPOWER	UNIONPOWER	0.47
VFT	VFT	4.64

### 13.6.6 Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308955	235203	01KISSNG	AP	235197	01KARNSC	AP	1	PN-P1-2-PN-345-107T	single	268.0	104.04	104.56	DC	3.07

Bus #	Bus	MW Impact
200608	26PINEY #1	0.66
200642	26SENECA#1	2.17
200643	26SENECA#2	2.32
200644	26SENECA#3	0.17
200662	26SCRUB GR	1.39
200805	26COLVER13	7.71
200828	26HNSMLK 1	0.65
200829	26HNSMLK 2	0.65
200830	26HNSMLK 3	0.65
200831	26HNSMLK 4	0.65
200832	26HNSMLK 5	0.65
200849	26LAKVU GN	0.05
201201	26WRREN CT	0.56
903643	W3-099 C OP1	1.09
914101	Y2-055	2.33
915951	Y3-092 FTIR	90.39
919491	AA2-000	27.96
930411	AB1-082	1.29
930511	AB1-092	1.03
932571	AC2-077	1.18
935191	AD1-154	2.51
936421	AD2-055	2.11
936991	AD2-133 C	0.97
938951	AE1-123	3.02
939171	AE1-147 C	0.65
939291	AE1-160 C	1.62
939381	AE1-169 C O1	6.69
940201	AE2-001 C	0.65
940681	AE2-055 C	0.63
940861	AE2-074 C O1	0.98
941191	AE2-113 C O1	4.48
941251	AE2-119 C	0.79
941261	AE2-120 C	0.65
941271	AE2-121 C	0.35
941321	AE2-126 C	0.84
941331	AE2-129 C	0.71
941351	AE2-131 C	0.71
941491	AE2-146 C	4.67
942351	AE2-248 C	0.51
942491	AE2-262 C	3.07
942501	AE2-263 C	2.89

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
942811	AE2-299 C	2.66
942961	AE2-316 C	4.65
943151	AE2-344 C O1	6.56
BLUEG	BLUEG	3.7
CALDERWOOD	CALDERWOOD	0.35
CANNELTON	CANNELTON	0.22
CATAWBA	CATAWBA	0.19
CBM-N	CBM-N	1.8
CHEOAH	CHEOAH	0.32
CHILHOWEE	CHILHOWEE	0.11
COFFEEN	COFFEEN	0.39
COTTONWOOD	COTTONWOOD	1.41
DUCKCREEK	DUCKCREEK	0.86
EDWARDS	EDWARDS	0.39
ELMERSMITH	ELMERSMITH	0.38
FARMERCITY	FARMERCITY	0.25
G-007A	G-007A	1.8
GIBSON	GIBSON	0.15
HAMLET	HAMLET	0.29
NEWTON	NEWTON	1.01
NYISO	NYISO	7.87
PRAIRIE	PRAIRIE	1.85
SANTEETLA	SANTEETLA	0.09
SMITHLAND	SMITHLAND	0.14
TATANKA	TATANKA	0.46
TILTON	TILTON	0.47
TRIMBLE	TRIMBLE	0.41
TVA	TVA	1.16
UNIONPOWER	UNIONPOWER	0.51
VFT	VFT	5.0

### 13.6.7 Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7307286	938380	AE1-071 TAP	PENELEC	200520	26ROXBURY	PENELEC	1	PL:10:P22:100582	bus	160.0	105.09	107.29	DC	7.8

Bus #	Bus	MW Impact
200812	26ALY HYDR	0.31
200852	26WARR RDG	0.09
236828	01GRAYMONT	0.45
290086	Q-036 E	2.36
293301	N-039 E	3.84
293802	O-038 E	2.4
294515	P-022 E	0.96
919491	AA2-000	29.83
925512	AC1-025 E	0.17
930511	AB1-092	1.1
936421	AD2-055	2.25
936991	AD2-133 C	1.06
936992	AD2-133 E	4.85
938381	AE1-071 C	41.88
938382	AE1-071 E	25.63
939171	AE1-147 C	1.34
939172	AE1-147 E	0.89
940201	AE2-001 C	1.35
940202	AE2-001 E	0.9
940681	AE2-055 C	1.41
940682	AE2-055 E	0.94
941231	AE2-117 C	1.47
941232	AE2-117 E	0.98
941241	AE2-118 C	1.47
941242	AE2-118 E	0.98
941251	AE2-119 C	0.84
941252	AE2-119 E	0.56
941261	AE2-120 C	1.35
941262	AE2-120 E	0.9
941271	AE2-121 C	0.71
941272	AE2-121 E	0.47
941321	AE2-126 C	0.77
941322	AE2-126 E	0.51
941331	AE2-129 C	0.77
941332	AE2-129 E	0.51
941351	AE2-131 C	0.77
941352	AE2-131 E	0.51
942031	AE2-215 C	13.9
942032	AE2-215 E	9.27
942351	AE2-248 C	1.11
942352	AE2-248 E	0.74

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
942491	AE2-262 C	4.67
942492	AE2-262 E	3.14
942501	AE2-263 C	4.39
942502	AE2-263 E	2.93
942511	AE2-264 C	4.79
942512	AE2-264 E	3.19
CATAWBA	CATAWBA	0.02
CBM-N	CBM-N	0.51
CBM-S1	CBM-S1	0.34
CBM-W1	CBM-W1	1.35
CBM-W2	CBM-W2	3.21
CIN	CIN	0.47
G-007	G-007	0.35
HAMLET	HAMLET	0.07
IPL	IPL	0.31
LGEE	LGEE	0.13
MEC	MEC	0.82
MECS	MECS	1.12
NYISO	NYISO	2.21
O-066	O-066	2.02
WEC	WEC	0.14

### 13.6.8 Index 8

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7308119	941190	AE2-113 TAP	PENELEC	200668	26FARM VLY	PENELEC	1	PN-P2-3-PN-230-8M_SUM_WIN	breaker	160.0	101.3	103.07	DC	6.25

Bus #	Bus	MW Impact
200649	26PENNTech	1.29
236828	01GRAYMONT	0.26
290086	Q-036 E	2.13
919491	AA2-000	27.18
925512	AC1-025 E	0.09
930511	AB1-092	1.0
936421	AD2-055	2.05
936991	AD2-133 C	0.96
936992	AD2-133 E	4.37
939171	AE1-147 C	0.77
939172	AE1-147 E	0.52
940201	AE2-001 C	0.77
940202	AE2-001 E	0.51
940681	AE2-055 C	0.73
940682	AE2-055 E	0.49
941191	AE2-113 C O1	35.95
941192	AE2-113 E O1	38.71
941251	AE2-119 C	1.08
941252	AE2-119 E	0.72
941261	AE2-120 C	0.77
941262	AE2-120 E	0.51
941271	AE2-121 C	0.41
941272	AE2-121 E	0.28
941321	AE2-126 C	1.96
941322	AE2-126 E	1.31
941331	AE2-129 C	0.84
941332	AE2-129 E	0.56
941351	AE2-131 C	0.84
941352	AE2-131 E	0.56
942351	AE2-248 C	0.6
942352	AE2-248 E	0.4
942491	AE2-262 C	3.74
942492	AE2-262 E	2.51
942501	AE2-263 C	3.52
942502	AE2-263 E	2.35
942961	AE2-316 C	2.67
942962	AE2-316 E	3.81
BLUEG	BLUEG	0.96
CALDERWOOD	CALDERWOOD	0.08
CANNELTON	CANNELTON	0.06
CARR	CARR	0.27

<b>Bus #</b>	<b>Bus</b>	<b>MW Impact</b>
CATAWBA	CATAWBA	0.04
CHEOAH	CHEOAH	0.07
CHILHOWEE	CHILHOWEE	0.03
COFFEEN	COFFEEN	0.1
COTTONWOOD	COTTONWOOD	0.35
DUCKCREEK	DUCKCREEK	0.23
EDWARDS	EDWARDS	0.11
ELMERSMITH	ELMERSMITH	0.1
FARMERCITY	FARMERCITY	0.07
G-007A	G-007A	0.58
GIBSON	GIBSON	0.04
HAMLET	HAMLET	0.06
NEWTON	NEWTON	0.27
PRAIRIE	PRAIRIE	0.48
RENSELAER	RENSELAER	0.2
SANTEETLA	SANTEETLA	0.02
SMITHLAND	SMITHLAND	0.04
TATANKA	TATANKA	0.12
TILTON	TILTON	0.13
TRIMBLE	TRIMBLE	0.11
TVA	TVA	0.28
UNIONPOWER	UNIONPOWER	0.12
VFT	VFT	1.55

## Affected Systems

## **13.7 Affected Systems**

### **13.7.1 LG&E**

LG&E Impacts to be determined during later study phases (as applicable).

### **13.7.2 MISO**

MISO Impacts to be determined during later study phases (as applicable).

### **13.7.3 TVA**

TVA Impacts to be determined during later study phases (as applicable).

### **13.7.4 Duke Energy Progress**

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

### **13.7.5 NYISO**

NYISO Impacts to be determined during later study phases (as applicable).

## 13.8 Contingency Descriptions

Contingency Name	Contingency Definition
PN-P2-3-PN-345-003A	CONTINGENCY 'PN-P2-3-PN-345-003A' /* WAYNE 345KV STUCK BREAKER DISCONNECT BUS 200595 /* 26WAYNE 345 END
PN-P2-3-PN-230-8M_SUM_WIN	CONTINGENCY 'PN-P2-3-PN-230-8M_SUM_WIN' /* GLADE STUCK BREAKER B42 (FOREST/SENECA) DISCONNECT BRANCH FROM BUS 200581 TO BUS 200593 CKT 1 /* 26FOREST 230 26GLADE 230 DISCONNECT BRANCH FROM BUS 200593 TO BUS 200594 CKT 1 /* 26GLADE 230 26SENECA 230 DISCONNECT BRANCH FROM BUS 200594 TO BUS 200642 CKT 1 /* 26SENECA 230 26SENECA#1 14 DISCONNECT BRANCH FROM BUS 200594 TO BUS 200643 CKT 1 /* 26SENECA 230 26SENECA#2 14 DISCONNECT BRANCH FROM BUS 200594 TO BUS 200644 CKT 1 /* 26SENECA 230 26SENECA#3 14 REMOVE MACHINE 1G FROM BUS 200642 /* 26SENECA#1 14 REMOVE MACHINE 2G FROM BUS 200643 /* 26SENECA#2 14 REMOVE MACHINE 3 FROM BUS 200644 /* 26SENECA#3 14 END
AP-P2-3-WP-230-443T *	CONTINGENCY 'AP-P2-3-WP-230-443T *' / UPDATED CON AJK 3-31-16 DISCONNECT BRANCH FROM BUS 200726 TO BUS 235175 CKT 1 DISCONNECT BRANCH FROM BUS 235175 TO BUS 235236 CKT 1 DISCONNECT BUS 235158 END
ATSI-P1-2-CEI-345-700T	CONTINGENCY 'ATSI-P1-2-CEI-345-700T' /* PN/ATSI ERIE WEST - ASHTABULA - PERRY 345KV DISCONNECT BRANCH FROM BUS 239036 TO BUS 238547 CKT 1 /* 02PERRY 345 02AT 345 DISCONNECT BRANCH FROM BUS 238547 TO BUS 239082 CKT 1 /* 02AT 345 02S8-ATT 345 DISCONNECT BRANCH FROM BUS 239082 TO BUS 238544 CKT 8 /* 02S8-ATT 345 02ASH_3 138 DISCONNECT BRANCH FROM BUS 238547 TO BUS 200599 CKT 1 /* 02AT 345 26ERIE W 345 END
AP-P2-2-WP-230-001T	CONTINGENCY 'AP-P2-2-WP-230-001T' DISCONNECT BRANCH FROM BUS 235175 TO BUS 235158 CKT 1 DISCONNECT BRANCH FROM BUS 235175 TO BUS 235236 CKT 1 DISCONNECT BRANCH FROM BUS 235175 TO BUS 200726 CKT 1 END
PL:10:P22:100582	CONTINGENCY 'PL:10:P22:100582' /* JUNIATA 230KV BUS 2 DISCONNECT BUS 208005 /* END
235104 01CABOT 500 239280 02CRNBRY 500 1	CONTINGENCY '235104 01CABOT 500 239280 02CRNBRY 500 1' / 8388 OPEN BRANCH FROM BUS 235104 TO BUS 239280 CKT 1 / 235104 01CABOT 500 239280 02CRNBRY 500 1 END
PN-P1-2-PN-345-107T	CONTINGENCY 'PN-P1-2-PN-345-107T' /* ERIE WEST - ASHTABULA - PERRY 345KV DISCONNECT BRANCH FROM BUS 200599 TO BUS 238547 CKT 1 /* 26ERIE W 345 02AT 345 DISCONNECT BRANCH FROM BUS 238547 TO BUS 239082 CKT 1 /* 02AT 345 02S8-ATT 345 DISCONNECT BRANCH FROM BUS 238547 TO BUS 239036 CKT 1 /* 02AT 345 02PERRY 345 DISCONNECT BUS 238547 /* 02AT 345 END

Contingency Name	Contingency Definition
<b>PN-P2-2-PN-230-006AT</b>	CONTINGENCY 'PN-P2-2-PN-230-006AT' /* LEWISTOWN #1 230KV BUS / PJM FIXED DISCONNECT BRANCH FROM BUS 200513 TO BUS 208005 CKT 1 /* 26LEWISTWN 230 JUNI BU2 230 /UPDATED JUNI BUS # DISCONNECT BRANCH FROM BUS 200513 TO BUS 200531 CKT 1 /* 26LEWISTWN 230 26YEAGRTWN 230 DISCONNECT BRANCH FROM BUS 200513 TO BUS 200512 TO BUS 200548 CKT 1/* 26LEWISTWN 230 26LEWISTWN 115 26LEWISTWN 46.00 REDUCE BUS 200513 SHUNT BY 100 PERCENT /* 26LEWISTWN 230 END
<b>AP-P2-3-WP-230-446T</b>	CONTINGENCY 'AP-P2-3-WP-230-446T' /* ELKO-MOSHANNON STK BKR AT ELKO DISCONNECT BRANCH FROM BUS 200726 TO BUS 235175 CKT 1 /* 26SHAWVL 2 230 01ELKO 230 DISCONNECT BRANCH FROM BUS 235158 TO BUS 235175 CKT 1 /* 01CARB 230 01ELKO 230 DISCONNECT BRANCH FROM BUS 235175 TO BUS 235236 CKT 1 /* 01ELKO 230 01QUEHAN 230 DISCONNECT BRANCH FROM BUS 235220 TO BUS 235236 CKT 1 /* 01MOSHAN 230 01QUEHAN 230 DISCONNECT BRANCH FROM BUS 235236 TO BUS 236732 CKT 81 /* 01QUEHAN 230 01QUEHANNA 46 END
<b>PN-P2-3-PN-230-3C</b>	CONTINGENCY 'PN-P2-3-PN-230-3C' /* EAST TOWANDA 230KV SB62 OR SB44 (SAME AS LINE) DISCONNECT BRANCH FROM BUS 200675 TO BUS 200924 CKT 1 /* 26E.TWANDA 230 26CANYON 230 DISCONNECT BRANCH FROM BUS 200706 TO BUS 200924 CKT 1 /* 26N.MESHPN 230 26CANYON 230 END

## Short Circuit

### 13.9 Short Circuit

The following Breakers are overduty:

None

## 14 Attachment 1 – One Line

**15 Attachment 2 – Project Location**