

Generation Interconnection Feasibility Study Report Queue Position AE2-335

The Interconnection Customer (IC) has proposed a 60.0 MW Energy (41.5 MW Capacity) combined solar and storage generating facility to be located at Latitude: 39.6124090, Longitude: -75.0380200 in Gloucester County, New Jersey. At the IC's request, PJM studied the AE2-335 project at both a Primary and Secondary Point of Interconnection. The project was studied at a commercial probability of 53% with the results provided below. The planned in-service date, as requested by the IC during the project kick-off call, is June 30, 2022. This date is dependent on completion of PJM studies (System Impact and Facilities) and the Transmission Owner's construction schedule for network upgrades.

Point(s) of Interconnection

The Interconnection Customer requested a Primary and Secondary Point of Interconnection (POI) be evaluated for the AE2-335 project.

Primary Point of Interconnection

PJM studied the AE2-335 project as an injection into the Atlantic City Electric Company (ACE) transmission system at the Franklin 138 kV Substation (PSSE bus #228482) and evaluated it for compliance with reliability criteria for summer peak conditions in 2022. The AE2-335 project will connect with the ACE transmission system at the 138 kV Franklin Substation where it will connect to a new 138 kV bus position.

Transmission Owner Scope of Attachment Facilities Work

Substation Interconnection Estimate

Scope: Build a new position onto the 138 kV bus at Franklin Substation. The new position will facilitate the interconnection of AE2-335 facility.

Estimate: \$2,600,000

Construction Time: 36-48 months

Major Equipment Included in Estimate:

- Power Circuit Breaker, 138 kV Qty. 1
- Breaker Disconnect, 138 kV Qty. 4
- Line Disconnect, 138 kV Qty. 1
- Double 1590 ACSR (325') Qty. 3
- Disconnect Switch Stand, Low, 138 kV, Steel Qty. 1
- Relay Panel, Bus, FL/BU (20") Qty. 1
- Control Panel, 138 kV Circuit Breaker (10") Qty. 1
- Take-off structure, 138 kV Qty. 1
- 138 kV Lightning Arresters Qty. 3

- 138 kV Lightning Arresters Stands Qty. 3
- Potential Transformer, 3-phase Qty. 1

Estimate Assumptions:

- Space available in control enclosure for new relay panel.
- Fiber optic cable necessary is 1,000 linear feet.
- Developer to purchase additional land for substation expansion.
- Existing AC & DC systems are adequate
- Existing ground grid and storm water management requires southward expansion.

Required Relaying and Communications

New protection relays are required for the new terminals.

Front line and back-up line protection will be required. One relay panel for each generator terminal will be required for front line and back-up protection.

A breaker control relay on a breaker control panel will be required for the control and operation of each new 138 kV circuit breaker (1 total).

The project will require re-wiring and adjustment of existing relay schemes to accommodate the new 138 kV position at Franklin substation.

Metering

A three phase 138 kV revenue metering point will need to be established within the IC facility at the POI.

The IC will purchase and install all metering instrument transformers, as well as construct a metering structure per ACE’s specifications. The secondary wiring connections at the instrument transformers will be completed by the IC’s contractors and inspected by ACE, while the secondary wiring work at the metering enclosure will be completed by ACE’s meter technicians. The metering control cable and meter cabinets will be supplied by ACE and installed by the IC’s contractors. ACE’s meter technicians will program and install two solid state multi-function meters (Primary & Backup) for each new metering position. Each meter will be equipped with load profile, telemetry, and DNP outputs. The IC will be provided with one (1) meter DNP output.

The IC will be required to make provisions for a POTS (plain old telephone service) line within approximately three (3) feet of each ACE metering position to facilitate remote interrogation and data collection.

Interconnection Customer Scope of Direct Connection Work

The IC is responsible for all design and construction related to activities on their side of the Point of Interconnection. Site preparation, including grading and an access road, as necessary, is assumed to be by the IC. Route selection, line design, and right-of-way acquisition of the direct connect facilities is not included in this report, and is the responsibility of the IC. Protective relaying and metering design and installation must comply with ACE’s applicable standards. The IC is also required to

provide revenue metering and real-time telemetering data to PJM in conformance with the requirements contained in PJM Manuals M-01 and M-14 and the PJM Tariff.

ACE Interconnection Customer Scope of Direct Connection Work Requirements:

- ACE requires that an IC circuit breaker is located within 500 feet of the ACE substation to facilitate the relay protection scheme between ACE and the IC at the Point of Interconnection (POI).

Special Operating Requirements

1. ACE will require the capability to remotely disconnect the generator from the grid by communication from its System Operations facility. Such disconnection may be facilitated by a generator breaker, or other method depending upon the specific circumstances and the evaluation by ACE.
2. ACE reserves the right to charge the Interconnection Customer operation and maintenance expenses to maintain the Interconnection Customer attachment facilities, including metering and telecommunications facilities, owned by ACE.

Summer Peak Analysis - 2022

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8558747	228402	MONROE	AE	219100	NEWFRDM	PSE&G	1	PS_P7-1_V2274+P2242_LT	tower	804.0	96.29	100.03	DC	29.69

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8557804	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B	bus	1180.0	107.07	107.6	DC	13.86
8558092	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1180.0	107.06	107.59	DC	13.86
8557806	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B	bus	1336.0	106.18	106.68	DC	14.79
8558094	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	106.16	106.67	DC	14.79
8558689	219100	NEWFRDM	PSE&G	219704	HILLTOP_3	PSE&G	1	PS_P7-1_V2274+P2242_LT	tower	740.0	123.86	124.88	DC	7.52
8558690	219100	NEWFRDM	PSE&G	219704	HILLTOP_3	PSE&G	1	AE_P7-1 W2275_O2241	tower	740.0	117.81	118.84	DC	7.55
8557805	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B	bus	1336.0	106.19	106.7	DC	14.79
8558093	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	106.18	106.68	DC	14.79

Summer Peak Load Flow Analysis Reinforcements

System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

ID	Index	Facility	Upgrade Description	Cost
8557804,8558092	4	RICHMOND 230.0 kV - WANEETA3 230.0 kV Ckt 1	<u>PECO</u> pe001 (678) : Change connection point for Chichester-Eddystone 220-36 line at Chichester from #1 bus to #2 kV bus Project Type : CON Cost : \$3,000,000 Time Estimate : 24.0 Months	\$3,000,000
8557806,8558094	5	RICHRE29 230.0 kV - RICHMOND 230.0 kV Ckt 1	<u>PSEG</u> r_PS_AE2_FES_CamRich (730) : No Violation. PSEG emergency rating 1497 MVA. Project Type : FAC Cost : \$0 Time Estimate : 0.0 Months	
8557805,8558093	7	CAMDEN 230.0 kV - RICHRE29 230.0 kV Ckt 1		
8558690,8558689	6	NEWFRDM 230.0 kV - HILLTOP_3 230.0 kV Ckt 1	<u>PSEG</u> r_PS_AE2_FES_11_NFreedHill (753) : Wreck and Rebuild Project Type : FAC Cost : \$76,885,198 Time Estimate : 55.0 Months	\$76,885,198

ID	Index	Facility	Upgrade Description	Cost
8558747	2	MONROE 230.0 kV - NEWFRDM 230.0 kV Ckt 1	<p>AEC at2305r0001 (52) : To mitigate the (ACE) Monroe to New Freedom 230 kV line (from bus 228402 to bus 219100 ckt 1) overload, it will require increasing the emergency rating of the Monroe to New Freedom 230 kV line by rebuilding the circuit. The rebuild will include the installation of new poles, foundations, insulators, and conductor. Project Type : FAC Cost : \$13,400,000 Time Estimate : 30-60 Months</p> <p>PSEG r_PS_AE2_FES_MonroeNewFrdm (741) : No Violation. PSEG emergency rating 1572 MVA. Project Type : FAC Cost : \$0 Time Estimate : 0.0 Months</p>	\$13,400,000
			TOTAL COST	\$93,285,198

Steady-State Voltage Requirements

To be performed during later study phases as required.

Short Circuit

No issues identified.

Stability and Reactive Power Requirement

To be performed during later study phase.

Light Load Analysis - 2022

To be performed during later study phases (as required by PJM Manual 14B).

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request. Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
----	-----------	----------	---------------	---------	--------	-------------	--------	-----------	------	------------	-----------------------	------------------------	-------	-----------

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8558485	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	Base Case	operation	760.0	104.2	104.94	DC	12.32
8558486	219110	GLOUCSTR	PSE&G	219755	CUTHBERT_4	PSE&G	1	PS_P1-2_C-2308_LT	operation	758.0	103.87	104.39	DC	8.57
8558221	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	Base Case	operation	154.0	181.92	187.82	DC	9.07
8558223	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	AE_P1-1 913341[Y1-077]-1-GEN	operation	205.0	156.42	160.85	DC	9.07
8558441	227902	LEWIS #1	AE	227945	LEWIS #2	AE	1	AE_P1-2 BLE-ML-LEW2	operation	286.8	115.43	115.98	DC	3.48
8558469	228404	MONROE	AE	228402	MONROE	AE	2	AE_P1-3 MON 3 XFR	operation	274.0	97.66	110.41	DC	34.93
8558492	228404	MONROE	AE	228402	MONROE	AE	1	AE_P1-3 MON 4 XFR	operation	292.0	92.55	104.62	DC	35.27

Atlantic City Electric Costs

Cost estimates will further be refined as a part of the Impact Study and Facilities Study for this project. The Interconnection Customer will be responsible for all costs incurred by ACE in connection with the AE2-335 project.

Secondary Point of Interconnection

PJM studied the AE2-335 project into the Atlantic City Electric Company (ACE) system at a tap of the Monroe (PSSE bus # 228404) to Landis (PSSE bus #228500) 138 kV circuit and evaluated it for compliance with reliability criteria for summer peak conditions in 2022.

Summer Peak Analysis - 2022

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1834621	228404	MONROE	AE	228402	MONROE	AE	2	AE_P1-3 MON 3 XFR	single	274.0	93.74	102.34	DC	23.57

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
430568	200051	ROCKSPGS	PJM	200065	PCHBTM2S	PJM	1	JC-P2-3-JCC-500-002D	breaker	2905.0	99.81	100.12	DC	19.47
1621844	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P2-	bus	1180.0	119.47	120.0	DC	13.83

								2_CHI230B1/* \$ DELCO \$ PECO_P2- 2_CHI230B1 \$ B						
1715079	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1180.0	119.46	119.99	DC	13.83
1715080	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P4_PEACH215/* \$ CHESCO \$ PECO_P4_PEACH215 \$ STBK	breaker	1180.0	106.07	106.65	DC	15.19
1621854	214010	WANEETA2	PECO	213817	N PHILA	PECO	1	PECO_P2- 2_CHI230B1/* \$ DELCO \$ PECO_P2- 2_CHI230B1 \$ B	bus	621.0	107.65	108.16	DC	7.03
1715150	214010	WANEETA2	PECO	213817	N PHILA	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	621.0	107.6	108.11	DC	7.03
1621846	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P2- 2_CHI230B1/* \$ DELCO \$ PECO_P2- 2_CHI230B1 \$ B	bus	1336.0	117.77	118.27	DC	14.75
1715087	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	117.75	118.26	DC	14.75
1715088	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P4_PEACH215/* \$ CHESCO \$ PECO_P4_PEACH215 \$ STBK	breaker	1336.0	105.77	106.32	DC	16.24
1715120	219110	GLOUCSTR	PSE&G	219125	CAMDEN	PSE&G	1	PS_P2-3_CUTB_1-4_LT	breaker	771.0	112.21	112.71	DC	8.35
1715121	219110	GLOUCSTR	PSE&G	219125	CAMDEN	PSE&G	1	PS_P2-3_CUTB_3-4_LT	breaker	771.0	110.68	111.17	DC	8.23
1715122	219110	GLOUCSTR	PSE&G	219125	CAMDEN	PSE&G	1	PS_P2-3_CUTB_1-2_LT	breaker	771.0	108.18	108.66	DC	8.06
1715123	219110	GLOUCSTR	PSE&G	219125	CAMDEN	PSE&G	1	PS_P2-3_CUTB_2-3_LT	breaker	771.0	106.49	106.96	DC	7.92
1621845	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P2- 2_CHI230B1/* \$ DELCO \$ PECO_P2- 2_CHI230B1 \$ B	bus	1336.0	117.78	118.29	DC	14.75
1715082	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	117.77	118.27	DC	14.75
1715083	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P4_PEACH215/* \$ CHESCO \$ PECO_P4_PEACH215 \$ STBK	breaker	1336.0	105.78	106.34	DC	16.24
1714964	227902	LEWIS #1	AE	227945	LEWIS #2	AE	1	AE_P4-2 AE33	breaker	286.8	161.07	163.86	DC	8.01
1899594	228312	PEDRKWTN	AE	228313	BRIDGPRT	AE	1	AE_P7-1 AE10TOWER- A	tower	552.0	107.47	110.51	DC	16.63
1899595	228312	PEDRKWTN	AE	228313	BRIDGPRT	AE	1	AE_P7-1 AE8TOWER-A	tower	552.0	106.78	109.82	DC	16.63
1899623	228313	BRIDGPRT	AE	228401	MCKLTON	AE	1	AE_P7-1 AE10TOWER- A	tower	805.0	99.66	101.75	DC	16.56
1899624	228313	BRIDGPRT	AE	228401	MCKLTON	AE	1	AE_P7-1 AE8TOWER-A	tower	805.0	99.2	101.29	DC	16.56
1899565	228500	LANDIS	AE	228211	UPITTS	AE	1	AE_P7-1 AE10TOWER- A	tower	205.0	104.58	119.44	DC	30.46
1899566	228500	LANDIS	AE	228211	UPITTS	AE	1	AE_P7-1 AE8TOWER-A	tower	205.0	101.6	116.46	DC	30.46

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1714961	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	AE_P4-2 AE46	breaker	205.0	163.42	168.01	DC	9.42
1834372	227901	DOROTHY	AE	227949	LEWIS	AE	1	Base Case	single	154.0	176.46	180.76	DC	6.62

					#3									
1834375	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	AE_P1-1 913341[Y1-077]-1-GEN	single	205.0	152.27	155.5	DC	6.62
1899457	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	AE_P7-1 AE10TOWER-A	tower	205.0	205.14	219.55	DC	29.53
1899458	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	AE_P7-1 AE8TOWER-A	tower	205.0	202.34	216.74	DC	29.53

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request. Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1834532	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	Base Case	operation	760.0	121.28	122.01	DC	12.28
1834533	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P1-2_5014/* \$ CHESCO \$ PECO_P1-2_5014 \$ L	operation	1180.0	103.07	103.65	DC	15.19
1834661	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P1-2_5014/* \$ CHESCO \$ PECO_P1-2_5014 \$ L	operation	1336.0	103.36	103.91	DC	16.24
1834568	219108	CUTHBERT	PSE&G	219125	CAMDEN	PSE&G	1	PS_P1-2_U-2299_LT	operation	771.0	116.26	116.81	DC	9.14
1834570	219108	CUTHBERT	PSE&G	219125	CAMDEN	PSE&G	1	Base Case	operation	500.0	104.38	104.88	DC	5.43
1834537	219110	GLOUCSTR	PSE&G	219755	CUTHBERT_4	PSE&G	1	PS_P1-2_C-2308_LT	operation	758.0	121.02	121.54	DC	8.54
1834540	219110	GLOUCSTR	PSE&G	219755	CUTHBERT_4	PSE&G	1	Base Case	operation	550.0	108.58	109.04	DC	5.54
1834574	219110	GLOUCSTR	PSE&G	219125	CAMDEN	PSE&G	1	Base Case	operation	500.0	116.19	116.7	DC	5.6
1834609	219110	GLOUCSTR	PSE&G	219753	CUTHBERT_2	PSE&G	1	PS_P1-2_D-2282_LT	operation	771.0	112.87	113.36	DC	8.1
1834657	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P1-2_5014/* \$ CHESCO \$ PECO_P1-2_5014 \$ L	operation	1336.0	103.37	103.93	DC	16.24
1834625	219754	CUTHBERT_3	PSE&G	219125	CAMDEN	PSE&G	1	PS_P1-2_Z-2305_LT	operation	792.0	110.55	111.07	DC	8.92
1834371	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	Base Case	operation	154.0	181.92	188.14	DC	9.57
1834373	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	AE_P1-1 913341[Y1-077]-1-GEN	operation	205.0	156.37	161.04	DC	9.57
1834649	228312	PEDRKTWN	AE	228313	BRIDGPRT	AE	1	AE_P1-2 ORCHARD XF	operation	552.0	106.09	106.67	DC	7.02
1834620	228404	MONROE	AE	228402	MONROE	AE	2	AE_P1-3 MON 3 XFR	operation	274.0	99.02	111.46	DC	34.08
1834653	228404	MONROE	AE	228402	MONROE	AE	1	AE_P1-3 MON 4 XFR	operation	292.0	93.84	105.62	DC	34.41

1834557	228500	LANDIS	AE	228482	FRANKLIN	AE	1	AE_P1-2 MONROE- LANDIS_1- A	operation	331.0	110.83	119.93	DC	30.12
---------	--------	--------	----	--------	----------	----	---	--------------------------------------	-----------	-------	--------	--------	----	-------

Primary POI Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8558747	228402	MONROE	AE	219100	NEWFRDM	PSE&G	1	PS_P7- 1_V2274+P2242_LT	tower	804.0	96.29	100.03	DC	29.69

Bus #	Bus	MW Impact
219229	EAGLEPT_G3	3.06
219230	EAGLEPT_G1	4.53
219231	EAGLEPT_G2	4.53
227801	ONTC&DCT	4.5
227843	MARINGEN E	0.47
227881	GRENWCHG	0.07
228261	V4-054E	1.49
228304	LOGAN	9.42
228306	PCLP STM	2.46
228357	V2-046E	3.93
228400	MICK 1CT	1.81
228423	Q-090 2	39.66
228471	VALERO1	0.61
228472	VALERO2	0.48
228473	VALERO3	0.48
228484	VALERO4	0.36
228712	V2-041E	0.42
228720	V2-035C	0.04
228721	V2-035E	0.48
291995	U4-036 C	0.1
291996	U4-036 E	1.33
292063	V1-021 E	0.04
292104	V1-030 C6	0.03

Bus #	Bus	MW Impact
292105	V1-030 E6	0.39
293404	V3-036	0.64
902091	W1-130C	0.17
902092	W1-130E	2.24
909032	X2-013 E	0.83
915022	Y3-012 E	0.87
924051	AB2-049 C	0.7
924052	AB2-049 E	1.14
924531	AB2-102 C	32.19
924532	AB2-102 E	0.72
930002	AB1-001 E	0.17
930722	AB1-116 E	0.21
930732	AB1-119 E	0.1
931191	AB1-169A	197.31
933962	AD1-019 E	0.89
936411	AD2-052 C	1.83
936412	AD2-052 E	0.9
936491	AD2-064 C	0.07
936492	AD2-064 E	0.1
938311	AE1-046 C	0.72
938312	AE1-046 E	0.36
938421	AE1-061 C	1.81
938422	AE1-061 E	1.81
938781	AE1-104 C O1	17.91
938782	AE1-104 E O1	45.81
938871	AE1-115 C	1.55
938872	AE1-115 E	1.55
939301	AE1-161 C	8.83
939302	AE1-161 E	13.25
939501	AE1-179 C O1	7.6
939502	AE1-179 E O1	5.37
939821	AE1-218 C O1	0.3
939822	AE1-218 E O1	0.45
939831	AE1-219 C O1	0.68
939832	AE1-219 E O1	0.98
939931	AE1-229 C O1	30.55
939932	AE1-229 E O1	20.7
940001	AE1-240 C O1	6.26
940002	AE1-240 E O1	4.46
940281	AE2-011 C	0.18
940282	AE2-011 E	0.25
940391	AE2-023 C O1	10.07
940392	AE2-023 E O1	47.12
940781	AE2-065 C	0.29
940782	AE2-065 E	0.46
940961	AE2-087 C	0.35
940962	AE2-087 E	0.49
940963	AE2-087 BAT	0.13
940971	AE2-088 C	0.37
940972	AE2-088 E	0.5
940973	AE2-088 BAT	0.39
941001	AE2-091 C O1	5.23

Bus #	Bus	MW Impact
941002	AE2-091 E O1	2.73
941071	AE2-101 C	0.55
941072	AE2-101 E	0.76
941121	AE2-106 C	0.39
941122	AE2-106 E	0.54
941123	AE2-106 BAT	0.13
941471	AE2-144 C	0.6
941472	AE2-144 E	1.06
941931	AE2-205 C O1	6.7
941932	AE2-205 E O1	4.46
942011	AE2-213 C	0.48
942012	AE2-213 E	0.82
942101	AE2-222 C O1	9.96
942102	AE2-222 E O1	25.02
942571	AE2-272	0.43
943071	AE2-334 C	10.71
943072	AE2-334 E	5.71
943081	AE2-335 C O1	20.53
943082	AE2-335 E O1	9.15
BLUEG	BLUEG	2.36
CALDERWOOD	CALDERWOOD	0.25
CANNELTON	CANNELTON	0.14
CARR	CARR	0.39
CATAWBA	CATAWBA	0.16
CHEOAH	CHEOAH	0.23
CHILHOWEE	CHILHOWEE	0.08
COFFEEN	COFFEEN	0.25
COTTONWOOD	COTTONWOOD	0.98
DUCKCREEK	DUCKCREEK	0.54
EDWARDS	EDWARDS	0.25
ELMERSMITH	ELMERSMITH	0.25
FARMERCITY	FARMERCITY	0.16
G-007	G-007	1.4
GIBSON	GIBSON	0.1
HAMLET	HAMLET	0.26
NEWTON	NEWTON	0.65
O-066	O-066	8.96
PRAIRIE	PRAIRIE	1.22
RENSSELAER	RENSSELAER	0.31
SANTEETLA	SANTEETLA	0.07
SMITHLAND	SMITHLAND	0.1
TATANKA	TATANKA	0.3
TILTON	TILTON	0.3
TRIMBLE	TRIMBLE	0.26
TVA	TVA	0.82
UNIONPOWER	UNIONPOWER	0.36

Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8558092	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1180.0	107.06	107.59	DC	13.86

Bus #	Bus	MW Impact
213606	FAIRLESS	9.69
213878	PENNSBRY	0.92
213918	RICHMD91	2.82
213919	RICHMD92	2.82
219124	CAMDEN_STG	2.8
219126	CAMDEN_CTG	3.44
219128	GLOUCSTR_26	1.52
219229	EAGLEPT_G3	2.5
219230	EAGLEPT_G1	3.7
219241	CAMDEN1	0.21
219242	CAMDEN2	0.02
227801	ONTC&DCT	7.26
227843	MARINGEN E	0.75
227928	V4-067E	0.3
228261	V4-054E	1.35
228357	V2-046E	3.06
228712	V2-041E	0.49
228721	V2-035E	0.28
291996	U4-036 E	1.01
292063	V1-021 E	0.06
292088	V1-030 CB	0.1
292099	V1-030 E3	0.23
292105	V1-030 E6	0.3
292115	V1-030 EB	1.33
292194	V1-030 CE	0.09
292195	V1-030 EE	1.23
293404	V3-036	1.03
902092	W1-130E	1.35
902432	W2-030 E	1.17
902692	W2-056 E	1.64
902842	W2-071E	0.45
903152	W2-102 E	1.04
903991	W3-080C	1.96
903992	W3-080E	3.21
904042	V4-005 E	0.43
904432	W3-124 E	0.42
905792	W4-103 E	1.03
907382	X1-070 E	0.73
907392	X1-071 E	0.26
909032	X2-013 E	0.63
910862	X3-075 E	1.06
913242	Y1-057 E	0.32
913332	Y1-075 E	0.41
915022	Y3-012 E	1.41
915072	Y3-026 E	1.6

Bus #	Bus	MW Impact
915592	Y3-087 E OP1	0.8
916292	Z1-082 E	0.34
917381	Z2-062	0.13
924051	AB2-049 C	0.87
924052	AB2-049 E	1.41
924531	AB2-102 C	43.43
924532	AB2-102 E	0.97
924701	AB2-122 C	0.13
924702	AB2-122 E	0.22
925391	AC1-010 C	0.78
925392	AC1-010 E	1.34
925442	AC1-016 E	1.41
925452	AC1-017 E	0.67
925562	AC1-030 E	0.51
930002	AB1-001 E	0.27
930102	AB1-025 E	1.01
930242	AB1-063 E	0.14
930722	AB1-116 E	0.18
930732	AB1-119 E	0.17
931191	AB1-169A	119.56
932361	AC2-050 C O1	0.89
932362	AC2-050 E O1	1.46
933962	AD1-019 E	1.43
936211	AD2-027 C	1.4
936212	AD2-027 E	2.29
936321	AD2-042 C	1.85
936322	AD2-042 E	3.03
936411	AD2-052 C	1.54
936412	AD2-052 E	0.76
936491	AD2-064 C	0.12
936492	AD2-064 E	0.17
936501	AD2-065 C	0.5
936502	AD2-065 E	0.69
936541	AD2-069 C	0.52
936542	AD2-069 E	0.26
937011	AD2-135 C	0.13
937012	AD2-135 E	0.23
938311	AE1-046 C	0.43
938312	AE1-046 E	0.22
938421	AE1-061 C	0.58
938422	AE1-061 E	0.58
938431	AE1-062 C	1.2
938432	AE1-062 E	1.2
938611	AE1-083 C	0.51
938612	AE1-083 E	0.71
938781	AE1-104 C O1	26.58
938782	AE1-104 E O1	67.99
938871	AE1-115 C	1.26
938872	AE1-115 E	1.26
939301	AE1-161 C	2.41
939302	AE1-161 E	3.61
939501	AE1-179 C O1	7.33

Bus #	Bus	MW Impact
939502	AE1-179 E O1	5.17
939821	AE1-218 C O1	0.19
939822	AE1-218 E O1	0.28
939831	AE1-219 C O1	0.42
939832	AE1-219 E O1	0.61
939931	AE1-229 C O1	20.42
939932	AE1-229 E O1	13.83
940001	AE1-240 C O1	6.08
940002	AE1-240 E O1	4.34
940281	AE2-011 C	0.29
940282	AE2-011 E	0.41
940361	AE2-020 C O1	17.4
940362	AE2-020 E O1	81.45
940371	AE2-021 C O1	17.4
940372	AE2-021 E O1	81.45
940381	AE2-022 C O1	10.15
940382	AE2-022 E O1	47.51
940391	AE2-023 C O1	14.94
940392	AE2-023 E O1	69.95
940771	AE2-064 C	0.37
940772	AE2-064 E	0.5
940781	AE2-065 C	0.24
940782	AE2-065 E	0.37
940951	AE2-085 C	0.43
940952	AE2-085 E	0.41
940961	AE2-087 C	0.32
940962	AE2-087 E	0.44
940963	AE2-087 BAT	0.12
940971	AE2-088 C	0.17
940972	AE2-088 E	0.23
940973	AE2-088 BAT	0.1
941001	AE2-091 C O1	4.9
941002	AE2-091 E O1	2.56
941051	AE2-097 C	0.24
941052	AE2-097 E	0.38
941071	AE2-101 C	0.42
941072	AE2-101 E	0.58
941121	AE2-106 C	0.35
941122	AE2-106 E	0.49
941123	AE2-106 BAT	0.12
941441	AE2-141 C	0.27
941442	AE2-141 E	0.44
941471	AE2-144 C	0.49
941472	AE2-144 E	0.46
941931	AE2-205 C O1	9.03
941932	AE2-205 E O1	6.02
942011	AE2-213 C	0.37
942012	AE2-213 E	0.33
942101	AE2-222 C O1	16.06
942102	AE2-222 E O1	40.34
942571	AE2-272	0.33
942941	AE2-314 C	7.91

Bus #	Bus	MW Impact
942942	AE2-314 E	5.27
943071	AE2-334 C	6.7
943072	AE2-334 E	3.57
943081	AE2-335 C O1	9.59
943082	AE2-335 E O1	4.27
BLUEG	BLUEG	6.64
CALDERWOOD	CALDERWOOD	0.72
CANNELTON	CANNELTON	0.4
CATAWBA	CATAWBA	0.46
CBM-N	CBM-N	0.84
CHEOAH	CHEOAH	0.66
CHILHOWEE	CHILHOWEE	0.24
COFFEEN	COFFEEN	0.7
COTTONWOOD	COTTONWOOD	2.77
DUCKCREEK	DUCKCREEK	1.53
EDWARDS	EDWARDS	0.7
ELMERSMITH	ELMERSMITH	0.7
FARMERCITY	FARMERCITY	0.46
G-007A	G-007A	12.57
GIBSON	GIBSON	0.27
HAMLET	HAMLET	0.75
NEWTON	NEWTON	1.83
NYISO	NYISO	3.63
PRAIRIE	PRAIRIE	3.42
SANTEETLA	SANTEETLA	0.19
SMITHLAND	SMITHLAND	0.27
TATANKA	TATANKA	0.83
TILTON	TILTON	0.83
TRIMBLE	TRIMBLE	0.74
TVA	TVA	2.31
UNIONPOWER	UNIONPOWER	1.03
VFT	VFT	22.63

Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8558094	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	106.16	106.67	DC	14.79

Bus #	Bus	MW Impact
219124	CAMDEN_STG	3.13
219126	CAMDEN_CTG	3.85
219128	GLOUCSTR_26	1.7
219229	EAGLEPT_G3	2.79
219230	EAGLEPT_G1	4.12
219231	EAGLEPT_G2	4.12
219241	CAMDEN1	0.23
219242	CAMDEN2	0.03

Bus #	Bus	MW Impact
227801	ONTC&DCT	7.56
227843	MARINGEN E	0.78
227928	V4-067E	0.31
228261	V4-054E	1.44
228357	V2-046E	3.3
228423	Q-090 2	30.11
228712	V2-041E	0.52
228721	V2-035E	0.3
291995	U4-036 C	0.08
291996	U4-036 E	1.12
292063	V1-021 E	0.06
292088	V1-030 CB	0.11
292099	V1-030 E3	0.22
292104	V1-030 C6	0.02
292105	V1-030 E6	0.33
292115	V1-030 EB	1.49
292194	V1-030 CE	0.1
292195	V1-030 EE	1.37
293404	V3-036	1.08
902092	W1-130E	1.43
902432	W2-030 E	1.21
902692	W2-056 E	1.53
902842	W2-071E	0.44
903152	W2-102 E	0.98
903991	W3-080C	1.35
903992	W3-080E	2.2
904042	V4-005 E	0.4
904432	W3-124 E	0.4
905792	W4-103 E	0.97
907381	X1-070 C	0.05
907382	X1-070 E	0.77
907391	X1-071 C	0.01
907392	X1-071 E	0.26
909032	X2-013 E	0.7
910862	X3-075 E	1.18
913332	Y1-075 E	0.39
914231	Y2-081 C OP1	1.35
914232	Y2-081 E OP1	0.07
915022	Y3-012 E	1.47
915072	Y3-026 E	1.1
915591	Y3-087 C OP1	0.06
915592	Y3-087 E OP1	0.89
916292	Z1-082 E	0.38
917381	Z2-062	0.14
919901	AB1-000 1	1.04
919911	AB1-000 2	1.04
919921	AB1-000 3	1.04
924051	AB2-049 C	0.91
924052	AB2-049 E	1.48
924531	AB2-102 C	45.91
924532	AB2-102 E	1.02
924701	AB2-122 C	0.14

Bus #	Bus	MW Impact
924702	AB2-122 E	0.23
925391	AC1-010 C	0.87
925392	AC1-010 E	1.5
925442	AC1-016 E	0.97
925452	AC1-017 E	0.56
925561	AC1-030 C	0.04
925562	AC1-030 E	0.52
930002	AB1-001 E	0.28
930102	AB1-025 E	0.94
930242	AB1-063 E	0.15
930722	AB1-116 E	0.19
930732	AB1-119 E	0.17
931191	AB1-169A	126.85
932361	AC2-050 C O1	0.86
932362	AC2-050 E O1	1.41
933962	AD1-019 E	1.49
934661	AD1-097 1	1.67
934671	AD1-097 2	1.67
934681	AD1-097 3	1.67
934691	AD1-097 4	0.99
936211	AD2-027 C	1.57
936212	AD2-027 E	2.57
936321	AD2-042 C	2.07
936322	AD2-042 E	3.4
936411	AD2-052 C	1.66
936412	AD2-052 E	0.82
936491	AD2-064 C	0.12
936492	AD2-064 E	0.17
936501	AD2-065 C	0.51
936502	AD2-065 E	0.71
936541	AD2-069 C	0.51
936542	AD2-069 E	0.25
937011	AD2-135 C	0.14
937012	AD2-135 E	0.24
938311	AE1-046 C	0.46
938312	AE1-046 E	0.23
938421	AE1-061 C	0.61
938422	AE1-061 E	0.61
938431	AE1-062 C	1.23
938432	AE1-062 E	1.23
938611	AE1-083 C	0.35
938612	AE1-083 E	0.49
938781	AE1-104 C O1	27.85
938782	AE1-104 E O1	71.26
938871	AE1-115 C	1.36
938872	AE1-115 E	1.36
939301	AE1-161 C	2.57
939302	AE1-161 E	3.85
939501	AE1-179 C O1	7.79
939502	AE1-179 E O1	5.5
939821	AE1-218 C O1	0.2
939822	AE1-218 E O1	0.3

Bus #	Bus	MW Impact
939831	AE1-219 C O1	0.44
939832	AE1-219 E O1	0.64
939931	AE1-229 C O1	21.94
939932	AE1-229 E O1	14.86
940001	AE1-240 C O1	6.46
940002	AE1-240 E O1	4.61
940281	AE2-011 C	0.31
940282	AE2-011 E	0.42
940361	AE2-020 C O1	17.69
940362	AE2-020 E O1	82.8
940371	AE2-021 C O1	17.69
940372	AE2-021 E O1	82.8
940381	AE2-022 C O1	10.32
940382	AE2-022 E O1	48.3
940391	AE2-023 C O1	15.66
940392	AE2-023 E O1	73.3
940771	AE2-064 C	0.41
940772	AE2-064 E	0.56
940781	AE2-065 C	0.26
940782	AE2-065 E	0.41
940951	AE2-085 C	0.41
940952	AE2-085 E	0.39
940961	AE2-087 C	0.34
940962	AE2-087 E	0.47
940963	AE2-087 BAT	0.13
940971	AE2-088 C	0.18
940972	AE2-088 E	0.25
940973	AE2-088 BAT	0.1
941001	AE2-091 C O1	5.22
941002	AE2-091 E O1	2.72
941051	AE2-097 C	0.25
941052	AE2-097 E	0.41
941071	AE2-101 C	0.46
941072	AE2-101 E	0.63
941121	AE2-106 C	0.38
941122	AE2-106 E	0.52
941123	AE2-106 BAT	0.13
941441	AE2-141 C	0.26
941442	AE2-141 E	0.42
941471	AE2-144 C	0.55
941472	AE2-144 E	0.97
941931	AE2-205 C O1	9.55
941932	AE2-205 E O1	6.37
942011	AE2-213 C	0.41
942012	AE2-213 E	0.7
942101	AE2-222 C O1	16.74
942102	AE2-222 E O1	42.04
942571	AE2-272	0.36
942941	AE2-314 C	8.2
942942	AE2-314 E	5.47
943071	AE2-334 C	7.11
943072	AE2-334 E	3.79

Bus #	Bus	MW Impact
943081	AE2-335 C O1	10.23
943082	AE2-335 E O1	4.56
BLUEG	BLUEG	5.69
CALDERWOOD	CALDERWOOD	0.61
CANNELTON	CANNELTON	0.34
CATAWBA	CATAWBA	0.39
CBM-N	CBM-N	0.34
CHEOAH	CHEOAH	0.56
CHILHOWEE	CHILHOWEE	0.2
COFFEEN	COFFEEN	0.6
COTTONWOOD	COTTONWOOD	2.36
DUCKCREEK	DUCKCREEK	1.31
EDWARDS	EDWARDS	0.6
ELMERSMITH	ELMERSMITH	0.59
FARMERCITY	FARMERCITY	0.4
G-007A	G-007A	9.86
GIBSON	GIBSON	0.23
HAMLET	HAMLET	0.63
NEWTON	NEWTON	1.57
NYISO	NYISO	1.45
PRAIRIE	PRAIRIE	2.92
SANTEETLA	SANTEETLA	0.16
SMITHLAND	SMITHLAND	0.23
TATANKA	TATANKA	0.71
TILTON	TILTON	0.72
TRIMBLE	TRIMBLE	0.63
TVA	TVA	1.97
UNIONPOWER	UNIONPOWER	0.88
VFT	VFT	14.46

Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8558689	219100	NEWFRDM	PSE&G	219704	HILLTOP_3	PSE&G	1	PS_P7-1_V2274+P2242_LT	tower	740.0	123.86	124.88	DC	7.52

Bus #	Bus	MW Impact
227801	ONTC&DCT	4.03
227843	MARINGEN E	0.42
227928	V4-067E	0.17
228260	V4-054C	0.1
228261	V4-054E	0.67
228357	V2-046E	1.38
228702	WEST CT	0.35
228712	V2-041E	0.26
228717	S121	0.5
228720	V2-035C	0.01
228721	V2-035E	0.14
228727	W2-039G	0.83

Bus #	Bus	MW Impact
291996	U4-036 E	0.32
292063	V1-021 E	0.03
292105	V1-030 E6	0.09
293404	V3-036	0.57
902091	W1-130C	0.05
902092	W1-130E	0.73
902432	W2-030 E	0.65
909032	X2-013 E	0.2
915022	Y3-012 E	0.78
916292	Z1-082 E	0.26
924051	AB2-049 C	0.5
924052	AB2-049 E	0.81
924531	AB2-102 C	23.15
924532	AB2-102 E	0.51
924701	AB2-122 C	0.07
924702	AB2-122 E	0.13
930002	AB1-001 E	0.15
930722	AB1-116 E	0.1
930732	AB1-119 E	0.09
931191	AB1-169A	64.54
933962	AD1-019 E	0.79
936411	AD2-052 C	0.7
936412	AD2-052 E	0.35
936491	AD2-064 C	0.07
936492	AD2-064 E	0.09
936501	AD2-065 C	0.25
936502	AD2-065 E	0.35
937011	AD2-135 C	0.09
937012	AD2-135 E	0.15
938311	AE1-046 C	0.23
938312	AE1-046 E	0.12
938421	AE1-061 C	0.59
938422	AE1-061 E	0.59
938431	AE1-062 C	1.19
938432	AE1-062 E	1.19
938781	AE1-104 C O1	14.58
938782	AE1-104 E O1	37.31
938871	AE1-115 C	0.55
938872	AE1-115 E	0.55
939301	AE1-161 C	2.43
939302	AE1-161 E	3.65
939501	AE1-179 C O1	3.78
939502	AE1-179 E O1	2.67
939821	AE1-218 C O1	0.1
939822	AE1-218 E O1	0.16
939831	AE1-219 C O1	0.23
939832	AE1-219 E O1	0.34
939931	AE1-229 C O1	9.8
939932	AE1-229 E O1	6.64
940001	AE1-240 C O1	3.12
940002	AE1-240 E O1	2.23
940281	AE2-011 C	0.17

Bus #	Bus	MW Impact
940282	AE2-011 E	0.23
940361	AE2-020 C O1	8.83
940362	AE2-020 E O1	41.35
940371	AE2-021 C O1	8.83
940372	AE2-021 E O1	41.35
940381	AE2-022 C O1	5.15
940382	AE2-022 E O1	24.12
940391	AE2-023 C O1	8.2
940392	AE2-023 E O1	38.38
940781	AE2-065 C	0.07
940782	AE2-065 E	0.11
940961	AE2-087 C	0.16
940962	AE2-087 E	0.22
940963	AE2-087 BAT	0.06
940971	AE2-088 C	0.09
940972	AE2-088 E	0.13
940973	AE2-088 BAT	0.1
941001	AE2-091 C O1	2.48
941002	AE2-091 E O1	1.29
941071	AE2-101 C	0.17
941072	AE2-101 E	0.24
941121	AE2-106 C	0.17
941122	AE2-106 E	0.24
941123	AE2-106 BAT	0.06
941471	AE2-144 C	0.14
941472	AE2-144 E	0.13
941931	AE2-205 C O1	4.81
941932	AE2-205 E O1	3.21
942011	AE2-213 C	0.12
942012	AE2-213 E	0.1
942101	AE2-222 C O1	8.91
942102	AE2-222 E O1	22.39
942571	AE2-272	0.15
942941	AE2-314 C	4.52
942942	AE2-314 E	3.02
943071	AE2-334 C	3.65
943072	AE2-334 E	1.95
943081	AE2-335 C O1	5.2
943082	AE2-335 E O1	2.32
BLUEG	BLUEG	0.66
CALDERWOOD	CALDERWOOD	0.06
CANNELTON	CANNELTON	0.04
CARR	CARR	0.28
CATAWBA	CATAWBA	0.03
CHEOAH	CHEOAH	0.06
CHILHOWEE	CHILHOWEE	0.02
COFFEEN	COFFEEN	0.07
COTTONWOOD	COTTONWOOD	0.25
DUCKCREEK	DUCKCREEK	0.15
EDWARDS	EDWARDS	0.07
ELMERSMITH	ELMERSMITH	0.07
FARMERCITY	FARMERCITY	0.04

Bus #	Bus	MW Impact
G-007	G-007	0.19
GIBSON	GIBSON	0.03
HAMLET	HAMLET	0.05
NEWTON	NEWTON	0.18
O-066	O-066	6.1
PRAIRIE	PRAIRIE	0.33
RENSSELAER	RENSSELAER	0.22
SANTEETLA	SANTEETLA	0.02
SMITHLAND	SMITHLAND	0.03
TATANKA	TATANKA	0.08
TILTON	TILTON	0.08
TRIMBLE	TRIMBLE	0.07
TVA	TVA	0.2
UNIONPOWER	UNIONPOWER	0.09

Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8558093	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	106.18	106.68	DC	14.79

Bus #	Bus	MW Impact
219124	CAMDEN_STG	3.13
219126	CAMDEN_CTG	3.85
219128	GLOUCSTR_26	1.7
219229	EAGLEPT_G3	2.79
219230	EAGLEPT_G1	4.12
219231	EAGLEPT_G2	4.12
219241	CAMDEN1	0.23
219242	CAMDEN2	0.03
227801	ONTC&DCT	7.56
227843	MARINGEN E	0.78
227928	V4-067E	0.31
228261	V4-054E	1.44
228357	V2-046E	3.3
228423	Q-090 2	30.11
228712	V2-041E	0.52
228721	V2-035E	0.3
291995	U4-036 C	0.08
291996	U4-036 E	1.12
292063	V1-021 E	0.06
292088	V1-030 CB	0.11
292099	V1-030 E3	0.22
292104	V1-030 C6	0.02
292105	V1-030 E6	0.33
292115	V1-030 EB	1.49
292194	V1-030 CE	0.1
292195	V1-030 EE	1.37

Bus #	Bus	MW Impact
293404	V3-036	1.08
902092	W1-130E	1.43
902432	W2-030 E	1.21
902692	W2-056 E	1.53
902842	W2-071E	0.44
903152	W2-102 E	0.98
903991	W3-080C	1.35
903992	W3-080E	2.2
904042	V4-005 E	0.4
904432	W3-124 E	0.4
905792	W4-103 E	0.97
907381	X1-070 C	0.05
907382	X1-070 E	0.77
907391	X1-071 C	0.01
907392	X1-071 E	0.26
909032	X2-013 E	0.7
910862	X3-075 E	1.18
913332	Y1-075 E	0.39
914231	Y2-081 C OP1	1.35
914232	Y2-081 E OP1	0.07
915022	Y3-012 E	1.47
915072	Y3-026 E	1.1
915591	Y3-087 C OP1	0.06
915592	Y3-087 E OP1	0.89
916292	Z1-082 E	0.38
917381	Z2-062	0.14
919901	AB1-000 1	1.04
919911	AB1-000 2	1.04
919921	AB1-000 3	1.04
924051	AB2-049 C	0.91
924052	AB2-049 E	1.48
924531	AB2-102 C	45.91
924532	AB2-102 E	1.02
924701	AB2-122 C	0.14
924702	AB2-122 E	0.23
925391	AC1-010 C	0.87
925392	AC1-010 E	1.5
925442	AC1-016 E	0.97
925452	AC1-017 E	0.56
925561	AC1-030 C	0.04
925562	AC1-030 E	0.52
930002	AB1-001 E	0.28
930102	AB1-025 E	0.94
930242	AB1-063 E	0.15
930722	AB1-116 E	0.19
930732	AB1-119 E	0.17
931191	AB1-169A	126.85
932361	AC2-050 C O1	0.86
932362	AC2-050 E O1	1.41
933962	AD1-019 E	1.49
934661	AD1-097 1	1.67
934671	AD1-097 2	1.67

Bus #	Bus	MW Impact
934681	AD1-097 3	1.67
934691	AD1-097 4	0.99
936211	AD2-027 C	1.57
936212	AD2-027 E	2.57
936321	AD2-042 C	2.07
936322	AD2-042 E	3.4
936411	AD2-052 C	1.66
936412	AD2-052 E	0.82
936491	AD2-064 C	0.12
936492	AD2-064 E	0.17
936501	AD2-065 C	0.51
936502	AD2-065 E	0.71
936541	AD2-069 C	0.51
936542	AD2-069 E	0.25
937011	AD2-135 C	0.14
937012	AD2-135 E	0.24
938311	AE1-046 C	0.46
938312	AE1-046 E	0.23
938421	AE1-061 C	0.61
938422	AE1-061 E	0.61
938431	AE1-062 C	1.23
938432	AE1-062 E	1.23
938611	AE1-083 C	0.35
938612	AE1-083 E	0.49
938781	AE1-104 C O1	27.85
938782	AE1-104 E O1	71.26
938871	AE1-115 C	1.36
938872	AE1-115 E	1.36
939301	AE1-161 C	2.57
939302	AE1-161 E	3.85
939501	AE1-179 C O1	7.79
939502	AE1-179 E O1	5.5
939821	AE1-218 C O1	0.2
939822	AE1-218 E O1	0.3
939831	AE1-219 C O1	0.44
939832	AE1-219 E O1	0.64
939931	AE1-229 C O1	21.94
939932	AE1-229 E O1	14.86
940001	AE1-240 C O1	6.46
940002	AE1-240 E O1	4.61
940281	AE2-011 C	0.31
940282	AE2-011 E	0.42
940361	AE2-020 C O1	17.69
940362	AE2-020 E O1	82.8
940371	AE2-021 C O1	17.69
940372	AE2-021 E O1	82.8
940381	AE2-022 C O1	10.32
940382	AE2-022 E O1	48.3
940391	AE2-023 C O1	15.66
940392	AE2-023 E O1	73.3
940771	AE2-064 C	0.41
940772	AE2-064 E	0.56

Bus #	Bus	MW Impact
940781	AE2-065 C	0.26
940782	AE2-065 E	0.41
940951	AE2-085 C	0.41
940952	AE2-085 E	0.39
940961	AE2-087 C	0.34
940962	AE2-087 E	0.47
940963	AE2-087 BAT	0.13
940971	AE2-088 C	0.18
940972	AE2-088 E	0.25
940973	AE2-088 BAT	0.1
941001	AE2-091 C O1	5.22
941002	AE2-091 E O1	2.72
941051	AE2-097 C	0.25
941052	AE2-097 E	0.41
941071	AE2-101 C	0.46
941072	AE2-101 E	0.63
941121	AE2-106 C	0.38
941122	AE2-106 E	0.52
941123	AE2-106 BAT	0.13
941441	AE2-141 C	0.26
941442	AE2-141 E	0.42
941471	AE2-144 C	0.55
941472	AE2-144 E	0.97
941931	AE2-205 C O1	9.55
941932	AE2-205 E O1	6.37
942011	AE2-213 C	0.41
942012	AE2-213 E	0.7
942101	AE2-222 C O1	16.74
942102	AE2-222 E O1	42.04
942571	AE2-272	0.36
942941	AE2-314 C	8.2
942942	AE2-314 E	5.47
943071	AE2-334 C	7.11
943072	AE2-334 E	3.79
943081	AE2-335 C O1	10.23
943082	AE2-335 E O1	4.56
BLUEG	BLUEG	5.69
CALDERWOOD	CALDERWOOD	0.61
CANNELTON	CANNELTON	0.34
CATAWBA	CATAWBA	0.39
CBM-N	CBM-N	0.34
CHEOAH	CHEOAH	0.56
CHILHOWEE	CHILHOWEE	0.2
COFFEEN	COFFEEN	0.6
COTTONWOOD	COTTONWOOD	2.36
DUCKCREEK	DUCKCREEK	1.31
EDWARDS	EDWARDS	0.6
ELMERSMITH	ELMERSMITH	0.59
FARMERCITY	FARMERCITY	0.4
G-007A	G-007A	9.86
GIBSON	GIBSON	0.23
HAMLET	HAMLET	0.63

Bus #	Bus	MW Impact
NEWTON	NEWTON	1.57
NYISO	NYISO	1.45
PRAIRIE	PRAIRIE	2.92
SANTEETLA	SANTEETLA	0.16
SMITHLAND	SMITHLAND	0.23
TATANKA	TATANKA	0.71
TILTON	TILTON	0.72
TRIMBLE	TRIMBLE	0.63
TVA	TVA	1.97
UNIONPOWER	UNIONPOWER	0.88
VFT	VFT	14.46

Contingency Name	Contingency Definition
AE_P1-3 MON 4 XFR	CONTINGENCY 'AE_P1-3 MON 4 XFR' OPEN LINE FROM BUS 228402 TO BUS 228404 CIRCUIT 2 / END
PS_P7-1_V2274+P2242_LT	CONTINGENCY 'PS_P7-1_V2274+P2242_LT' /* EAGLE POINT - GLOUCESTER & DEPTFORD - GLOUCESTER DISCONNECT BUS 219757 /* DEPTFORD SECTION 2 DISCONNECT BUS 219760 /* EAGLE POINT SECTION 4 TRIP LINE FROM BUS 219110 TO BUS 219128 CKT 1 /* DISCONNECT TRANSFORMER 26KV CKT 1 CLOSE LINE FROM BUS 219255 TO BUS 219256 CKT Z /* DEPTFORD CLOSE LINE FROM BUS 219180 TO BUS 219181 CKT Z /* DEPTFORD MOVE 8 MW LOAD FROM BUS 219180 TO BUS 219162 /* INTERSTATION TIE TRANSFER LOAD FROM DEPTFORD TO BEAVERBK T1 MOVE 8 MW LOAD FROM BUS 219181 TO BUS 219163 /* INTERSTATION TIE TRANSFER LOAD FROM DEPTFORD TO BEAVERBK T2 MOVE 8 MW LOAD FROM BUS 219255 TO BUS 219162 /* INTERSTATION TIE TRANSFER LOAD FROM DEPTFORD TO BEAVERBK T1 MOVE 8 MW LOAD FROM BUS 219256 TO BUS 219163 /* INTERSTATION TIE TRANSFER LOAD FROM DEPTFORD TO BEAVERBK T2 END
PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B PECO_P2-2_CHI230B1 \$ B	CONTINGENCY 'PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B' DISCONNECT BUS 213489 /* CHICHST1 230.00 \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B END
PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK PECO_P4_CHICH045 \$ STBK	CONTINGENCY 'PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK' DISCONNECT BUS 213489 /* CHICHST1 230.00 \$ DELCO \$ PECO_P4_CHICH045 \$ STBK DISCONNECT BUS 213627 /* FOULK8 230.00 \$ DELCO \$ PECO_P4_CHICH045 \$ STBK END

Contingency Name	Contingency Definition
AE_P7-1 W2275_O2241	CONTINGENCY 'AE_P7-1 W2275_O2241' /* DOUBLE CIRCUIT TOWER W-2275(MICKLETON - DEPTFORD) AND O-2241(MICKLETON - THOROFARE) TRIP BRANCH FROM BUS 219762 TO BUS 228401 CKT 1 /* TRIP O-2241(MICKLETON - THOROFARE) 230KV TRIP BRANCH FROM BUS 219121 TO BUS 228401 CKT 1 /* TRIP (MICKLETON - THOROFARE #2) 230KV END

Secondary POI Flow Gate Details

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1834621	228404	MONROE	AE	228402	MONROE	AE	2	AE_P1-3 MON 3 XFR	single	274.0	93.74	102.34	DC	23.57

Bus #	Bus	MW Impact
227801	ONTC&DCT	3.23
227842	MARINGEN	0.04
227927	V4-067C	0.01
228014	PVILLEG	0.04
228720	V2-035C	0.03
292062	V1-021 C	0.02
902091	W1-130C	0.18
902431	W2-030 C	0.04
913341	Y1-077	4.08
924701	AB2-122 C	0.05
930001	AB1-001 C	0.01
931191	AB1-169A	214.46
938311	AE1-046 C	0.78
938421	AE1-061 C	1.97
938781	AE1-104 C O1	10.46
939301	AE1-161 C	9.86
939931	AE1-229 C O1	21.62
940361	AE2-020 C O2	5.64
940371	AE2-021 C O2	5.64
940381	AE2-022 C O2	3.29
940391	AE2-023 C O2	7.34
940971	AE2-088 C	0.43
940973	AE2-088 BAT	0.45
942101	AE2-222 C O2	7.14
942201	AE2-232 C O2	5.95
942381	AE2-251 C O2	17.86
942941	AE2-314 C	2.29
943081	AE2-335 C O2	23.57
BLUEG	BLUEG	0.22
CALDERWOOD	CALDERWOOD	0.02

Bus #	Bus	MW Impact
CANNELTON	CANNELTON	0.01
CARR	CARR	0.0
CATAWBA	CATAWBA	0.02
CHEOAH	CHEOAH	0.02
CHILHOWEE	CHILHOWEE	0.01
COFFEEN	COFFEEN	0.02
COTTONWOOD	COTTONWOOD	0.09
DUCKCREEK	DUCKCREEK	0.05
EDWARDS	EDWARDS	0.02
ELMERSMITH	ELMERSMITH	0.02
FARMERCITY	FARMERCITY	0.02
G-007A	G-007A	0.52
GIBSON	GIBSON	0.01
HAMLET	HAMLET	0.03
NEWTON	NEWTON	0.06
PRAIRIE	PRAIRIE	0.11
SANTEETLA	SANTEETLA	0.01
SMITHLAND	SMITHLAND	0.01
TATANKA	TATANKA	0.03
TILTON	TILTON	0.03
TRIMBLE	TRIMBLE	0.02
TVA	TVA	0.08
UNIONPOWER	UNIONPOWER	0.03
VFT	VFT	0.15

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
430568	200051	ROCKSPGS	PJM	200065	PCHBTM2S	PJM	1	JC-P2-3-JCC-500-002D	breaker	2905.0	99.81	100.12	DC	19.47

Bus #	Bus	MW Impact
200052	ROCKSP 1	9.91
200053	ROCKSP 2	9.91
200054	ROCKSP 3	10.0
200055	ROCKSP 4	10.0
228261	V4-054E	2.09
228357	V2-046E	4.18
228712	V2-041E	0.86
228721	V2-035E	0.41
231708	CHRIST3	4.51
231911	HR5	7.89
231912	HR6	7.89
231913	HR7	7.89
231914	HR8	11.99
232922	MR3	51.57
292063	V1-021 E	0.1
901004	W1-003 E	2.27
901014	W1-004 E	2.27
901024	W1-005 E	2.27
901034	W1-006 E	2.27

Bus #	Bus	MW Impact
902092	W1-130E	2.01
902432	W2-030 E	2.0
907052	X1-032 E	2.0
910572	X3-008 E	6.17
910822	X3-066 E	1.79
913271	Y1-065 C	92.46
913362	Y1-079 E	3.02
913412	Y1-080 E	1.05
915542	Y3-058 E	4.65
917082	Z2-012 E	6.21
917432	Z2-076 E	1.01
917442	Z2-077 E	1.01
919831	AA2-069	228.01
923921	AB2-032 C	6.49
923922	AB2-032 E	3.05
923951	AB2-036 C	17.02
923952	AB2-036 E	27.84
923961	AB2-037 C	38.3
923962	AB2-037 E	62.56
924051	AB2-049 C	1.25
924052	AB2-049 E	2.04
924191	AB2-063 C	3.65
924192	AB2-063 E	5.96
924531	AB2-102 C	79.87
924532	AB2-102 E	1.77
924681	AB2-120 C	19.03
924682	AB2-120 E	31.05
924781	AB2-130 C O1	16.16
924782	AB2-130 E O1	26.37
924801	AB2-133 C O1	11.7
924802	AB2-133 E O1	14.84
924821	AB2-135 C	14.37
924822	AB2-135 E	16.39
924831	AB2-136 C	12.35
924832	AB2-136 E	13.1
924971	AB2-153 C	3.63
924972	AB2-153 E	5.92
925111	AB2-168 C	1.57
925112	AB2-168 E	2.15
925151	AB2-172 C	9.45
925152	AB2-172 E	15.42
925251	AB2-179 C	16.99
925252	AB2-179 E	5.6
925261	AB2-180 C	7.0
925262	AB2-180 E	3.0
925271	AB2-185 C	6.81
925272	AB2-185 E	2.92
926131	AC1-091 C	3.79
926132	AC1-091 E	6.21
926141	AC1-092 C	3.79
926142	AC1-092 E	6.21
926151	AC1-093 C	3.59

Bus #	Bus	MW Impact
926152	AC1-093 E	5.91
926161	AC1-094 C	3.03
926162	AC1-094 E	5.0
926171	AC1-095 C	1.92
926172	AC1-095 E	3.08
926911	AC1-177	2.0
927031	AC1-190 C	17.42
927032	AC1-190 E	7.46
927191	AC1-213 C	1.6
927192	AC1-213 E	1.05
930202	AB1-056 E O1	92.01
930722	AB1-116 E	0.25
930732	AB1-119 E	0.24
930881	AB1-137 C	2.11
930882	AB1-137 E	0.9
930921	AB1-141 C	6.44
930922	AB1-141 E	3.01
930931	AB1-142 C	6.44
930932	AB1-142 E	3.01
931111	AB1-162 C	3.05
931112	AB1-162 E	4.98
931191	AB1-169A	178.35
931261	AB1-176 C	1.64
931262	AB1-176 E	2.69
932081	AC2-018 C1	0.39
932082	AC2-018 E1	20.99
932091	AC2-018 C2	0.39
932092	AC2-018 E2	20.99
932161	AC2-023 C	13.25
932162	AC2-023 E	9.65
933631	AC2-185 C	7.68
933632	AC2-185 E	12.53
933641	AC2-186 C	9.49
933642	AC2-186 E	15.49
936411	AD2-052 C	2.21
936412	AD2-052 E	1.09
936451	AD2-059 C	0.11
936452	AD2-059 E	0.33
936491	AD2-064 C	0.17
936492	AD2-064 E	0.24
936501	AD2-065 C	0.71
936502	AD2-065 E	0.98
936611	AD2-076 C O1	8.93
936612	AD2-076 E O1	14.56
936691	AD2-088 C O1	9.01
936692	AD2-088 E O1	6.01
937011	AD2-135 C	0.2
937012	AD2-135 E	0.34
937281	AD2-167	41.98
938251	AE1-038 C O1	4.25
938252	AE1-038 E O1	5.86
938311	AE1-046 C	0.65

Bus #	Bus	MW Impact
938312	AE1-046 E	0.32
938421	AE1-061 C	0.86
938422	AE1-061 E	0.86
938431	AE1-062 C	1.72
938432	AE1-062 E	1.72
938651	AE1-087 C	4.22
938652	AE1-087 E	1.05
938781	AE1-104 C O1	46.38
938782	AE1-104 E O1	118.65
938811	AE1-107 C	14.01
938812	AE1-107 E	9.99
938871	AE1-115 C	1.73
938872	AE1-115 E	1.73
938891	AE1-117 C O1	24.07
938892	AE1-117 E O1	64.19
938901	AE1-118 C O1	24.07
938902	AE1-118 E O1	64.19
939151	AE1-145 C1	6.01
939152	AE1-145 C2	4.01
939153	AE1-145 E	0.1
939301	AE1-161 C	3.44
939302	AE1-161 E	5.17
939361	AE1-167 C O1	3.0
939362	AE1-167 E O1	2.5
939501	AE1-179 C O1	11.95
939502	AE1-179 E O1	8.43
939621	AE1-192 C O1	23.53
939622	AE1-192 E O1	11.52
939821	AE1-218 C O1	0.26
939822	AE1-218 E O1	0.39
939831	AE1-219 C O1	0.59
939832	AE1-219 E O1	0.85
939931	AE1-229 C O1	29.31
939932	AE1-229 E O1	19.86
940001	AE1-240 C O1	9.9
940002	AE1-240 E O1	7.07
940281	AE2-011 C	0.43
940282	AE2-011 E	0.59
940391	AE2-023 C O2	25.26
940392	AE2-023 E O2	118.25
940741	AE2-061	5.65
940961	AE2-087 C	0.5
940962	AE2-087 E	0.68
940963	AE2-087 BAT	0.19
940971	AE2-088 C	0.24
940972	AE2-088 E	0.33
940973	AE2-088 BAT	0.13
941001	AE2-091 C O2	7.79
941002	AE2-091 E O2	4.07
941021	AE2-093 C	9.73
941022	AE2-093 E	15.46
941121	AE2-106 C	0.55

Bus #	Bus	MW Impact
941122	AE2-106 E	0.76
941123	AE2-106 BAT	0.19
941181	AE2-112 C	3.64
941182	AE2-112 E	5.94
941931	AE2-205 C O2	16.35
941932	AE2-205 E O2	10.9
941971	AE2-209 C	16.45
941972	AE2-209 E	11.47
942261	AE2-238 C	1.61
942262	AE2-238 E	2.23
942441	AE2-257 C O2	16.55
942442	AE2-257 E O2	43.63
942571	AE2-272	0.45
942701	AE2-286 C	3.97
942702	AE2-286 E	5.76
942821	AE2-301 C	2.0
942822	AE2-301 E	3.05
943071	AE2-334 C	9.36
943072	AE2-334 E	4.99
943081	AE2-335 C O2	13.47
943082	AE2-335 E O2	6.0
BLUEG	BLUEG	28.52
CALDERWOOD	CALDERWOOD	3.2
CANNELTON	CANNELTON	1.74
CATAWBA	CATAWBA	2.1
CBM-N	CBM-N	3.04
CHEOAH	CHEOAH	2.93
CHILHOWEE	CHILHOWEE	1.05
COFFEEN	COFFEEN	3.01
COTTONWOOD	COTTONWOOD	12.18
DUCKCREEK	DUCKCREEK	6.54
EDWARDS	EDWARDS	2.98
ELMERSMITH	ELMERSMITH	3.0
FARMERCITY	FARMERCITY	2.0
G-007A	G-007A	25.54
GIBSON	GIBSON	1.18
HAMLET	HAMLET	3.48
NEWTON	NEWTON	7.88
NYISO	NYISO	13.13
PRAIRIE	PRAIRIE	14.79
SANTEETLA	SANTEETLA	0.86
SMITHLAND	SMITHLAND	1.19
TATANKA	TATANKA	3.59
TILTON	TILTON	3.58
TRIMBLE	TRIMBLE	3.17
TVA	TVA	10.17
UNIONPOWER	UNIONPOWER	4.55
VFT	VFT	52.17

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1621844	213922	RICHMOND	PECO	214012	WANEETA3	PECO	1	PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B	bus	1180.0	119.47	120.0	DC	13.83

Bus #	Bus	MW Impact
213606	FAIRLESS	9.69
213878	PENNSBRY	0.92
213918	RICHMD91	2.82
213919	RICHMD92	2.82
219124	CAMDEN_STG	2.8
219126	CAMDEN_CTG	3.44
219128	GLOUCSTR_26	1.52
219229	EAGLEPT_G3	2.5
219230	EAGLEPT_G1	3.7
219241	CAMDEN1	0.21
219242	CAMDEN2	0.02
227801	ONTC&DCT	7.26
227843	MARINGEN E	0.75
227928	V4-067E	0.3
228261	V4-054E	1.35
228357	V2-046E	3.06
228712	V2-041E	0.49
228721	V2-035E	0.28
291996	U4-036 E	1.01
292063	V1-021 E	0.06
292088	V1-030 CB	0.1
292099	V1-030 E3	0.23
292105	V1-030 E6	0.3
292115	V1-030 EB	1.33
292194	V1-030 CE	0.09
292195	V1-030 EE	1.23
293404	V3-036	1.03
902092	W1-130E	1.35
902432	W2-030 E	1.17
902692	W2-056 E	1.64
902842	W2-071E	0.45
903152	W2-102 E	1.04
903991	W3-080C	1.96
903992	W3-080E	3.21
904042	V4-005 E	0.43
904432	W3-124 E	0.42
905792	W4-103 E	1.03
907382	X1-070 E	0.73
907392	X1-071 E	0.26
909032	X2-013 E	0.63
910862	X3-075 E	1.06
913242	Y1-057 E	0.32
913332	Y1-075 E	0.41

Bus #	Bus	MW Impact
915022	Y3-012 E	1.41
915072	Y3-026 E	1.6
915592	Y3-087 E OP1	0.8
916292	Z1-082 E	0.34
917381	Z2-062	0.13
924051	AB2-049 C	0.87
924052	AB2-049 E	1.41
924531	AB2-102 C	43.43
924532	AB2-102 E	0.97
924701	AB2-122 C	0.13
924702	AB2-122 E	0.22
925391	AC1-010 C	0.78
925392	AC1-010 E	1.34
925442	AC1-016 E	1.41
925452	AC1-017 E	0.67
925562	AC1-030 E	0.51
930002	AB1-001 E	0.27
930102	AB1-025 E	1.01
930242	AB1-063 E	0.14
930722	AB1-116 E	0.18
930732	AB1-119 E	0.17
931191	AB1-169A	119.56
932361	AC2-050 C O1	0.89
932362	AC2-050 E O1	1.46
933962	AD1-019 E	1.43
936211	AD2-027 C	1.4
936212	AD2-027 E	2.29
936321	AD2-042 C	1.85
936322	AD2-042 E	3.03
936411	AD2-052 C	1.54
936412	AD2-052 E	0.76
936491	AD2-064 C	0.12
936492	AD2-064 E	0.17
936501	AD2-065 C	0.5
936502	AD2-065 E	0.69
936541	AD2-069 C	0.52
936542	AD2-069 E	0.26
937011	AD2-135 C	0.13
937012	AD2-135 E	0.23
938311	AE1-046 C	0.43
938312	AE1-046 E	0.22
938421	AE1-061 C	0.58
938422	AE1-061 E	0.58
938431	AE1-062 C	1.2
938432	AE1-062 E	1.2
938611	AE1-083 C	0.51
938612	AE1-083 E	0.71
938781	AE1-104 C O1	26.58
938782	AE1-104 E O1	67.99
938871	AE1-115 C	1.26
938872	AE1-115 E	1.26
939301	AE1-161 C	2.41

Bus #	Bus	MW Impact
939302	AE1-161 E	3.61
939501	AE1-179 C O1	7.33
939502	AE1-179 E O1	5.17
939821	AE1-218 C O1	0.19
939822	AE1-218 E O1	0.28
939831	AE1-219 C O1	0.42
939832	AE1-219 E O1	0.61
939931	AE1-229 C O1	20.42
939932	AE1-229 E O1	13.83
940001	AE1-240 C O1	6.08
940002	AE1-240 E O1	4.34
940281	AE2-011 C	0.29
940282	AE2-011 E	0.41
940361	AE2-020 C O2	19.49
940362	AE2-020 E O2	91.26
940371	AE2-021 C O2	19.49
940372	AE2-021 E O2	91.26
940381	AE2-022 C O2	11.37
940382	AE2-022 E O2	53.23
940391	AE2-023 C O2	14.81
940392	AE2-023 E O2	69.34
940771	AE2-064 C	0.37
940772	AE2-064 E	0.5
940781	AE2-065 C	0.24
940782	AE2-065 E	0.37
940951	AE2-085 C	0.43
940952	AE2-085 E	0.41
940961	AE2-087 C	0.32
940962	AE2-087 E	0.44
940963	AE2-087 BAT	0.12
940971	AE2-088 C	0.17
940972	AE2-088 E	0.23
940973	AE2-088 BAT	0.1
941001	AE2-091 C O2	4.91
941002	AE2-091 E O2	2.56
941051	AE2-097 C	0.24
941052	AE2-097 E	0.38
941071	AE2-101 C	0.42
941072	AE2-101 E	0.58
941121	AE2-106 C	0.35
941122	AE2-106 E	0.49
941123	AE2-106 BAT	0.12
941441	AE2-141 C	0.27
941442	AE2-141 E	0.44
941471	AE2-144 C	0.49
941472	AE2-144 E	0.46
941931	AE2-205 C O2	9.18
941932	AE2-205 E O2	6.12
942011	AE2-213 C	0.37
942012	AE2-213 E	0.33
942101	AE2-222 C O2	16.06
942102	AE2-222 E O2	40.34

Bus #	Bus	MW Impact
942201	AE2-232 C O2	20.58
942202	AE2-232 E O2	52.67
942381	AE2-251 C O2	61.75
942382	AE2-251 E O2	158.0
942571	AE2-272	0.33
942941	AE2-314 C	7.91
942942	AE2-314 E	5.27
943071	AE2-334 C	6.7
943072	AE2-334 E	3.57
943081	AE2-335 C O2	9.56
943082	AE2-335 E O2	4.26
BLUEG	BLUEG	6.64
CALDERWOOD	CALDERWOOD	0.72
CANNELTON	CANNELTON	0.4
CATAWBA	CATAWBA	0.46
CBM-N	CBM-N	0.84
CHEOAH	CHEOAH	0.66
CHILHOWEE	CHILHOWEE	0.24
COFFEEN	COFFEEN	0.7
COTTONWOOD	COTTONWOOD	2.77
DUCKCREEK	DUCKCREEK	1.53
EDWARDS	EDWARDS	0.7
ELMERSMITH	ELMERSMITH	0.7
FARMERCITY	FARMERCITY	0.46
G-007A	G-007A	12.57
GIBSON	GIBSON	0.27
HAMLET	HAMLET	0.75
NEWTON	NEWTON	1.83
NYISO	NYISO	3.63
PRAIRIE	PRAIRIE	3.42
SANTEETLA	SANTEETLA	0.19
SMITHLAND	SMITHLAND	0.27
TATANKA	TATANKA	0.83
TILTON	TILTON	0.83
TRIMBLE	TRIMBLE	0.74
TVA	TVA	2.31
UNIONPOWER	UNIONPOWER	1.03
VFT	VFT	22.63

ID	FROM BUS#	FROM BUS AREA	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1715150	214010	WANEETA2	PECO	213817	N PHILA	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	621.0	107.6	108.11	DC	7.03

Bus #	Bus	MW Impact
213606	FAIRLESS	6.63
213878	PENNSBRY	0.63
213918	RICHMD91	1.37
213919	RICHMD92	1.37
219124	CAMDEN_STG	1.4

Bus #	Bus	MW Impact
219126	CAMDEN_CTG	1.72
219128	GLOUCSTR_26	0.76
219229	EAGLEPT_G3	1.25
219230	EAGLEPT_G1	1.85
219241	CAMDEN1	0.1
219242	CAMDEN2	0.01
227801	ONTC&DCT	3.75
227843	MARINGEN E	0.39
227928	V4-067E	0.16
228261	V4-054E	0.69
228357	V2-046E	1.55
228712	V2-041E	0.25
228721	V2-035E	0.14
291996	U4-036 E	0.51
292063	V1-021 E	0.03
292088	V1-030 CB	0.05
292099	V1-030 E3	0.12
292105	V1-030 E6	0.15
292115	V1-030 EB	0.66
292194	V1-030 CE	0.05
292195	V1-030 EE	0.61
293404	V3-036	0.53
902092	W1-130E	0.69
902432	W2-030 E	0.6
902692	W2-056 E	0.86
902842	W2-071E	0.23
903152	W2-102 E	0.55
903991	W3-080C	1.09
903992	W3-080E	1.78
904042	V4-005 E	0.23
904432	W3-124 E	0.22
905792	W4-103 E	0.54
907382	X1-070 E	0.37
907391	X1-071 C	0.01
907392	X1-071 E	0.13
909032	X2-013 E	0.32
910862	X3-075 E	0.53
913332	Y1-075 E	0.22
915022	Y3-012 E	0.73
915072	Y3-026 E	0.89
915592	Y3-087 E OP1	0.4
916292	Z1-082 E	0.17
917381	Z2-062	0.06
924051	AB2-049 C	0.44
924052	AB2-049 E	0.72
924531	AB2-102 C	22.23
924532	AB2-102 E	0.49
924701	AB2-122 C	0.07
924702	AB2-122 E	0.12
925391	AC1-010 C	0.39
925392	AC1-010 E	0.67
925442	AC1-016 E	0.78

Bus #	Bus	MW Impact
925452	AC1-017 E	0.36
925561	AC1-030 C	0.02
925562	AC1-030 E	0.26
930002	AB1-001 E	0.14
930102	AB1-025 E	0.53
930242	AB1-063 E	0.07
930722	AB1-116 E	0.09
930732	AB1-119 E	0.08
931191	AB1-169A	61.04
932361	AC2-050 C O1	0.47
932362	AC2-050 E O1	0.76
933962	AD1-019 E	0.74
936211	AD2-027 C	0.7
936212	AD2-027 E	1.14
936321	AD2-042 C	0.92
936322	AD2-042 E	1.51
936411	AD2-052 C	0.78
936412	AD2-052 E	0.38
936491	AD2-064 C	0.06
936492	AD2-064 E	0.08
936501	AD2-065 C	0.26
936502	AD2-065 E	0.35
936541	AD2-069 C	0.27
936542	AD2-069 E	0.13
937011	AD2-135 C	0.07
937012	AD2-135 E	0.12
938311	AE1-046 C	0.22
938312	AE1-046 E	0.11
938421	AE1-061 C	0.29
938422	AE1-061 E	0.29
938431	AE1-062 C	0.62
938432	AE1-062 E	0.62
938611	AE1-083 C	0.29
938612	AE1-083 E	0.4
938781	AE1-104 C O1	13.68
938782	AE1-104 E O1	35.0
938871	AE1-115 C	0.64
938872	AE1-115 E	0.64
939301	AE1-161 C	1.23
939302	AE1-161 E	1.84
939501	AE1-179 C O1	3.74
939502	AE1-179 E O1	2.64
939821	AE1-218 C O1	0.1
939822	AE1-218 E O1	0.14
939831	AE1-219 C O1	0.21
939832	AE1-219 E O1	0.31
939931	AE1-229 C O1	10.36
939932	AE1-229 E O1	7.02
940001	AE1-240 C O1	3.1
940002	AE1-240 E O1	2.21
940281	AE2-011 C	0.15
940282	AE2-011 E	0.21

Bus #	Bus	MW Impact
940361	AE2-020 C O2	10.1
940362	AE2-020 E O2	47.27
940371	AE2-021 C O2	10.1
940372	AE2-021 E O2	47.27
940381	AE2-022 C O2	5.89
940382	AE2-022 E O2	27.58
940391	AE2-023 C O2	7.65
940392	AE2-023 E O2	35.79
940771	AE2-064 C	0.18
940772	AE2-064 E	0.25
940781	AE2-065 C	0.12
940782	AE2-065 E	0.19
940951	AE2-085 C	0.23
940952	AE2-085 E	0.21
940961	AE2-087 C	0.16
940962	AE2-087 E	0.22
940963	AE2-087 BAT	0.06
940971	AE2-088 C	0.09
940972	AE2-088 E	0.12
940973	AE2-088 BAT	0.05
941001	AE2-091 C O2	2.5
941002	AE2-091 E O2	1.31
941051	AE2-097 C	0.12
941052	AE2-097 E	0.2
941071	AE2-101 C	0.21
941072	AE2-101 E	0.29
941121	AE2-106 C	0.18
941122	AE2-106 E	0.25
941123	AE2-106 BAT	0.06
941441	AE2-141 C	0.14
941442	AE2-141 E	0.23
941471	AE2-144 C	0.25
941472	AE2-144 E	0.23
941931	AE2-205 C O2	4.7
941932	AE2-205 E O2	3.13
942011	AE2-213 C	0.19
942012	AE2-213 E	0.17
942101	AE2-222 C O2	8.29
942102	AE2-222 E O2	20.83
942201	AE2-232 C O2	10.66
942202	AE2-232 E O2	27.28
942381	AE2-251 C O2	31.99
942382	AE2-251 E O2	81.85
942571	AE2-272	0.17
942941	AE2-314 C	4.1
942942	AE2-314 E	2.73
943071	AE2-334 C	3.41
943072	AE2-334 E	1.82
943081	AE2-335 C O2	4.86
943082	AE2-335 E O2	2.17
BLUEG	BLUEG	2.88
CALDERWOOD	CALDERWOOD	0.32

Bus #	Bus	MW Impact
CANNELTON	CANNELTON	0.18
CATAWBA	CATAWBA	0.21
CBM-N	CBM-N	0.87
CHEOAH	CHEOAH	0.29
CHILHOWEE	CHILHOWEE	0.1
COFFEEN	COFFEEN	0.3
COTTONWOOD	COTTONWOOD	1.22
DUCKCREEK	DUCKCREEK	0.66
EDWARDS	EDWARDS	0.3
ELMERSMITH	ELMERSMITH	0.3
FARMERCITY	FARMERCITY	0.2
G-007A	G-007A	8.18
GIBSON	GIBSON	0.12
HAMLET	HAMLET	0.34
NEWTON	NEWTON	0.79
NYISO	NYISO	3.79
PRAIRIE	PRAIRIE	1.49
SANTEETLA	SANTEETLA	0.09
SMITHLAND	SMITHLAND	0.12
TATANKA	TATANKA	0.36
TILTON	TILTON	0.36
TRIMBLE	TRIMBLE	0.32
TVA	TVA	1.01
UNIONPOWER	UNIONPOWER	0.45
VFT	VFT	16.55

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1715087	214206	RICHRE29	PECO	213922	RICHMOND	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	117.75	118.26	DC	14.75

Bus #	Bus	MW Impact
219124	CAMDEN_STG	3.13
219126	CAMDEN_CTG	3.85
219128	GLOUCSTR_26	1.7
219229	EAGLEPT_G3	2.79
219230	EAGLEPT_G1	4.12
219231	EAGLEPT_G2	4.12
219241	CAMDEN1	0.23
219242	CAMDEN2	0.03
227801	ONTC&DCT	7.56
227843	MARINGEN E	0.78
227928	V4-067E	0.31
228261	V4-054E	1.44
228357	V2-046E	3.3
228423	Q-090 2	30.11
228712	V2-041E	0.52
228721	V2-035E	0.3
291995	U4-036 C	0.08
291996	U4-036 E	1.12

Bus #	Bus	MW Impact
292063	V1-021 E	0.06
292088	V1-030 CB	0.11
292099	V1-030 E3	0.22
292104	V1-030 C6	0.02
292105	V1-030 E6	0.33
292115	V1-030 EB	1.49
292194	V1-030 CE	0.1
292195	V1-030 EE	1.37
293404	V3-036	1.08
902092	W1-130E	1.43
902432	W2-030 E	1.21
902692	W2-056 E	1.53
902842	W2-071E	0.44
903152	W2-102 E	0.98
903991	W3-080C	1.35
903992	W3-080E	2.2
904042	V4-005 E	0.4
904432	W3-124 E	0.4
905792	W4-103 E	0.97
907381	X1-070 C	0.05
907382	X1-070 E	0.77
907391	X1-071 C	0.01
907392	X1-071 E	0.26
909032	X2-013 E	0.7
910862	X3-075 E	1.18
913332	Y1-075 E	0.39
914231	Y2-081 C OP1	1.35
914232	Y2-081 E OP1	0.07
915022	Y3-012 E	1.47
915072	Y3-026 E	1.1
915591	Y3-087 C OP1	0.06
915592	Y3-087 E OP1	0.89
916292	Z1-082 E	0.38
917381	Z2-062	0.14
919901	AB1-000 1	1.04
919911	AB1-000 2	1.04
919921	AB1-000 3	1.04
924051	AB2-049 C	0.91
924052	AB2-049 E	1.48
924531	AB2-102 C	45.91
924532	AB2-102 E	1.02
924701	AB2-122 C	0.14
924702	AB2-122 E	0.23
925391	AC1-010 C	0.87
925392	AC1-010 E	1.5
925442	AC1-016 E	0.97
925452	AC1-017 E	0.56
925561	AC1-030 C	0.04
925562	AC1-030 E	0.52
930002	AB1-001 E	0.28
930102	AB1-025 E	0.94
930242	AB1-063 E	0.15

Bus #	Bus	MW Impact
930722	AB1-116 E	0.19
930732	AB1-119 E	0.17
931191	AB1-169A	126.85
932361	AC2-050 C O1	0.86
932362	AC2-050 E O1	1.41
933962	AD1-019 E	1.49
934661	AD1-097 1	1.67
934671	AD1-097 2	1.67
934681	AD1-097 3	1.67
934691	AD1-097 4	0.99
936211	AD2-027 C	1.57
936212	AD2-027 E	2.57
936321	AD2-042 C	2.07
936322	AD2-042 E	3.4
936411	AD2-052 C	1.66
936412	AD2-052 E	0.82
936491	AD2-064 C	0.12
936492	AD2-064 E	0.17
936501	AD2-065 C	0.51
936502	AD2-065 E	0.71
936541	AD2-069 C	0.51
936542	AD2-069 E	0.25
937011	AD2-135 C	0.14
937012	AD2-135 E	0.24
938311	AE1-046 C	0.46
938312	AE1-046 E	0.23
938421	AE1-061 C	0.61
938422	AE1-061 E	0.61
938431	AE1-062 C	1.23
938432	AE1-062 E	1.23
938611	AE1-083 C	0.35
938612	AE1-083 E	0.49
938781	AE1-104 C O1	27.85
938782	AE1-104 E O1	71.26
938871	AE1-115 C	1.36
938872	AE1-115 E	1.36
939301	AE1-161 C	2.57
939302	AE1-161 E	3.85
939501	AE1-179 C O1	7.79
939502	AE1-179 E O1	5.5
939821	AE1-218 C O1	0.2
939822	AE1-218 E O1	0.3
939831	AE1-219 C O1	0.44
939832	AE1-219 E O1	0.64
939931	AE1-229 C O1	21.94
939932	AE1-229 E O1	14.86
940001	AE1-240 C O1	6.46
940002	AE1-240 E O1	4.61
940281	AE2-011 C	0.31
940282	AE2-011 E	0.42
940361	AE2-020 C O2	20.21
940362	AE2-020 E O2	94.63

Bus #	Bus	MW Impact
940371	AE2-021 C O2	20.21
940372	AE2-021 E O2	94.63
940381	AE2-022 C O2	11.79
940382	AE2-022 E O2	55.2
940391	AE2-023 C O2	15.45
940392	AE2-023 E O2	72.34
940771	AE2-064 C	0.41
940772	AE2-064 E	0.56
940781	AE2-065 C	0.26
940782	AE2-065 E	0.41
940951	AE2-085 C	0.41
940952	AE2-085 E	0.39
940961	AE2-087 C	0.34
940962	AE2-087 E	0.47
940963	AE2-087 BAT	0.13
940971	AE2-088 C	0.18
940972	AE2-088 E	0.25
940973	AE2-088 BAT	0.1
941001	AE2-091 C O2	5.24
941002	AE2-091 E O2	2.73
941051	AE2-097 C	0.25
941052	AE2-097 E	0.41
941071	AE2-101 C	0.46
941072	AE2-101 E	0.63
941121	AE2-106 C	0.38
941122	AE2-106 E	0.52
941123	AE2-106 BAT	0.13
941441	AE2-141 C	0.26
941442	AE2-141 E	0.42
941471	AE2-144 C	0.55
941472	AE2-144 E	0.97
941931	AE2-205 C O2	9.7
941932	AE2-205 E O2	6.47
942011	AE2-213 C	0.41
942012	AE2-213 E	0.7
942101	AE2-222 C O2	16.74
942102	AE2-222 E O2	42.04
942201	AE2-232 C O2	21.34
942202	AE2-232 E O2	54.61
942381	AE2-251 C O2	64.03
942382	AE2-251 E O2	163.83
942571	AE2-272	0.36
942941	AE2-314 C	8.2
942942	AE2-314 E	5.47
943071	AE2-334 C	7.11
943072	AE2-334 E	3.79
943081	AE2-335 C O2	10.2
943082	AE2-335 E O2	4.55
BLUEG	BLUEG	5.69
CALDERWOOD	CALDERWOOD	0.61
CANNELTON	CANNELTON	0.34
CATAWBA	CATAWBA	0.39

Bus #	Bus	MW Impact
CBM-N	CBM-N	0.34
CHEOAH	CHEOAH	0.56
CHILHOWEE	CHILHOWEE	0.2
COFFEEN	COFFEEN	0.6
COTTONWOOD	COTTONWOOD	2.36
DUCKCREEK	DUCKCREEK	1.31
EDWARDS	EDWARDS	0.6
ELMERSMITH	ELMERSMITH	0.59
FARMERCITY	FARMERCITY	0.4
G-007A	G-007A	9.86
GIBSON	GIBSON	0.23
HAMLET	HAMLET	0.63
NEWTON	NEWTON	1.57
NYISO	NYISO	1.45
PRAIRIE	PRAIRIE	2.92
SANTEETLA	SANTEETLA	0.16
SMITHLAND	SMITHLAND	0.23
TATANKA	TATANKA	0.71
TILTON	TILTON	0.72
TRIMBLE	TRIMBLE	0.63
TVA	TVA	1.97
UNIONPOWER	UNIONPOWER	0.88
VFT	VFT	14.46

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1715120	219110	GLOUCSTR	PSE&G	219125	CAMDEN	PSE&G	1	PS_P2-3_CUTB_1-4_LT	breaker	771.0	112.21	112.71	DC	8.35

Bus #	Bus	MW Impact
219124	CAMDEN_STG	2.61
219126	CAMDEN_CTG	3.21
219128	GLOUCSTR_26	1.41
219229	EAGLEPT_G3	2.25
219230	EAGLEPT_G1	3.34
219231	EAGLEPT_G2	3.34
227801	ONTC&DCT	3.65
227843	MARINGEN E	0.38
227928	V4-067E	0.15
228261	V4-054E	0.82
228357	V2-046E	2.03
228423	Q-090 2	21.2
228712	V2-041E	0.28
228721	V2-035E	0.18
291995	U4-036 C	0.06
291996	U4-036 E	0.86
292063	V1-021 E	0.03
292104	V1-030 C6	0.02
292105	V1-030 E6	0.25
292194	V1-030 CE	0.09
292195	V1-030 EE	1.14

Bus #	Bus	MW Impact
293404	V3-036	0.52
902092	W1-130E	0.79
902432	W2-030 E	0.59
909032	X2-013 E	0.54
910862	X3-075 E	0.99
914231	Y2-081 C OP1	1.07
914232	Y2-081 E OP1	0.06
915022	Y3-012 E	0.71
915591	Y3-087 C OP1	0.05
915592	Y3-087 E OP1	0.7
916292	Z1-082 E	0.14
917381	Z2-062	0.12
924051	AB2-049 C	0.42
924052	AB2-049 E	0.69
924531	AB2-102 C	24.15
924532	AB2-102 E	0.54
924701	AB2-122 C	0.06
924702	AB2-122 E	0.11
925391	AC1-010 C	0.72
925392	AC1-010 E	1.25
930002	AB1-001 E	0.14
930722	AB1-116 E	0.1
930732	AB1-119 E	0.07
931191	AB1-169A	69.49
933962	AD1-019 E	0.72
936411	AD2-052 C	1.01
936412	AD2-052 E	0.5
936491	AD2-064 C	0.05
936492	AD2-064 E	0.07
936501	AD2-065 C	0.19
936502	AD2-065 E	0.26
937011	AD2-135 C	0.06
937012	AD2-135 E	0.11
938311	AE1-046 C	0.25
938312	AE1-046 E	0.13
938421	AE1-061 C	0.34
938422	AE1-061 E	0.34
938431	AE1-062 C	0.46
938432	AE1-062 E	0.46
938781	AE1-104 C O1	13.91
938782	AE1-104 E O1	35.59
938871	AE1-115 C	0.85
938872	AE1-115 E	0.85
939301	AE1-161 C	1.45
939302	AE1-161 E	2.18
939501	AE1-179 C O1	4.28
939502	AE1-179 E O1	3.02
939821	AE1-218 C O1	0.11
939822	AE1-218 E O1	0.16
939831	AE1-219 C O1	0.24
939832	AE1-219 E O1	0.34
939931	AE1-229 C O1	13.11

Bus #	Bus	MW Impact
939932	AE1-229 E O1	8.89
940001	AE1-240 C O1	3.56
940002	AE1-240 E O1	2.54
940281	AE2-011 C	0.13
940282	AE2-011 E	0.18
940361	AE2-020 C O2	9.37
940362	AE2-020 E O2	43.85
940371	AE2-021 C O2	9.37
940372	AE2-021 E O2	43.85
940381	AE2-022 C O2	5.46
940382	AE2-022 E O2	25.58
940391	AE2-023 C O2	7.5
940392	AE2-023 E O2	35.11
940771	AE2-064 C	0.32
940772	AE2-064 E	0.44
940781	AE2-065 C	0.21
940782	AE2-065 E	0.33
940961	AE2-087 C	0.19
940962	AE2-087 E	0.27
940963	AE2-087 BAT	0.07
940971	AE2-088 C	0.1
940972	AE2-088 E	0.14
940973	AE2-088 BAT	0.06
941001	AE2-091 C O2	2.94
941002	AE2-091 E O2	1.53
941071	AE2-101 C	0.3
941072	AE2-101 E	0.41
941121	AE2-106 C	0.22
941122	AE2-106 E	0.3
941123	AE2-106 BAT	0.07
941471	AE2-144 C	0.44
941472	AE2-144 E	0.78
941931	AE2-205 C O2	5.11
941932	AE2-205 E O2	3.41
942011	AE2-213 C	0.32
942012	AE2-213 E	0.54
942101	AE2-222 C O2	8.07
942102	AE2-222 E O2	20.28
942201	AE2-232 C O2	9.89
942202	AE2-232 E O2	25.31
942381	AE2-251 C O2	29.67
942382	AE2-251 E O2	75.92
942571	AE2-272	0.22
942941	AE2-314 C	3.8
942942	AE2-314 E	2.53
943071	AE2-334 C	3.87
943072	AE2-334 E	2.06
943081	AE2-335 C O2	5.78
943082	AE2-335 E O2	2.57
BLUEG	BLUEG	1.6
CALDERWOOD	CALDERWOOD	0.16
CANNELTON	CANNELTON	0.1

Bus #	Bus	MW Impact
CARR	CARR	0.37
CATAWBA	CATAWBA	0.1
CHEOAH	CHEOAH	0.15
CHILHOWEE	CHILHOWEE	0.05
COFFEEN	COFFEEN	0.17
COTTONWOOD	COTTONWOOD	0.64
DUCKCREEK	DUCKCREEK	0.37
EDWARDS	EDWARDS	0.17
ELMERSMITH	ELMERSMITH	0.17
FARMERCITY	FARMERCITY	0.11
G-007	G-007	0.75
GIBSON	GIBSON	0.07
HAMLET	HAMLET	0.16
NEWTON	NEWTON	0.44
O-066	O-066	8.35
PRAIRIE	PRAIRIE	0.82
RENSSELAER	RENSSELAER	0.3
SANTEETLA	SANTEETLA	0.04
SMITHLAND	SMITHLAND	0.06
TATANKA	TATANKA	0.2
TILTON	TILTON	0.2
TRIMBLE	TRIMBLE	0.18
TVA	TVA	0.54
UNIONPOWER	UNIONPOWER	0.24

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1715082	219125	CAMDEN	PSE&G	214206	RICHRE29	PECO	1	PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	breaker	1336.0	117.77	118.27	DC	14.75

Bus #	Bus	MW Impact
219124	CAMDEN_STG	3.13
219126	CAMDEN_CTG	3.85
219128	GLOUCSTR_26	1.7
219229	EAGLEPT_G3	2.79
219230	EAGLEPT_G1	4.12
219231	EAGLEPT_G2	4.12
219241	CAMDEN1	0.23
219242	CAMDEN2	0.03
227801	ONTC&DCT	7.56
227843	MARINGEN E	0.78
227928	V4-067E	0.31
228261	V4-054E	1.44
228357	V2-046E	3.3
228423	Q-090 2	30.11
228712	V2-041E	0.52
228721	V2-035E	0.3
291995	U4-036 C	0.08
291996	U4-036 E	1.12
292063	V1-021 E	0.06

Bus #	Bus	MW Impact
292088	V1-030 CB	0.11
292099	V1-030 E3	0.22
292104	V1-030 C6	0.02
292105	V1-030 E6	0.33
292115	V1-030 EB	1.49
292194	V1-030 CE	0.1
292195	V1-030 EE	1.37
293404	V3-036	1.08
902092	W1-130E	1.43
902432	W2-030 E	1.21
902692	W2-056 E	1.53
902842	W2-071E	0.44
903152	W2-102 E	0.98
903991	W3-080C	1.35
903992	W3-080E	2.2
904042	V4-005 E	0.4
904432	W3-124 E	0.4
905792	W4-103 E	0.97
907381	X1-070 C	0.05
907382	X1-070 E	0.77
907391	X1-071 C	0.01
907392	X1-071 E	0.26
909032	X2-013 E	0.7
910862	X3-075 E	1.18
913332	Y1-075 E	0.39
914231	Y2-081 C OP1	1.35
914232	Y2-081 E OP1	0.07
915022	Y3-012 E	1.47
915072	Y3-026 E	1.1
915591	Y3-087 C OP1	0.06
915592	Y3-087 E OP1	0.89
916292	Z1-082 E	0.38
917381	Z2-062	0.14
919901	AB1-000 1	1.04
919911	AB1-000 2	1.04
919921	AB1-000 3	1.04
924051	AB2-049 C	0.91
924052	AB2-049 E	1.48
924531	AB2-102 C	45.91
924532	AB2-102 E	1.02
924701	AB2-122 C	0.14
924702	AB2-122 E	0.23
925391	AC1-010 C	0.87
925392	AC1-010 E	1.5
925442	AC1-016 E	0.97
925452	AC1-017 E	0.56
925561	AC1-030 C	0.04
925562	AC1-030 E	0.52
930002	AB1-001 E	0.28
930102	AB1-025 E	0.94
930242	AB1-063 E	0.15
930722	AB1-116 E	0.19

Bus #	Bus	MW Impact
930732	AB1-119 E	0.17
931191	AB1-169A	126.85
932361	AC2-050 C O1	0.86
932362	AC2-050 E O1	1.41
933962	AD1-019 E	1.49
934661	AD1-097 1	1.67
934671	AD1-097 2	1.67
934681	AD1-097 3	1.67
934691	AD1-097 4	0.99
936211	AD2-027 C	1.57
936212	AD2-027 E	2.57
936321	AD2-042 C	2.07
936322	AD2-042 E	3.4
936411	AD2-052 C	1.66
936412	AD2-052 E	0.82
936491	AD2-064 C	0.12
936492	AD2-064 E	0.17
936501	AD2-065 C	0.51
936502	AD2-065 E	0.71
936541	AD2-069 C	0.51
936542	AD2-069 E	0.25
937011	AD2-135 C	0.14
937012	AD2-135 E	0.24
938311	AE1-046 C	0.46
938312	AE1-046 E	0.23
938421	AE1-061 C	0.61
938422	AE1-061 E	0.61
938431	AE1-062 C	1.23
938432	AE1-062 E	1.23
938611	AE1-083 C	0.35
938612	AE1-083 E	0.49
938781	AE1-104 C O1	27.85
938782	AE1-104 E O1	71.26
938871	AE1-115 C	1.36
938872	AE1-115 E	1.36
939301	AE1-161 C	2.57
939302	AE1-161 E	3.85
939501	AE1-179 C O1	7.79
939502	AE1-179 E O1	5.5
939821	AE1-218 C O1	0.2
939822	AE1-218 E O1	0.3
939831	AE1-219 C O1	0.44
939832	AE1-219 E O1	0.64
939931	AE1-229 C O1	21.94
939932	AE1-229 E O1	14.86
940001	AE1-240 C O1	6.46
940002	AE1-240 E O1	4.61
940281	AE2-011 C	0.31
940282	AE2-011 E	0.42
940361	AE2-020 C O2	20.21
940362	AE2-020 E O2	94.63
940371	AE2-021 C O2	20.21

Bus #	Bus	MW Impact
940372	AE2-021 E O2	94.63
940381	AE2-022 C O2	11.79
940382	AE2-022 E O2	55.2
940391	AE2-023 C O2	15.45
940392	AE2-023 E O2	72.34
940771	AE2-064 C	0.41
940772	AE2-064 E	0.56
940781	AE2-065 C	0.26
940782	AE2-065 E	0.41
940951	AE2-085 C	0.41
940952	AE2-085 E	0.39
940961	AE2-087 C	0.34
940962	AE2-087 E	0.47
940963	AE2-087 BAT	0.13
940971	AE2-088 C	0.18
940972	AE2-088 E	0.25
940973	AE2-088 BAT	0.1
941001	AE2-091 C O2	5.24
941002	AE2-091 E O2	2.73
941051	AE2-097 C	0.25
941052	AE2-097 E	0.41
941071	AE2-101 C	0.46
941072	AE2-101 E	0.63
941121	AE2-106 C	0.38
941122	AE2-106 E	0.52
941123	AE2-106 BAT	0.13
941441	AE2-141 C	0.26
941442	AE2-141 E	0.42
941471	AE2-144 C	0.55
941472	AE2-144 E	0.97
941931	AE2-205 C O2	9.7
941932	AE2-205 E O2	6.47
942011	AE2-213 C	0.41
942012	AE2-213 E	0.7
942101	AE2-222 C O2	16.74
942102	AE2-222 E O2	42.04
942201	AE2-232 C O2	21.34
942202	AE2-232 E O2	54.61
942381	AE2-251 C O2	64.03
942382	AE2-251 E O2	163.83
942571	AE2-272	0.36
942941	AE2-314 C	8.2
942942	AE2-314 E	5.47
943071	AE2-334 C	7.11
943072	AE2-334 E	3.79
943081	AE2-335 C O2	10.2
943082	AE2-335 E O2	4.55
BLUEG	BLUEG	5.69
CALDERWOOD	CALDERWOOD	0.61
CANNELTON	CANNELTON	0.34
CATAWBA	CATAWBA	0.39
CBM-N	CBM-N	0.34

Bus #	Bus	MW Impact
CHEOAH	CHEOAH	0.56
CHILHOWEE	CHILHOWEE	0.2
COFFEEN	COFFEEN	0.6
COTTONWOOD	COTTONWOOD	2.36
DUCKCREEK	DUCKCREEK	1.31
EDWARDS	EDWARDS	0.6
ELMERSMITH	ELMERSMITH	0.59
FARMERCITY	FARMERCITY	0.4
G-007A	G-007A	9.86
GIBSON	GIBSON	0.23
HAMLET	HAMLET	0.63
NEWTON	NEWTON	1.57
NYISO	NYISO	1.45
PRAIRIE	PRAIRIE	2.92
SANTEETLA	SANTEETLA	0.16
SMITHLAND	SMITHLAND	0.23
TATANKA	TATANKA	0.71
TILTON	TILTON	0.72
TRIMBLE	TRIMBLE	0.63
TVA	TVA	1.97
UNIONPOWER	UNIONPOWER	0.88
VFT	VFT	14.46

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1714964	227902	LEWIS #1	AE	227945	LEWIS #2	AE	1	AE_P4-2 AE33	breaker	286.8	161.07	163.86	DC	8.01

Bus #	Bus	MW Impact
227801	ONTC&DCT	3.58
227843	MARINGEN E	0.38
228014	PVILLEG	0.06
228720	V2-035C	0.01
228721	V2-035E	0.15
293404	V3-036	0.51
902091	W1-130C	0.14
902092	W1-130E	1.91
915022	Y3-012 E	0.72
930001	AB1-001 C	0.01
930002	AB1-001 E	0.18
931191	AB1-169A	171.55
933962	AD1-019 E	0.7
938311	AE1-046 C	0.62
938312	AE1-046 E	0.31
938421	AE1-061 C	1.54
938422	AE1-061 E	1.54
939301	AE1-161 C	3.4
939302	AE1-161 E	5.1
939931	AE1-229 C O1	6.89
939932	AE1-229 E O1	4.67

Bus #	Bus	MW Impact
940391	AE2-023 C O2	56.68
940392	AE2-023 E O2	265.37
940971	AE2-088 C	0.09
940972	AE2-088 E	0.13
940973	AE2-088 BAT	0.1
942101	AE2-222 C O2	7.91
942102	AE2-222 E O2	19.88
943081	AE2-335 C O2	5.54
943082	AE2-335 E O2	2.47
CARR	CARR	0.0
CBM-S1	CBM-S1	0.14
CBM-S2	CBM-S2	0.07
CBM-W1	CBM-W1	0.25
CBM-W2	CBM-W2	1.04
CIN	CIN	0.11
CPLE	CPLE	0.03
G-007	G-007	0.22
IPL	IPL	0.07
LGEE	LGEE	0.03
MEC	MEC	0.2
MECS	MECS	0.15
O-066	O-066	0.25
RENSSELAER	RENSSELAER	0.0
WEC	WEC	0.03

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1899594	228312	PEDRKTWN	AE	228313	BRIDGPRT	AE	1	AE_P7-1 AE10TOWER-A	tower	552.0	107.47	110.51	DC	16.63

Bus #	Bus	MW Impact
227801	ONTC&DCT	4.76
227843	MARINGEN E	0.49
227928	V4-067E	0.19
228201	CARL#2CT	0.55
228261	V4-054E	1.13
228306	PCLP STM	4.77
228307	PCLP GT	4.76
228309	CCLP NUG	14.01
228334	MANNMILG	0.24
228343	QUINTN#1	0.06
228351	V2-046C	0.18
228357	V2-046E	2.72
228712	V2-041E	0.4
228720	V2-035C	0.03
228721	V2-035E	0.4
292063	V1-021 E	0.05
293404	V3-036	0.68
902091	W1-130C	0.11
902092	W1-130E	1.49
902432	W2-030 E	0.77

Bus #	Bus	MW Impact
915022	Y3-012 E	0.92
924531	AB2-102 C	38.79
924532	AB2-102 E	0.86
924701	AB2-122 C	0.08
924702	AB2-122 E	0.14
930002	AB1-001 E	0.18
931191	AB1-169A	131.36
933962	AD1-019 E	0.94
936411	AD2-052 C	1.76
936412	AD2-052 E	0.87
938311	AE1-046 C	0.48
938312	AE1-046 E	0.24
938421	AE1-061 C	1.2
938422	AE1-061 E	1.2
938781	AE1-104 C O1	19.7
938782	AE1-104 E O1	50.4
938871	AE1-115 C	3.12
938872	AE1-115 E	3.12
939301	AE1-161 C	5.54
939302	AE1-161 E	8.31
939501	AE1-179 C O1	5.55
939502	AE1-179 E O1	3.92
939931	AE1-229 C O1	32.63
939932	AE1-229 E O1	22.11
940001	AE1-240 C O1	4.71
940002	AE1-240 E O1	3.36
940361	AE2-020 C O2	11.08
940362	AE2-020 E O2	51.88
940371	AE2-021 C O2	11.08
940372	AE2-021 E O2	51.88
940381	AE2-022 C O2	6.46
940382	AE2-022 E O2	30.27
940391	AE2-023 C O2	10.07
940392	AE2-023 E O2	47.15
940961	AE2-087 C	0.27
940962	AE2-087 E	0.37
940963	AE2-087 BAT	0.1
941001	AE2-091 C O2	3.94
941002	AE2-091 E O2	2.05
941071	AE2-101 C	0.31
941072	AE2-101 E	0.42
941121	AE2-106 C	0.3
941122	AE2-106 E	0.41
941123	AE2-106 BAT	0.1
941931	AE2-205 C O2	7.63
941932	AE2-205 E O2	5.09
942101	AE2-222 C O2	10.52
942102	AE2-222 E O2	26.44
942201	AE2-232 C O2	11.7
942202	AE2-232 E O2	29.94
942381	AE2-251 C O2	35.11
942382	AE2-251 E O2	89.83

Bus #	Bus	MW Impact
942571	AE2-272	0.3
942941	AE2-314 C	4.5
942942	AE2-314 E	3.0
943081	AE2-335 C O2	11.5
943082	AE2-335 E O2	5.13
BLUEG	BLUEG	0.52
CALDERWOOD	CALDERWOOD	0.05
CANNELTON	CANNELTON	0.03
CARR	CARR	0.07
CATAWBA	CATAWBA	0.03
CHEOAH	CHEOAH	0.05
CHILHOWEE	CHILHOWEE	0.02
COFFEEN	COFFEEN	0.06
COTTONWOOD	COTTONWOOD	0.21
DUCKCREEK	DUCKCREEK	0.12
EDWARDS	EDWARDS	0.06
ELMERSMITH	ELMERSMITH	0.05
FARMERCITY	FARMERCITY	0.04
G-007A	G-007A	0.58
GIBSON	GIBSON	0.02
HAMLET	HAMLET	0.05
NEWTON	NEWTON	0.14
O-066	O-066	1.13
PRAIRIE	PRAIRIE	0.27
RENSELAER	RENSELAER	0.05
SANTEETLA	SANTEETLA	0.01
SMITHLAND	SMITHLAND	0.02
TATANKA	TATANKA	0.07
TILTON	TILTON	0.07
TRIMBLE	TRIMBLE	0.06
TVA	TVA	0.18
UNIONPOWER	UNIONPOWER	0.08

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1899624	228313	BRIDGPRT	AE	228401	MCKLTON	AE	1	AE_P7-1 AE8TOWER-A	tower	805.0	99.2	101.29	DC	16.56

Bus #	Bus	MW Impact
227801	ONTC&DCT	4.71
227843	MARINGEN E	0.49
227928	V4-067E	0.19
228261	V4-054E	1.12
228304	LOGAN	18.88
228306	PCLP STM	4.76
228307	PCLP GT	4.75
228309	CCLP NUG	13.97
228334	MANNMILG	0.24

Bus #	Bus	MW Impact
228343	QUINTN#1	0.06
228351	V2-046C	0.18
228357	V2-046E	2.71
228712	V2-041E	0.4
228720	V2-035C	0.03
228721	V2-035E	0.4
292063	V1-021 E	0.05
293404	V3-036	0.67
902091	W1-130C	0.11
902092	W1-130E	1.48
902432	W2-030 E	0.76
915022	Y3-012 E	0.91
924531	AB2-102 C	38.52
924532	AB2-102 E	0.86
924701	AB2-122 C	0.08
924702	AB2-122 E	0.14
930002	AB1-001 E	0.17
931191	AB1-169A	130.71
933962	AD1-019 E	0.93
936411	AD2-052 C	1.75
936412	AD2-052 E	0.86
938311	AE1-046 C	0.48
938312	AE1-046 E	0.24
938421	AE1-061 C	1.19
938422	AE1-061 E	1.19
938781	AE1-104 C O1	19.54
938782	AE1-104 E O1	49.98
938871	AE1-115 C	3.11
938872	AE1-115 E	3.11
939301	AE1-161 C	5.52
939302	AE1-161 E	8.28
939501	AE1-179 C O1	5.51
939502	AE1-179 E O1	3.89
939931	AE1-229 C O1	32.52
939932	AE1-229 E O1	22.03
940001	AE1-240 C O1	4.67
940002	AE1-240 E O1	3.34
940361	AE2-020 C O2	10.95
940362	AE2-020 E O2	51.29
940371	AE2-021 C O2	10.95
940372	AE2-021 E O2	51.29
940381	AE2-022 C O2	6.39
940382	AE2-022 E O2	29.92
940391	AE2-023 C O2	9.98
940392	AE2-023 E O2	46.71
940961	AE2-087 C	0.27
940962	AE2-087 E	0.37
940963	AE2-087 BAT	0.1
940971	AE2-088 C	0.2
940972	AE2-088 E	0.28
940973	AE2-088 BAT	0.22
941001	AE2-091 C O2	3.91

Bus #	Bus	MW Impact
941002	AE2-091 E O2	2.04
941071	AE2-101 C	0.3
941072	AE2-101 E	0.42
941121	AE2-106 C	0.3
941122	AE2-106 E	0.41
941123	AE2-106 BAT	0.1
941931	AE2-205 C O2	7.58
941932	AE2-205 E O2	5.05
942101	AE2-222 C O2	10.42
942102	AE2-222 E O2	26.18
942201	AE2-232 C O2	11.57
942202	AE2-232 E O2	29.6
942381	AE2-251 C O2	34.7
942382	AE2-251 E O2	88.8
942571	AE2-272	0.29
942941	AE2-314 C	4.45
942942	AE2-314 E	2.96
943081	AE2-335 C O2	11.45
943082	AE2-335 E O2	5.11
BLUEG	BLUEG	1.13
CALDERWOOD	CALDERWOOD	0.12
CANNELTON	CANNELTON	0.07
CARR	CARR	0.11
CATAWBA	CATAWBA	0.08
CHEOAH	CHEOAH	0.11
CHILHOWEE	CHILHOWEE	0.04
COFFEEN	COFFEEN	0.12
COTTONWOOD	COTTONWOOD	0.47
DUCKCREEK	DUCKCREEK	0.26
EDWARDS	EDWARDS	0.12
ELMERSMITH	ELMERSMITH	0.12
FARMERCITY	FARMERCITY	0.08
G-007A	G-007A	0.29
GIBSON	GIBSON	0.05
HAMLET	HAMLET	0.12
NEWTON	NEWTON	0.31
O-066	O-066	1.95
PRAIRIE	PRAIRIE	0.58
RENSSELAER	RENSSELAER	0.09
SANTEETLA	SANTEETLA	0.03
SMITHLAND	SMITHLAND	0.05
TATANKA	TATANKA	0.14
TILTON	TILTON	0.14
TRIMBLE	TRIMBLE	0.13
TVA	TVA	0.39
UNIONPOWER	UNIONPOWER	0.17

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1899565	228500	LANDIS	AE	228211	UPITTS	AE	1	AE_P7-1 AE10TOWER-A	tower	205.0	104.58	119.44	DC	30.46

Bus #	Bus	MW Impact
227801	ONTC&DCT	2.85
227843	MARINGEN E	0.3
227928	V4-067E	0.09
293404	V3-036	0.41
902091	W1-130C	0.19
902092	W1-130E	2.49
902432	W2-030 E	0.42
915022	Y3-012 E	0.55
924701	AB2-122 C	0.04
924702	AB2-122 E	0.07
930002	AB1-001 E	0.11
931191	AB1-169A	219.19
933962	AD1-019 E	0.56
938311	AE1-046 C	0.8
938312	AE1-046 E	0.4
938421	AE1-061 C	2.01
938422	AE1-061 E	2.01
938781	AE1-104 C O1	8.25
938782	AE1-104 E O1	21.1
939301	AE1-161 C	10.15
939302	AE1-161 E	15.23
940391	AE2-023 C O2	6.58
940392	AE2-023 E O2	30.83
942101	AE2-222 C O2	6.31
942102	AE2-222 E O2	15.84
943081	AE2-335 C O2	21.07
943082	AE2-335 E O2	9.39
BLUEG	BLUEG	0.05
CALDERWOOD	CALDERWOOD	0.01
CANNELTON	CANNELTON	0.0
CATAWBA	CATAWBA	0.0
CBM-N	CBM-N	0.06
CHEOAH	CHEOAH	0.01
CHILHOWEE	CHILHOWEE	0.0
COFFEEN	COFFEEN	0.01
COTTONWOOD	COTTONWOOD	0.02
DUCKCREEK	DUCKCREEK	0.01
EDWARDS	EDWARDS	0.01
ELMERSMITH	ELMERSMITH	0.01
FARMERCITY	FARMERCITY	0.0
G-007A	G-007A	0.7
GIBSON	GIBSON	0.0
HAMLET	HAMLET	0.01
NEWTON	NEWTON	0.01
NYISO	NYISO	0.24
PRAIRIE	PRAIRIE	0.03
SANTEETLA	SANTEETLA	0.0
SMITHLAND	SMITHLAND	0.0
TATANKA	TATANKA	0.01
TILTON	TILTON	0.01
TRIMBLE	TRIMBLE	0.01

Bus #	Bus	MW Impact
TVA	TVA	0.02
UNIONPOWER	UNIONPOWER	0.01
VFT	VFT	0.75

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
1899457	227901	DOROTHY	AE	227949	LEWIS #3	AE	1	AE_P7-1 AE10TOWER-A	tower	205.0	205.14	219.55	DC	29.53

Bus #	Bus	MW Impact
228720	V2-035C	0.03
228721	V2-035E	0.44
902091	W1-130C	0.28
902092	W1-130E	3.71
931191	AB1-169A	330.8
938311	AE1-046 C	1.2
938312	AE1-046 E	0.6
938421	AE1-061 C	2.99
938422	AE1-061 E	2.99
939301	AE1-161 C	9.84
939302	AE1-161 E	14.77
939931	AE1-229 C O1	21.12
939932	AE1-229 E O1	14.31
943081	AE2-335 C O2	20.43
943082	AE2-335 E O2	9.11
CARR	CARR	0.03
CBM-S1	CBM-S1	0.03
CBM-S2	CBM-S2	0.02
CBM-W1	CBM-W1	0.05
CBM-W2	CBM-W2	0.21
CIN	CIN	0.02
CPLE	CPLE	0.01
G-007	G-007	0.31
IPL	IPL	0.01
LGEE	LGEE	0.01
MEC	MEC	0.04
MECS	MECS	0.03
O-066	O-066	0.8
RENSSELAER	RENSSELAER	0.02
WEC	WEC	0.01

Contingency Name	Contingency Definition
PS_P1-2_U-2299_LT	CONTINGENCY 'PS_P1-2_U-2299_LT' /* CAMDEN CUTBERTH DISCONNECT BUS 219754 /* CUTHBERTH SECTION 3 CLOSE LINE FROM BUS 219176 TO BUS 219179 CKT Z /* CUTBERTH MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219170 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO CINN T2 MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219676 /* INTERSTATION TIE TRANSFER LOAD

	<p>FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219724 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO LAWNSIDE END</p>
PS_P1-2_D-2282_LT	<p>CONTINGENCY 'PS_P1-2_D-2282_LT' /* CUTHBERT TO GLOUCESTER DISCONNECT BUS 219755 /* BUS SECTION 4 CUTHBERT CLOSE LINE FROM BUS 219177 TO BUS 219178 CKT Z /* CUTHBERT MOVE 8 MW LOAD FROM BUS 219178 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219177 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE END</p>
PS_P2-3_CUTB_3-4_LT	<p>CONTINGENCY 'PS_P2-3_CUTB_3-4_LT' DISCONNECT BUS 219754 /* CUTHBERTH SECTION 3 DISCONNECT BUS 219755 /* BUS SECTION 4 CUTHBERT CLOSE LINE FROM BUS 219177 TO BUS 219178 CKT Z /* CUTHBERT CLOSE LINE FROM BUS 219176 TO BUS 219179 CKT Z /* CUTBERTH MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219170 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO CINN T2 MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219178 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219177 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219629 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO LAWNSIDE END</p>
PS_P2-3_CUTB_1-4_LT	<p>CONTINGENCY 'PS_P2-3_CUTB_1-4_LT' DISCONNECT BUS 219108 /* CUTBERTH SECTION 1 DISCONNECT BUS 219755 /* BUS SECTION 4 CUTHBERT CLOSE LINE FROM BUS 219177 TO BUS 219178 CKT Z /* CUTHBERT CLOSE LINE FROM BUS 219176 TO BUS 219179 CKT Z /* CUTBERTH MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219170 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO CINN T2 MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219178 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219177 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219629 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO LAWNSIDE END</p>
PS_P2-3_CUTB_1-2_LT	<p>CONTINGENCY 'PS_P2-3_CUTB_1-2_LT' DISCONNECT BUS 219753 /* CUTHBERTH SECTION 2 DISCONNECT BUS 219108 /* CUTHBERTH SECTION 1 CLOSE LINE FROM BUS 219176 TO BUS 219179 CKT Z /* CUTBERTH CLOSE LINE FROM BUS 219177 TO BUS 219178 CKT Z /* CUTHBERT MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219170 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO CINN T2</p>

	MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219178 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219177 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219629 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO LAWNSIDE END
JC-P2-3-JCC-500-002D	CONTINGENCY 'JC-P2-3-JCC-500-002D' /* E.WINDSOR CB16 DISCONNECT BRANCH FROM BUS 200006 TO BUS 200028 CKT 1 /* DEANS - WINDSOR 500.00 LINE DISCONNECT BRANCH FROM BUS 200012 TO BUS 200028 CKT 1 /* NEWFRDM - WINDSOR 500.00 LINE END
AE_P1-3 MON 4 XFR	CONTINGENCY 'AE_P1-3 MON 4 XFR' OPEN LINE FROM BUS 228402 TO BUS 228404 CIRCUIT 2 / END
AE_P1-3 MON 3 XFR	CONTINGENCY 'AE_P1-3 MON 3 XFR' OPEN LINE FROM BUS 228402 TO BUS 228404 CIRCUIT 1 / END
AE_P7-1 AE8TOWER-A	CONTINGENCY 'AE_P7-1 AE8TOWER-A' DISCONNECT BRANCH FROM BUS 228404 TO BUS 228482 CKT 1 /* MONROE TO FRANK 138 KV DISCONNECT BRANCH FROM BUS 228404 TO BUS 943080 CKT 1 /* MONROE TO AE2-335 TAP 138 138 KV END
AE_P1-1 913341[Y1-077]-1-GEN	CONTINGENCY 'AE_P1-1 913341[Y1-077]-1-GEN' REMOVE MACHINE 1 FROM BUS 913341 /* PMAX = 73.0 MW END
PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B PECO_P2-2_CHI230B1 \$ B	CONTINGENCY 'PECO_P2-2_CHI230B1/* \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B' DISCONNECT BUS 213489 /* CHICHST1 230.00 \$ DELCO \$ PECO_P2-2_CHI230B1 \$ B END
AE_P1-2 ORCHARD XF	CONTINGENCY 'AE_P1-2 ORCHARD XF' OPEN LINE FROM BUS 200063 TO BUS 228002 CIRCUIT 1 / END
AE_P7-1 AE10TOWER-A	CONTINGENCY 'AE_P7-1 AE10TOWER-A' DISCONNECT BRANCH FROM BUS 228482 TO BUS 228500 CKT 1 /* FRANK TO LANDIS 138 KV DISCONNECT BRANCH FROM BUS 228404 TO BUS 943080 CKT 1 /* MONROE TO AE2-335 TAP 138 138 KV END
PECO_P1-2_5014/* \$ CHESCO \$ PECO_P1-2_5014 \$ L PECO_P1-2_5014 \$ L	CONTINGENCY 'PECO_P1-2_5014/* \$ CHESCO \$ PECO_P1-2_5014 \$ L' TRIP BRANCH FROM BUS 200065 TO BUS 200051 CKT 1 /* PCHBTM2S 500.00 ROCKSPGS 500.00 \$ CHESCO \$ PECO_P1-2_5014 \$ L

	END
AE_P4-2 AE33	CONTINGENCY 'AE_P4-2 AE33' /*LEWIS TO CARDIFF BREAKER V DISCONNECT BRANCH FROM BUS 227902 TO BUS 227913 CKT 1 /*LEWIS CARDIFF 138 138 DISCONNECT BRANCH FROM BUS 227902 TO BUS 227903 CKT 1 /*LEWIS MILL #1 138 138 DISCONNECT BRANCH FROM BUS 227902 TO BUS 227918 CKT 1 /*LEWIS 138 69 T1 END
PS_P1-2_Z-2305_LT	CONTINGENCY 'PS_P1-2_Z-2305_LT' /* CAMDEN TO CUTBERTH DISCONNECT BUS 219108 /* CUTBERTH SECTION 1 CLOSE LINE FROM BUS 219176 TO BUS 219179 CKT Z /* CUTBERTH MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219170 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO CINN T2 MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO LAWNSIDE END
PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK	CONTINGENCY 'PECO_P4_CHICH045/* \$ DELCO \$ PECO_P4_CHICH045 \$ STBK' DISCONNECT BUS 213489 /* CHICHST1 230.00 \$ DELCO \$ PECO_P4_CHICH045 \$ STBK DISCONNECT BUS 213627 /* FOULK8 230.00 \$ DELCO \$ PECO_P4_CHICH045 \$ STBK END
Base Case	
AE_P1-2 MONROE-LANDIS_1-A	CONTINGENCY 'AE_P1-2 MONROE-LANDIS_1-A' OPEN BRANCH FROM BUS 228404 TO BUS 943080 CKT 1 END
PS_P2-3_CUTB_2-3_LT	CONTINGENCY 'PS_P2-3_CUTB_2-3_LT' DISCONNECT BUS 219753 /* CUTHBERTH SECTION 2 DISCONNECT BUS 219754 /* CUTHBERTH SECTION 3 CLOSE LINE FROM BUS 219176 TO BUS 219179 CKT Z /* CUTBERTH CLOSE LINE FROM BUS 219177 TO BUS 219178 CKT Z /* CUTHBERT MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219170 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO CINN T2 MOVE 8 MW LOAD FROM BUS 219176 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219178 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219177 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE MOVE 8 MW LOAD FROM BUS 219179 TO BUS 219629 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO LAWNSIDE END
PECO_P4_PEACH215/* \$ CHESCO \$ PECO_P4_PEACH215 \$ STBK	CONTINGENCY 'PECO_P4_PEACH215/* \$ CHESCO \$ PECO_P4_PEACH215 \$ STBK' TRIP BRANCH FROM BUS 200065 TO BUS 200051 CKT 1 /* PCHBTM2S 500.00 ROCKSPGS 500.00 \$ CHESCO \$ PECO_P4_PEACH215 \$ STBK REMOVE MACHINE 1 FROM BUS 200034 /* PCHBTM 2 22.00 \$ CHESCO \$

	PECO_P4_PEACH215 \$ STBK END
PS_P1-2_C-2308_LT	CONTINGENCY 'PS_P1-2_C-2308_LT' /* CUTHBERT TO GLOUCESTER DISCONNECT BUS 219753 /* CUTHBERTH SECTOIN 2 CLOSE LINE FROM BUS 219177 TO BUS 219178 CKT Z /* CUTHBERT MOVE 8 MW LOAD FROM BUS 219178 TO BUS 219678 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE /* INTERSTATION TIE TRANSFER LOAD MOVE 8 MW LOAD FROM BUS 219177 TO BUS 219677 /* INTERSTATION TIE TRANSFER LOAD FROM CUTHBERT TO MAPLE SHADE END
AE_P4-2 AE46	CONTINGENCY 'AE_P4-2 AE46' /*ORCHARD 230 BUS BREAKER D DISCONNECT BRANCH FROM BUS 228002 TO BUS 228310 CKT 1 /* ORCHARD TO CHURCHTOWN 230 230 DISCONNECT BRANCH FROM BUS 200063 TO BUS 228002 CKT 1 /*ORCHARD ORCHARD 500 230 T1 END