



**Generation Interconnection  
Combined Feasibility and System Impact  
Study Report  
for  
Queue Project AF1-195  
GILBERT CT9 230 KV  
1 MW Capacity / 1 MW Energy**

January 2020

# Table of Contents

- 1 Introduction..... 3
- 2 Preface..... 3
- 3 General..... 5
  - 3.1 Point of Interconnection ..... 5
  - 3.2 Cost Summary..... 5
- 4 Transmission Owner Scope of Work..... 6
- 5 Attachment Facilities ..... 6
- 6 Direct Connection Cost Estimate..... 6
- 7 Non-Direct Connection Cost Estimate..... 6
- 8 Schedule..... 6
- 9 Transmission Owner Analysis..... 7
  - 9.1 Power Flow Analysis ..... 7
- 10 Interconnection Customer Requirements..... 8
  - System Protection ..... 8
  - Compliance Issues and Interconnection Customer Requirements..... 8
- 11 Revenue Metering and SCADA Requirements ..... 9
  - 11.1 PJM Requirements ..... 9
  - 11.2 JCPL Requirements..... 9
- 12 Network Impacts.....10
  - 12.1 Generation Deliverability .....12
  - 12.2 Multiple Facility Contingency .....12
  - 12.3 Contribution to Previously Identified Overloads.....12
  - 12.4 Potential Congestion due to Local Energy Deliverability.....12
- 13 Short Circuit.....14
- 14 Affected Systems .....16
  - 14.1 LG&E.....16
  - 14.2 MISO .....16
  - 14.3 TVA.....16
  - 14.4 Duke Energy Progress.....16
  - 14.5 NYISO .....16
- 15 Attachment 1 – One Line.....17

## 1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between, the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Jersey Central Power & Light Company (JCPL).

## 2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

### 3 General

The Interconnection Customer (IC), has proposed an increase to an existing Natural Gas generating facility located in Hunterdon County, Milford, New Jersey. Note that this project is an increase to the Interconnection Customer's existing Gilbert CT 9, which will share the same property and connection point. This projects requests an increase to the installed capability of Gilbert CT 9 of 1.0 MW with 1.0 MW of this output being recognized by PJM as Capacity. The installed facilities will have a total capability of 168 MW with 153 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is October 1, 2019. This study does not imply a TO commitment to this in-service date.

|                            |                    |
|----------------------------|--------------------|
| <b>Queue Number</b>        | <b>AF1-195</b>     |
| <b>Project Name</b>        | GILBERT CT9 230 KV |
| <b>State</b>               | New Jersey         |
| <b>County</b>              | Hunterdon          |
| <b>Transmission Owner</b>  | JCPL               |
| <b>MFO</b>                 | 168                |
| <b>MWE</b>                 | 1                  |
| <b>MWC</b>                 | 1                  |
| <b>Fuel</b>                | Natural Gas        |
| <b>Basecase Study Year</b> | 2023               |

#### 3.1 Point of Interconnection

AF1-195 will interconnect with the JCPL transmission system as an uprate to existing Gilbert CT; Unit: 9 at the Gilbert CT 18.0 kV substation.

#### 3.2 Cost Summary

The AF1-195 project will be responsible for the following costs:

| Description                                   | Total Cost |
|---|------------|
| <b>Attachment Facilities</b>                  | \$ 0       |
| <b>Direct Connection Network Upgrade</b>      | \$ 0       |
| <b>Non Direct Connection Network Upgrades</b> | \$ 0       |
| <b>Total Costs</b>                            | \$ 0       |

In addition, the AF1-195 project may be responsible for a contribution to the following costs

| Description            | Total Cost |
|------------------------|------------|
| <b>System Upgrades</b> | \$0        |

Cost allocations for these upgrades will be provided in the System Impact Study Report.

The costs provided above exclude the Contribution in Aid of Construction (“CIAC”) Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

#### **4 Transmission Owner Scope of Work**

The interconnection of the project at the Primary POI will be accomplished by utilizing the existing Gilbert unit 9 interconnection which is modeled by direct connection to the Gilbert 230 kV substation in the JCPL area. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct the associated facilities. The project will also require non-direct connection upgrades at Gilbert substation.

#### **5 Attachment Facilities**

There is no Attachment Facility scope of work required.

#### **6 Direct Connection Cost Estimate**

There is no Direct Connection scope of work required.

#### **7 Non-Direct Connection Cost Estimate**

There is no Non-Direct Connection scope of work required.

#### **8 Schedule**

AF1-195 is an increase to the generation at the Gilbert 230 kV substation. Therefore, there are no Attachment Facilities, Direct, and Non-Direct Connection facilities work to be completed outside of the scope of the AF1-195 project.

## 9 Transmission Owner Analysis

### 9.1 Power Flow Analysis

FE performed an analysis of its underlying transmission <100 kV system. The AF1-195 project did not contribute to any overloads on the FE transmission <100 kV system.

## 10 Interconnection Customer Requirements

### System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

### Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

### Power Factor Requirements

The existing 152 MW portion of the Customer Facility shall retain its existing ability to maintain a power factor as specified in the ISA. The increase of 1 MW to the Customer Facilities associated with the AF1-195 project shall be designed with the ability to maintain a Power Factor of at least 1.0 (unity) to 0.90 lagging (supplying VARs) measured at the generator's terminal.

## 11 Revenue Metering and SCADA Requirements

### 11.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

### 11.2 JCPL Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

## 12 Network Impacts

The Queue Project AF1-195 was evaluated as a 1.0 MW (Capacity 1.0 MW) injection as an uprate to existing Gilbert CT; Unit: 9 at the Gilbert CT 18.0 kV substation in the JCPL area. Project AF1-195 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF1-195 was studied with a commercial probability of 1.00. Potential network impacts were as follows:

# Summer Peak Load Flow

### **12.1 Generation Deliverability**

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

### **12.2 Multiple Facility Contingency**

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

### **12.3 Contribution to Previously Identified Overloads**

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

### **12.4 Potential Congestion due to Local Energy Deliverability**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

# Short Circuit

### 13 Short Circuit

The following Breakers are overdutied:

None.

# Affected Systems

## **14 Affected Systems**

### **14.1 LG&E**

LG&E Impacts to be determined during later study phases (as applicable).

### **14.2 MISO**

MISO Impacts to be determined during later study phases (as applicable).

### **14.3 TVA**

TVA Impacts to be determined during later study phases (as applicable).

### **14.4 Duke Energy Progress**

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

### **14.5 NYISO**

NYISO Impacts to be determined during later study phases (as applicable).

# 15 Attachment 1 – One Line

