



Generation Interconnection

Feasibility Study Report

for

Queue Project AF1-250

MAYSVILLE 69 KV II

10.8 MW Capacity / 18 MW Energy

January 2020

Table of Contents

| | | |
|-------|--|----|
| 1 | Introduction..... | 4 |
| 2 | Preface..... | 4 |
| 3 | General..... | 6 |
| 3.1 | Point of Interconnection | 7 |
| 3.2 | Cost Summary..... | 7 |
| 4 | Transmission Owner Scope of Work..... | 9 |
| 4.1 | Attachment Facilities..... | 9 |
| 4.2 | Direct Connection Cost Estimate..... | 9 |
| 4.3 | Non-Direct Connection Cost Estimate..... | 9 |
| 5 | Schedule..... | 10 |
| 6 | Transmission Owner Analysis..... | 11 |
| 7 | Interconnection Customer Requirements..... | 12 |
| 7.1 | System Protection..... | 12 |
| 7.2 | Compliance Issues and Interconnection..... | 12 |
| 7.3 | Power Factor Requirements..... | 13 |
| 8 | Revenue Metering and SCADA Requirements..... | 14 |
| 8.1 | PJM Requirements..... | 14 |
| 8.1.1 | Meteorological Data Reporting Requirement..... | 14 |
| 8.2 | ATSI Requirements..... | 14 |
| 9 | Network Impacts..... | 15 |
| 10 | Generation Deliverability..... | 17 |
| 11 | Multiple Facility Contingency..... | 17 |
| 12 | Contribution to Previously Identified Overloads..... | 17 |
| 13 | Potential Congestion due to Local Energy Deliverability..... | 17 |
| 14 | System Reinforcements..... | 18 |
| 15 | Affected Systems..... | 20 |
| 15.1 | LG&E..... | 20 |
| 15.2 | MISO..... | 20 |
| 15.3 | TVA..... | 20 |
| 15.4 | Duke Energy Progress..... | 20 |
| 15.5 | NYISO..... | 20 |

16 Short Circuit.....22

17 Attachment One: One Line Diagram.....23

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is American Transmission Systems Inc. (ATSI – Penn Power zone).

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model.

The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC) has proposed an update to a planned solar generating facility located in Mercer County, Pennsylvania. This project is an increase to the Interconnection Customer's AE2-285 project, which will share the same property and point of interconnection. The AF1-250 queue position is a 18 MW update (10.8 MW Capacity update) to the previous project. The total installed facilities will have a capability of 68 MW with 40.8 MW of this output being recognized by PJM as Capacity (see table below for clarity). The proposed in-service date for this update project is June 30, 2022. This study does not imply a TO commitment to this in-service date.

| Queue | Maximum Facility Output (MFO) (MW) | Energy (MW) | Capacity (MW) |
|--------------|------------------------------------|-------------|---------------|
| AE2-285 | 50 | 50 | 30 |
| AF1-250 | 18 | 18 | 10.8 |
| Total | 68 | 68 | 40.8 |

| Queue Number | AF1-250 |
|---------------------|--------------------|
| Project Name | MAYSVILLE 69 KV II |
| State | Pennsylvania |
| County | Mercer |
| Transmission Owner | ATSI |
| MFO | 68 |
| MWE | 18 |
| MWC | 10.8 |
| Fuel | Solar |
| Basecase Study Year | 2023 |

3.1 Point of Interconnection

AF1-250 will interconnect with the ATSI transmission system as an uprate to AE2-285 at the Maysville 69 kV substation. For the AE2-285 project, the interconnection of the project at the Primary POI will be accomplished by extending the Maysville 69 kV bus, installing one (1) 69 kV circuit breaker, and extending a new line exit to the Primary POI. The IC will be responsible for acquiring all easements, properties, and permits that may be required to expand the Maysville substation and associated attachment facilities. There will be no additional interconnection facilities required to accommodate AF1-150 uprate.

Attachment 1 shows a one-line diagram of the proposed primary direct connection facilities for the AF1-250 generation project to connect to the FirstEnergy (“FE”) transmission system. IC will be responsible for constructing all of the facilities on its side of the POI, including the attachment facilities which connect the generator to the FE transmission system’s direct connection facilities.

3.2 Cost Summary

The AF1-250 project will be responsible for the following costs:

| Description | Total Cost |
|--|-----------------|
| Attachment Facilities | \$0 |
| Direct Connection Network Upgrade | \$10,000 |
| Non Direct Connection Network Upgrades | \$0 |
| Total Costs | \$10,000 |

In addition, the AF1-250 project may be responsible for a contribution to the following costs:

| Description | Total Cost |
|-----------------|------------|
| System Upgrades | \$0 |

The Feasibility Study is used to make a preliminary determination of the type and scope of Attachment Facilities, Local Upgrades, and Network Upgrades that will be necessary to accommodate the Interconnection Request and to provide the Interconnection Customer a preliminary estimate of the time that will be required to construct any necessary facilities and upgrades and the Interconnection Customer’s cost responsibility. The System Impact Study provides refined and comprehensive estimates of cost responsibility and construction lead times for new facilities and system upgrades. Facilities Studies will include, commensurate with the degree of engineering specificity as provided in the Facilities Study Agreement, good faith estimates of the cost, determined in accordance with Section 217 of the Tariff,

(a) to be charged to each affected New Service Customer for the Facilities and System Upgrades that are necessary to accommodate this queue project;

(b) the time required to complete detailed design and construction of the facilities and upgrades; and

(c) a description of any site-specific environmental issues or requirements that could reasonably be anticipated to affect the cost or time required to complete construction of such facilities and upgrades.

The costs provided above exclude the Contribution in Aid of Construction (“CIAC”) Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

The required Attachment Facilities and Direct and Non-Direct Connection work for the interconnection of the AF1-250 generation project to the FE Transmission System is detailed in the following sections. The associated one-line with the generation project is shown in Attachment 1.

4 Transmission Owner Scope of Work

The AF1-250 project is an uprate to the AE2-285 project. For the AE2-285 project, the interconnection of the project at the Primary POI will be accomplished by extending the Maysville 69 kV bus, installing one (1) 69 kV circuit breaker, and extending a new line exit to the Primary POI. The IC will be responsible for acquiring all easements, properties, and permits that may be required to expand the Maysville substation and associated attachment facilities. There will be no additional interconnection facilities required to accommodate AF1-150 uprate.

4.1 Attachment Facilities

There is no Attachment Facilities scope of work required for this uprate project.

4.2 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description | Total Cost |
|---|-----------------|
| Engineering Review | \$10,000 |
| Total Direct Connection Facility Costs | \$10,000 |

4.3 Non-Direct Connection Cost Estimate

There is no Non-Direct Connection scope of work required for this uprate project.

5 Schedule

Based on the scope of work it is expected to take a minimum of **1 month** after the signing of an Interconnection Service Agreement to accommodate this uprate project (engineering review work can possibly be done concurrently with the AE2-285 project depending on timing of issuance of the agreement for each project). This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined interconnection work, and that all transmission system outages will be allowed when requested.

6 Transmission Owner Analysis

FE performed an analysis of its underlying transmission <100 kV system. The AF1-250 project did not contribute to any overloads on the FE transmission system.

7 Interconnection Customer Requirements

7.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

7.2 Compliance Issues and Interconnection

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 69 kV circuit breaker to protect the AE2-285 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AE2-285 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

7.3 Power Factor Requirements

For the existing proposed AE2-285 solar Customer Facility 50 MW portion of the Customer Facility shall retain the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system. The increase of 18 MWs to the solar Customer Facility associated with AF1-250 project shall be designed with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs).

8 Revenue Metering and SCADA Requirements

8.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

8.1.1 Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

8.2 ATSI Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

9 Network Impacts

The Queue Project AF1-250 was evaluated as a 18.0 MW (Capacity 10.8 MW) injection as an uprate to AE2-285 at the Maysville 69 kV substation in the ATSI area. Project AF1-250 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF1-250 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

10 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

11 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

12 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

13 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

14 System Reinforcements

None

Affected Systems

15 Affected Systems

15.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

15.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

15.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

15.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

15.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

Short Circuit

16 Short Circuit

The following Breakers are overduty:

None

17 Attachment One: One Line Diagram