



**Generation Interconnection  
Feasibility Study Report  
for  
Queue Project AF1-315  
CEDARVILLE-FORD 138 KV  
36 MW Capacity / 60 MW Energy**

January, 2020

# Table of Contents

|      |  |    |
|------|--|----|
| 1    | Preface.....   | 3  |
| 2    | General.....   | 4  |
| 2.1  | Point of Interconnection .....                               | 5  |
| 2.2  | Cost Summary.....  | 5  |
| 3    | Transmission Owner Scope of Work.....                        | 6  |
| 4    | Attachment Facilities .....                                  | 6  |
| 5    | Direct Connection Cost Estimate.....                         | 6  |
| 6    | Non-Direct Connection Cost Estimate.....                     | 7  |
| 7    | Schedule.....  | 8  |
| 8    | Transmission Owner Analysis.....                             | 8  |
| 9    | Interconnection Customer Requirements.....                   | 8  |
| 10   | Revenue Metering and SCADA Requirements .....                | 9  |
| 10.1 | PJM Requirements.....  | 9  |
| 10.2 | DEOK Requirements.....                                       | 9  |
| 11   | Network Impacts.....   | 10 |
| 12   | Generation Deliverability .....                              | 12 |
| 13   | Multiple Facility Contingency .....                          | 12 |
| 14   | Contribution to Previously Identified Overloads .....        | 12 |
| 15   | Potential Congestion due to Local Energy Deliverability..... | 13 |
| 16   | System Reinforcements.....                                   | 14 |
| 17   | Flow Gate Details .....                                      | 15 |
| 17.1 | Index 1 .....  | 16 |
| 17.2 | Index 2 .....  | 19 |
| 18   | Affected Systems .....                                       | 21 |
| 18.1 | LG&E.....  | 21 |
| 18.2 | MISO .....   | 21 |
| 18.3 | TVA.....   | 21 |
| 18.4 | Duke Energy Progress.....                                    | 21 |
| 18.5 | NYISO .....  | 21 |
| 19   | Short Circuit.....   | 23 |

## 1 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

## 2 General

Project AF1-315 is a request that proposes a 60 MW solar generator to be built near State Road OH-276, Clermont County, Ohio; please refer to the facilities location map in Appendix 1(Please note this POI location is not official). The proposed in-service date for this project is December 31, 2023. **This study does not imply a Duke Energy commitment to this in-service date.**

|                            |                        |
|----------------------------|------------------------|
| <b>Queue Number</b>        | <b>AF1-315</b>         |
| <b>Project Name</b>        | CEDARVILLE-FORD 138 KV |
| <b>State</b>               | Ohio                   |
| <b>County</b>              | Clermont               |
| <b>Transmission Owner</b>  | DEOK                   |
| <b>MFO</b>                 | 60                     |
| <b>MWE</b>                 | 60                     |
| <b>MWC</b>                 | 36                     |
| <b>Fuel</b>                | Solar                  |
| <b>Basecase Study Year</b> | 2023                   |

## 2.1 Point of Interconnection

AF1-315 will interconnect with the Duke Energy transmission system by direct injection into a new 138 kV substation bus located on the feeder between the Ford and the AE2-318/AF1-045 substations. The new substation will have a three-breaker ring bus configuration. The Point of Interconnection is located where Duke Energy's overhead line from the new substation terminates to the Interconnection Customer's pole mounted switches, approximately 25 feet outside the new substation fence; please refer to the single-line diagram in Appendix 2.

## 2.2 Cost Summary

The AF1-315 project will be responsible for the following costs:

Duke Energy facilities and network upgrades costs required to support the AF1-315 project are listed below. Please note this is a class 5 estimate, with a band range of (-50% to +100 %). It is also assumed there will be no issues obtaining Transmission Line easement for station power.

| Description                            | Total Cost         |
|--|--------------------|
| Attachment Facilities                  | \$ 425,411         |
| Direct Connection Network Upgrade      | \$7,475,413        |
| Non Direct Connection Network Upgrades | \$1,152,888        |
| <b>Total Costs</b>                     | <b>\$9,053,712</b> |

NOTE: CIAC Tax Gross Up charges will be charged to the project if it does not meet the eligibility requirements of IRS Notice 88-129.

In addition, the AF1-315 project may be responsible for a contribution to the following costs

| Description     | Total Cost   |
|-----------------|--------------|
| System Upgrades | \$14,540,000 |

Cost allocations for these upgrades will be provided in the System Impact Study Report.

### 3 Transmission Owner Scope of Work

#### 4 Attachment Facilities

Duke Energy will install a revenue metering package, equipment for protection and relaying, a take-off structure, a set of disconnect switches, and overhead conductors from the new substation to the Interconnect Customer's pole mounted switches.

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description                            | Total Cost       |
|--|------------------|
|  | \$425,411        |
| <b>Total Attachment Facility Costs</b> | <b>\$425,411</b> |

#### 5 Direct Connection Cost Estimate

Duke Energy will build a new 138 kV substation on Interconnect Customer supplied land. The substation will include, but is not limited to, a three breaker ring bus configuration, three 145 kV breakers, eight sets of disconnect switches, associated buswork, relaying, metering, control building, take-off structures, lighting, fencing, gravel, and foundations as necessary to form a complete substation installation.

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description                                   | Total Cost         |
|---|--------------------|
|   | \$7,475,413        |
| <b>Total Direct Connection Facility Costs</b> | <b>\$7,475,413</b> |

## 6 Non-Direct Connection Cost Estimate

Duke Energy will reconfigure the Ford to the AE2-318/AF1-045 POI 138 kV feeder to loop through the new substation and perform any work needed at the other substations on the terminal ends of the line.

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description                                       | Total Cost         |
|---|--------------------|
|   | \$1,152,888        |
| <b>Total Non-Direct Connection Facility Costs</b> | <b>\$1,152,888</b> |

## 7 Schedule

The estimated time to complete this work is approximately 29 months from a signed ISA and CSA. This assumes no issues getting right of way, a PJM outage on the line or adjacent line on tower, and no major interruptions for weather.

## 8 Transmission Owner Analysis

A Summer Peak 2023 load flow study was performed evaluating AF1-315 for compliance with applicable reliability planning criteria (NERC, NERC Regional Reliability Council, and Transmission Owner). For the load flow case, PJM queue project AE2-318 was modeled on the 138 kV line between Ford and Cedarville. Also, AF1-045 was modeled on this line. Due to this, AF1-315 was studied as a 60 MW injection onto the 138 kV line between Ford and the AE2-318/AF1-045 POI. Previous queued generation and other AF1 queued generation within the DEOK footprint only were modeled as well. An impact was found on the system caused by the combination of this generation interconnection and AF1-045. The impact was that the line from the AE2-318/AF1-045 POI to Cedarville becomes overloaded for contingencies elsewhere on the DEOK system. The scope and cost estimate are given below in the Network Upgrades section.

## 9 Interconnection Customer Requirements

Interconnection Customer will be required to procure and provide land for the new substation. The land will be ceded to Duke Energy prior to construction of the new substation. The land must be near the Ford - Cedarville 138 kV feeder path and have direct access to publicly maintained roadway. The land shall be environmentally permitted, graded and ready for construction. Final size and location is to be approved by Duke Energy.

Interconnection Customer will be required to engineer, procure, and construct the connecting circuit from the Interconnection Customer's substation to the Point of Interconnection (POI). This includes, but is not limited to, a pole and disconnect switches to be installed approximately 25 feet outside the new substation fence at the POI.

Interconnection Customer will be responsible for meeting all criteria as specified in the applicable sections of the "Duke Energy Midwest transmission systems Facility Connection Requirements" document, Version 7, effective October 31, 2018, which can be found under this link:

<http://www.pjm.com/~media/planning/plan-standards/deok/deok-facility-connection-requirements.ashx>.

## **10 Revenue Metering and SCADA Requirements**

### **10.1 PJM Requirements**

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

### **10.2 DEOK Requirements**

The Interconnection Customer will be required to comply with all Duke Energy revenue metering requirements for generation interconnection customers. The revenue metering requirements may be found within the "Duke Energy Midwest transmission systems Facility Connection Requirements" document, Version 7, effective October 31, 2018.

## 11 Network Impacts

The Queue Project AF1-315 was evaluated as a 60.0 MW (Capacity 36.0 MW) injection tapping the Cedarville to Ford 138 kV line in the DEOK area. Project AF1-315 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF1-315 was studied with a commercial probability of 0.53. Potential network impacts were as follows:

# Summer Peak Load Flow

## 12 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

## 13 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

| ID           | FROM BUS#  | FROM BUS           | kV        | FRO M BUS AREA | TO BUS#    | TO BUS       | kV        | TO BUS AREA | CK T ID | CONT NAME                      | Type        | Ratin g MVA | PRE PROJEC T LOADIN G % | POST PROJEC T LOADIN G % | AC D C | MW IMPAC T |
|--------------|------------|--------------------|-----------|----------------|------------|--------------|-----------|-------------|---------|--------------------------------|-------------|-------------|-------------------------|--------------------------|--------|------------|
| 436270<br>12 | 24402<br>2 | 05COL<br>E         | 345.<br>0 | AEP            | 24345<br>7 | 05HAYD<br>EN | 345.<br>0 | AEP         | 1       | AEP_P4_#8094_05BI<br>XBY 345_C | break<br>er | 1429.<br>0  | 99.83                   | 100.0                    | DC     | 5.2        |
| 417196<br>93 | 94320<br>0 | AE2-<br>318<br>TAP | 138.<br>0 | DEO&<br>K      | 24999<br>3 | 08CDRVL<br>2 | 138.<br>0 | DEO&<br>K   | 1       | DEOK_P2-3_C2<br>1425_HILLCREST | break<br>er | 298.0       | 98.35                   | 111.91                   | DC     | 40.42      |
| 417196<br>94 | 94320<br>0 | AE2-<br>318<br>TAP | 138.<br>0 | DEO&<br>K      | 24999<br>3 | 08CDRVL<br>2 | 138.<br>0 | DEO&<br>K   | 1       | DEOK_P2-3_C2<br>1423_HILLCREST | break<br>er | 298.0       | 98.35                   | 111.91                   | DC     | 40.42      |
| 417196<br>95 | 94320<br>0 | AE2-<br>318<br>TAP | 138.<br>0 | DEO&<br>K      | 24999<br>3 | 08CDRVL<br>2 | 138.<br>0 | DEO&<br>K   | 1       | DEOK_P2-3_C2<br>1427_HILLCREST | break<br>er | 298.0       | 98.21                   | 111.78                   | DC     | 40.42      |

## 14 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

## 15 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

| ID           | FROM BUS#  | FROM BUS           | kV        | FROM BUS AREA | TO BUS#    | TO BUS       | kV        | TO BUS AREA | CK T ID | CONT NAME  | Type          | Rating MVA | PRE PROJECT LOADIN G % | POST PROJECT LOADIN G % | AC D C | MW IMPAC T |
|--------------|------------|--------------------|-----------|---------------|------------|--------------|-----------|-------------|---------|--|---------------|------------|------------------------|-------------------------|--------|------------|
| 4141553<br>2 | 94320<br>0 | AE2-<br>318<br>TAP | 138.<br>0 | DEO&<br>K     | 24999<br>3 | 08CDRVL<br>2 | 138.<br>0 | DEO&<br>K   | 1       | DEOK_P1<br>-3_B3<br>HILLCRES<br>T<br>345/138<br>TB21 | operatio<br>n | 298.0      | 96.03                  | 109.6                   | DC     | 40.43      |

## 16 System Reinforcements

| ID                             | Index | Facility  | Upgrade Description   | Cost         |
|--------------------------------|-------|---|---|--------------|
| 43627012                       | 1     | 05COLE 345.0 kV -<br>05HAYDEN 345.0 kV Ckt 1      | <p><u>AEP</u><br/>           AEPO0041a : A Sag Study will be required on the 7.7 miles of bundled ACSR ~ 954 ~ 45/7 ~ RAIL- Conductor section 1 to mitigate the overload. Depending on the sag study results, the cost for this upgrade is expected to be between \$40,000 (no remediations required, just sag study) and \$11.55 million (complete line reconductor/rebuild). New rating after sag study: S/N: 1409 S/E: 1887. Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement.</p> <p>Project Type : FAC<br/>           Cost : \$40,000<br/>           Time Estimate : 6-12 Months</p> | \$40,000     |
| 41719693,41719695,<br>41719694 | 2     | AE2-318 TAP 138.0 kV -<br>08CDRVL2 138.0 kV Ckt 1 | <p><u>DEOK</u><br/>           n2986 (2783) : Rebuild the line, Replace equipment at Cedarville</p> <p>Project Type : FAC<br/>           Cost : \$14,500,000<br/>           Time Estimate : 30.0 Months</p>  | \$12,722,939 |
|                                |       |   | TOTAL COST  | \$12,722,979 |

## 17 Flow Gate Details

The following indices contain additional information about each flowgate presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

---

## 17.1 Index 1

| ID       | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS    | TO BUS AREA | CKT ID | CONT NAME                  | Type    | Rating MVA | PRE PROJECT LOADIN G % | POST PROJECT LOADIN G % | AC D C | MW IMPACT |
|----------|-----------|----------|---------------|---------|-----------|-------------|--------|----------------------------|---------|------------|------------------------|-------------------------|--------|-----------|
| 43627012 | 244022    | 05COL E  | AEP           | 24345 7 | 05HAYDE N | AEP         | 1      | AEP_P4_#8094_05BIXB Y345_C | breaker | 1429.0     | 99.83                  | 100.0                   | DC     | 5.2       |

| Bus #  | Bus                                   | MW Impact |
|--------|---------------------------------------|-----------|
| 251827 | WILLYESP                              | 0.3438    |
| 251828 | CLNTESP1                              | 0.3672    |
| 251829 | CLNTESP2                              | 0.2448    |
| 253077 | 09STUART (Deactivation : 09/30/17)    | 151.9788  |
| 253110 | 09ADKINS                              | 21.6442   |
| 902531 | W2-040 C (Withdrawn : 01/23/2020)     | 0.6370    |
| 902532 | W2-040 E (Withdrawn : 01/23/2020)     | 1.0392    |
| 904722 | V4-073 E                              | 0.1407    |
| 913222 | Y1-054 E                              | 1.1296    |
| 918802 | AA1-099 E                             | 0.2448    |
| 923522 | AB1-169 C OP                          | 97.7355   |
| 925921 | AC1-068 C                             | 9.0185    |
| 925922 | AC1-068 E                             | 4.2175    |
| 925931 | AC1-069 C                             | 9.0185    |
| 925932 | AC1-069 E                             | 4.2175    |
| 926011 | AC1-078 C O1                          | 5.5017    |
| 926012 | AC1-078 E O1                          | 9.1695    |
| 926061 | AC1-085 C                             | 17.6046   |
| 926062 | AC1-085 E                             | 28.7234   |
| 926101 | AC1-089 C O1                          | 3.3721    |
| 926102 | AC1-089 E O1                          | 5.5019    |
| 926791 | AC1-165 C                             | 8.9124    |
| 926792 | AC1-165 E                             | 4.3236    |
| 926801 | AC1-166 C                             | 8.9124    |
| 926802 | AC1-166 E                             | 4.3236    |
| 926951 | AC1-182                               | 1.3350    |
| 930062 | AB1-014 E                             | 6.0038    |
| 932201 | AC2-029 C                             | 1.5189    |
| 932202 | AC2-029 E                             | 2.4783    |
| 932381 | AC2-055 C                             | 1.9694    |
| 932382 | AC2-055 E                             | 3.2133    |
| 932421 | AC2-060 C                             | 6.9830    |
| 932422 | AC2-060 E                             | 3.9280    |
| 932431 | AC2-061 C                             | 3.4372    |
| 932432 | AC2-061 E                             | 3.4845    |
| 932461 | AC2-066 C                             | 2.2079    |
| 932462 | AC2-066 E                             | 3.6023    |
| 932481 | AC2-068 C                             | 2.1417    |
| 932482 | AC2-068 E                             | 3.5075    |
| 932651 | AC2-087 C O1 (Withdrawn : 01/15/2020) | 5.1718    |
| 932652 | AC2-087 E O1 (Withdrawn : 01/15/2020) | 4.1025    |
| 932661 | AC2-088 C O1                          | 3.0447    |

| Bus #  | Bus          | MW Impact |
|--------|--------------|-----------|
| 932662 | AC2-088 E O1 | 2.5055    |
| 934491 | AD1-073 C    | 1.4403    |
| 934492 | AD1-073 E    | 0.7419    |
| 934561 | AD1-081 C    | 1.1003    |
| 934562 | AD1-081 E    | 0.5668    |
| 935031 | AD1-136 C    | 0.4282    |
| 935032 | AD1-136 E    | 0.3647    |
| 935041 | AD1-140 C O1 | 7.5486    |
| 935042 | AD1-140 E O1 | 6.2406    |
| 936251 | AD2-031 C O1 | 2.1276    |
| 936252 | AD2-031 E O1 | 3.4714    |
| 938051 | AE1-007 C    | 0.6142    |
| 938052 | AE1-007 E    | 1.0021    |
| 938271 | AE1-040 C O1 | 4.0119    |
| 938272 | AE1-040 E O1 | 2.0187    |
| 938921 | AE1-120      | 3.4086    |
| 939141 | AE1-144 C O1 | 5.2641    |
| 939142 | AE1-144 E O1 | 2.6124    |
| 940531 | AE2-038 C O1 | 3.5116    |
| 940532 | AE2-038 E O1 | 1.7394    |
| 941411 | AE2-138 C    | 10.7123   |
| 941412 | AE2-138 E    | 3.9621    |
| 941511 | AE2-148 C    | 131.8281  |
| 941512 | AE2-148 E    | 59.6263   |
| 941981 | AE2-210 C O1 | 3.6912    |
| 941982 | AE2-210 E O1 | 1.3884    |
| 942021 | AE2-214 C    | 66.6492   |
| 942022 | AE2-214 E    | 44.4328   |
| 942061 | AE2-218 C    | 6.8737    |
| 942062 | AE2-218 E    | 4.6689    |
| 942091 | AE2-221 C    | 21.8322   |
| 942092 | AE2-221 E    | 14.5548   |
| 942521 | AE2-267 C O1 | 1.0468    |
| 942522 | AE2-267 E O1 | 0.6471    |
| 942951 | AE2-315      | 2.1333    |
| 942981 | AE2-320 C O1 | 17.7452   |
| 942982 | AE2-320 E O1 | 8.7798    |
| 943191 | AE2-319 C O1 | 17.7452   |
| 943192 | AE2-319 E O1 | 8.7798    |
| 943201 | AE2-318 C    | 4.9163    |
| 943202 | AE2-318 E    | 2.3996    |
| 943771 | AF1-045      | 2.0240    |
| 944521 | AF1-117 C    | 37.8168   |
| 944522 | AF1-117 E    | 11.6492   |
| 944941 | AF1-159      | 1.2318    |
| 945631 | AF1-228 C    | 32.6095   |
| 945632 | AF1-228 E    | 21.7397   |
| 945681 | AF1-233 C O1 | 5.2587    |
| 945682 | AF1-233 E O1 | 2.5979    |
| 945821 | AF1-247 C    | 1.0468    |
| 945822 | AF1-247 E    | 0.6471    |
| 945841 | AF1-249 C    | 0.4559    |

| <b>Bus #</b> | <b>Bus</b>   | <b>MW Impact</b> |
|--------------|--------------|------------------|
| 945842       | AF1-249 E    | 0.2145           |
| 945861       | AF1-251 C    | 3.9200           |
| 945862       | AF1-251 E    | 2.6133           |
| 945911       | AF1-256 C    | 1.6938           |
| 945912       | AF1-256 E    | 1.1292           |
| 946101       | AF1-275      | 27.7705          |
| 946171       | AF1-282 C    | 6.9492           |
| 946172       | AF1-282 E    | 4.6328           |
| 946181       | AF1-283 C    | 9.0340           |
| 946182       | AF1-283 E    | 6.0226           |
| 946511       | AF1-315 C O1 | 1.4067           |
| 946512       | AF1-315 E O1 | 0.9378           |
| LGEE         | LGEE         | 2.3607           |
| CPL          | CPL          | 0.2944           |
| WEC          | WEC          | 0.3604           |
| CBM-W2       | CBM-W2       | 16.2572          |
| NY           | NY           | 0.6531           |
| CBM-W1       | CBM-W1       | 9.4451           |
| TVA          | TVA          | 2.6054           |
| O-066        | O-066        | 7.7482           |
| CBM-S2       | CBM-S2       | 4.3523           |
| CBM-S1       | CBM-S1       | 19.4597          |
| G-007        | G-007        | 1.1929           |
| MEC          | MEC          | 2.3168           |

## 17.2 Index 2

| ID       | FROM BUS# | FROM BUS    | FROM BUS AREA | TO BUS# | TO BUS   | TO BUS AREA | CKT ID | CONT NAME                   | Type    | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|----------|-----------|-------------|---------------|---------|----------|-------------|--------|-----------------------------|---------|------------|-----------------------|------------------------|-------|-----------|
| 41719695 | 943200    | AE2-318 TAP | DEO&K         | 249993  | 08CDRVL2 | DEO&K       | 1      | DEOK_P2-3_C2 1427_HILLCREST | breaker | 298.0      | 98.21                 | 111.78                 | DC    | 40.42     |

| Bus #      | Bus          | MW Impact |
|------------|--------------|-----------|
| 250166     | HLCRST AB114 | 3.8724    |
| 251830     | BIOENGRY     | 0.2790    |
| 930062     | AB1-014 E    | 45.2639   |
| 932461     | AC2-066 C    | 16.6454   |
| 932462     | AC2-066 E    | 27.1583   |
| 932661     | AC2-088 C O1 | 15.9878   |
| 932662     | AC2-088 E O1 | 13.1567   |
| 935031     | AD1-136 C    | 2.2483    |
| 935032     | AD1-136 E    | 1.9152    |
| 938921     | AE1-120      | 25.6982   |
| 943201     | AE2-318 C    | 46.5998   |
| 943202     | AE2-318 E    | 22.7452   |
| 943771     | AF1-045      | 36.1981   |
| 946511     | AF1-315 C O1 | 24.2543   |
| 946512     | AF1-315 E O1 | 16.1695   |
| DUCKCREEK  | DUCKCREEK    | 0.1762    |
| NEWTON     | NEWTON       | 0.1816    |
| CPLE       | CPLE         | 0.0245    |
| FARMERCITY | FARMERCITY   | 0.0068    |
| G-007A     | G-007A       | 0.0887    |
| VFT        | VFT          | 0.2386    |
| PRAIRIE    | PRAIRIE      | 0.3255    |
| COFFEEN    | COFFEEN      | 0.0835    |
| CBM-S2     | CBM-S2       | 0.1965    |
| EDWARDS    | EDWARDS      | 0.0543    |
| TILTON     | TILTON       | 0.1235    |
| MADISON    | MADISON      | 2.4837    |
| GIBSON     | GIBSON       | 0.1141    |
| BLUEG      | BLUEG        | 0.3559    |
| TRIMBLE    | TRIMBLE      | 0.1213    |

# Affected Systems

## **18 Affected Systems**

### **18.1 LG&E**

LG&E Impacts to be determined during later study phases (as applicable).

### **18.2 MISO**

MISO Impacts to be determined during later study phases (as applicable).

### **18.3 TVA**

TVA Impacts to be determined during later study phases (as applicable).

### **18.4 Duke Energy Progress**

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

### **18.5 NYISO**

NYISO Impacts to be determined during later study phases (as applicable).

| Contingency Name                    | Contingency Definition   |
|-------------------------------------|--|
| DEOK_P2-3_C2 1425_HILLCREST         | CONTINGENCY 'DEOK_P2-3_C2 1425_HILLCREST'<br>OPEN BRANCH FROM BUS 249566 TO BUS 249578 CKT 1 / 249566 08FOSTER 345 249578<br>08HILCRT 345 1<br>OPEN BRANCH FROM BUS 249578 TO BUS 250136 CKT 1 / 249578 08HILCRT 345 250136<br>08HILCRT 138 1<br>END |
| AEP_P4_#8094_05BIXBY 345_C          | CONTINGENCY 'AEP_P4_#8094_05BIXBY 345_C'<br>OPEN BRANCH FROM BUS 243453 TO BUS 243454 CKT 1 / 243453 05BEATTY 345 243454<br>05BIXBY 345 1<br>OPEN BRANCH FROM BUS 941520 TO BUS 243454 CKT 1 / 941520 AE2-149 TAP 345 243454<br>05BIXBY 345 1<br>END |
| DEOK_P1-3_B3 HILLCREST 345/138 TB21 | CONTINGENCY 'DEOK_P1-3_B3 HILLCREST 345/138 TB21'<br>OPEN BRANCH FROM BUS 249578 TO BUS 250136 CKT 1 / 249578 08HILCRT 345 250136<br>08HILCRT 138 1<br>END   |
| DEOK_P2-3_C2 1423_HILLCREST         | CONTINGENCY 'DEOK_P2-3_C2 1423_HILLCREST'<br>OPEN BRANCH FROM BUS 249578 TO BUS 253077 CKT 1 / 249578 08HILCRT 345 253077<br>09STUART 345 1<br>OPEN BRANCH FROM BUS 249578 TO BUS 250136 CKT 1 / 249578 08HILCRT 345 250136<br>08HILCRT 138 1<br>END |
| DEOK_P2-3_C2 1427_HILLCREST         | CONTINGENCY 'DEOK_P2-3_C2 1427_HILLCREST'<br>OPEN BRANCH FROM BUS 249578 TO BUS 253077 CKT 1 / 249578 08HILCRT 345 253077<br>09STUART 345 1<br>OPEN BRANCH FROM BUS 249566 TO BUS 249578 CKT 1 / 249566 08FOSTER 345 249578<br>08HILCRT 345 1<br>END |

## 19 Short Circuit

No Breakers were identified as overdutied