



**Generation Interconnection
Feasibility Study Report
for
Queue Project AF1-321
HOOVERSVILLE 115 KV I
12 MW Capacity / 20 MW Energy**

January, 2020

Table of Contents

- 1 Introduction..... 4
- 2 Preface..... 4
- 3 General..... 5
 - 3.1 Primary Point of Interconnection 5
 - 3.2 Secondary Point of Interconnection..... 5
- 2.2 Cost Summary..... 6
- 4 Transmission Owner Scope of Work..... 6
- 5 Attachment Facilities 6
- 6 Direct Connection Cost Estimate..... 7
- 7 Non-Direct Connection Cost Estimate..... 7
- 8 Schedule..... 7
- 9 Transmission Owner Analysis..... 7
 - 9.1 Power Flow Analysis 7
- 10 Interconnection Customer Requirements..... 8
 - 10.1 System Protection..... 8
 - 10.2 Compliance Issues and Interconnection Customer Requirements 8
 - 10.3 Power Factor Requirements..... 9
- 11 Revenue Metering and SCADA Requirements 9
 - 11.1 PJM Requirements 9
 - 11.1.1 Meteorological Data Reporting Requirement..... 9
 - 11.2 FE Requirements..... 9
- 12 Network Impacts – Primary Point of Interconnection..... 9
 - 12.1 Generation Deliverability 11
 - 12.2 Multiple Facility Contingency 11
 - 12.3 Contribution to Previously Identified Overloads..... 11
 - 12.4 Potential Congestion due to Local Energy Deliverability..... 11
 - 12.5 System Reinforcements..... 12
 - 12.6 Flow Gate Details..... 14
 - 12.6.1 Contingency Descriptions 14
 - 12.6.2 Index 1 15
 - 12.6.3 Index 2 17

| | | |
|--------|--|----|
| 12.7 | Short Circuit | 20 |
| 13 | Network Impacts – Secondary Point of Interconnection | 21 |
| 13.1 | Generation Deliverability | 23 |
| 13.2 | Multiple Facility Contingency | 23 |
| 13.3 | Contribution to Previously Identified Overloads..... | 23 |
| 13.4 | Potential Congestion due to Local Energy Deliverability..... | 23 |
| 13.5 | Flow Gate Details..... | 24 |
| 13.5.1 | Contingency Descriptions | 24 |
| 13.6 | Short Circuit | 26 |
| 14 | Affected Systems | 28 |
| 14.1 | LG&E..... | 28 |
| 14.2 | MISO | 28 |
| 14.3 | TVA..... | 28 |
| 14.4 | Duke Energy Progress..... | 28 |
| 14.5 | NYISO | 28 |
| | Attachment 1 | 29 |

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Mid-Atlantic Interstate Transmission (MAIT- Penelec zone).

2 Preface

The intent of the Feasibility Study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See

Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in Somerset County, Pennsylvania. The installed facilities will have a total capability of 20 MW with 12 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is 03/01/2022. This study does not imply a TO commitment to this in-service date.

| | |
|----------------------------|-----------------------|
| Queue Number | AF1-321 |
| Project Name | HOOVERSVILLE 115 KV I |
| State | Pennsylvania |
| County | Somerset |
| Transmission Owner | PENELEC |
| MFO | 20 |
| MWE | 20 |
| MWC | 12 |
| Fuel | Solar |
| Basecase Study Year | 2023 |

3.1 Primary Point of Interconnection

The interconnection of the project at the primary Point of Interconnection (POI) will be accomplished by constructing a new 115 kV breaker position in the existing Hooversville 115 kV substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection and the associated facilities. The IC will also be responsible for the rough grade of the property and any access needed to the proposed breaker terminal. The project is not planned to require non-direct connection upgrades at any remote substations.

3.2 Secondary Point of Interconnection

The interconnection of the project at a secondary POI can be accomplished by constructing a new 230 kV breaker position in the existing substation at Quemahonning 230 kV station. A full scope of work or estimated cost is not provided for the proposed Secondary POI.

2.2 Cost Summary

The AF1-321 project will be responsible for the following costs:

| Description | Total Cost |
|--|---------------------|
| Attachment Facilities | \$ 0 |
| Direct Connection Network Upgrade | \$ 0 |
| Non Direct Connection Network Upgrades | \$ 1,615,000 |
| Total Costs | \$ 1,615,000 |

In addition, the AF1-321 project may be responsible for a contribution to the following costs

| Description | Total Cost |
|-----------------|------------|
| System Upgrades | \$ 0 |

Cost allocations for these upgrades will be provided in the System Impact Study Report.

The costs provided above exclude the Contribution in Aid of Construction (“CIAC”) Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

The required Attachment Facilities and Direct and Non-Direct Connection work for the interconnection of the AF1-321 generation project to the FE Transmission System is detailed in the following sections. The associated one-line with the generation project Attachment Facilities and the Primary Direct and Non-Direct Connection facilities are shown in Attachment 1.

4 Transmission Owner Scope of Work

The interconnection of the project at the Primary POI will be accomplished by constructing a new 115 kV breaker position in the existing Hooversville 115 kV substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection and the associated facilities. The IC will also be responsible for the rough grade of the property and any access needed to the proposed breaker terminal. The project is not planned to require non-direct connection upgrades at any remote substations.

5 Attachment Facilities

There was no Attachment Facilities scope of work identified in this study.

6 Direct Connection Cost Estimate

There is no Direct Connection scope of work required.

7 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description | Total Cost |
|---|---------------------|
| Install a breaker at Hooversville | \$ 1,550,400 |
| Nameplates and Drawing Review | \$ 64,600 |
| Total Non-Direct Connection Facility Costs | \$ 1,615,000 |

8 Schedule

Based on the scope of work for the Attachment Facilities and the Direct and/or Non-Direct Connection facilities, it is expected to take a minimum of 18 months after the signing of an Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the IC to make a preliminary payment that compensates FE for the first three months of the engineering design work that is related to the construction of the interconnection substation. This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection and network upgrades, and that all transmission system outages will be allowed when requested.

The schedule for the required Network Impact Reinforcements will be more clearly identified in future study phases. The estimate elapsed time to complete each of the required reinforcements is identified in the "System Reinforcements" section of the report.

9 Transmission Owner Analysis

9.1 Power Flow Analysis

FE performed an analysis of its underlying transmission < 100 kV system. The AF1-321 project did not contribute to any overloads on the FE transmission < 100 kV system.

10 Interconnection Customer Requirements

10.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

The IC has requested a non-standard GSU transformer winding configuration. This transformer is in violation of section 14.2.6 of FE's "Requirements for Transmission Connected Facilities" document and will not be accepted. The GSU transformer must have a grounded wye connection on the high (utility) side and a delta connection on the low (generator) side.

10.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 115 kV circuit breaker to protect the AF1-321 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AF1-321 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits.

Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

10.3 Power Factor Requirements

The IC shall design its Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system.

11 Revenue Metering and SCADA Requirements

11.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

11.1.1 Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

11.2 FE Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

12 Network Impacts – Primary Point of Interconnection

The Queue Project AF1-321 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection at the Hooversville 115 kV substation in the PENELEC area. Project AF1-321 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF1-321 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

12.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

12.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

| ID | FROM BUS# | FROM BUS | kV | FROM BUS AREA | TO BUS# | TO BUS | kV | TO BUS AREA | CK T ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADIN G % | POST PROJECT LOADIN G % | AC D C | MW IMPACT |
|----------|-----------|-------------|-------|---------------|---------|-----------|-------|-------------|---------|--------------------|-------|------------|------------------------|-------------------------|--------|-----------|
| 41080612 | 200743 | 26HOOVERS V | 115.0 | PENELEC | 200734 | 26SCAL PL | 115.0 | PENELEC | 1 | PN-P7-1-PN-230-001 | tower | 190.0 | 95.27 | 100.59 | DC | 10.1 |

12.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

| ID | FROM BUS# | FROM BUS | kV | FROM BUS AREA | TO BUS# | TO BUS | kV | TO BUS AREA | CK T ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADIN G % | POST PROJECT LOADIN G % | AC D C | MW IMPACT |
|----------|-----------|------------|-------|---------------|---------|-------------|-------|-------------|---------|--------------------|-------|------------|------------------------|-------------------------|--------|-----------|
| 41080443 | 200746 | 26ROCKWOOD | 115.0 | PENELEC | 202650 | 26HIGHPOINT | 115.0 | PENELEC | 1 | PN-P7-1-PN-230-001 | tower | 179.0 | 134.56 | 136.9 | DC | 4.19 |

12.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

| ID | FROM BUS# | FROM BUS | kV | FROM BUS AREA | TO BUS# | TO BUS | kV | TO BUS AREA | CK T ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADIN G % | POST PROJECT LOADIN G % | AC D C | MW IMPACT |
|----------|-----------|------------|-------|---------------|---------|----------|-------|-------------|---------|--------------------|-----------|------------|------------------------|-------------------------|--------|-----------|
| 41422173 | 200742 | 26TOWER 51 | 115.0 | PENELEC | 200741 | 26SEWARD | 115.0 | PENELEC | 1 | AP-P1-3-PN-115-010 | operation | 185.0 | 117.57 | 121.46 | DC | 7.19 |

| ID | FROM BUS# | FROM BUS | kV | FROM BUS AREA | TO BUS# | TO BUS | kV | TO BUS AREA | CK T ID | CON T NAME | Type | Ratin g MVA | PRE PROJEC T LOADIN G % | POST PROJEC T LOADIN G % | AC D C | MW IMPAC T |
|----------|-----------|--------------|-------|---------------|---------|--------------|-------|-------------|---------|--------------------|------------|-------------|-------------------------|--------------------------|--------|------------|
| 41421883 | 200743 | 26HOOVERS V | 115.0 | PENELE C | 200742 | 26TOWER 51 | 115.0 | PENELE C | 1 | AP-P1-3-PN-115-010 | operatio n | 172.0 | 139.78 | 144.02 | DC | 7.29 |
| 41421888 | 200743 | 26HOOVERS V | 115.0 | PENELE C | 200742 | 26TOWER 51 | 115.0 | PENELE C | 1 | Base Case | operatio n | 137.0 | 112.19 | 117.01 | DC | 6.61 |
| 41422004 | 200746 | 26ROCKWOD | 115.0 | PENELE C | 202650 | 26HIGHPOI NT | 115.0 | PENELE C | 1 | Base Case | operatio n | 148.0 | 138.13 | 138.73 | DC | 1.98 |
| 41421716 | 200747 | 26PENN-MAR | 115.0 | PENELE C | 946190 | AF1-284 TAP | 115.0 | PENELE C | 1 | Base Case | operatio n | 137.0 | 164.87 | 165.52 | DC | 1.98 |
| 41421599 | 200762 | 26GARRETT | 115.0 | PENELE C | 235470 | 01GARRET | 115.0 | AP | 1 | Base Case | operatio n | 133.0 | 187.4 | 188.07 | DC | 1.98 |
| 41421767 | 202650 | 26HIGHPOIN T | 115.0 | PENELE C | 200747 | 26PENN-MAR | 115.0 | PENELE C | 1 | Base Case | operatio n | 137.0 | 160.84 | 161.5 | DC | 1.98 |
| 41421667 | 946190 | AF1-284 TAP | 115.0 | PENELE C | 200762 | 26GARRETT | 115.0 | PENELE C | 1 | Base Case | operatio n | 137.0 | 173.43 | 174.08 | DC | 1.98 |

12.5 System Reinforcements

| ID | Index | Facility | Upgrade Description | Cost |
|----------|-------|--|---|------|
| 41080443 | 2 | 26ROCKWOOD 115.0 kV - 26HIGHPOINT 115.0 kV Ckt 1 | <p>PENELEC</p> <p>s1770.1: Supplemental upgrade s1770.1: Penn Mar – High Point – Rockwood 115 kV Line, Rebuild/reconductor approximately 14.8 miles of wood pole construction. The supplemental project has a projected in-service date of 06/01/2020. Project Type: CON Cost : \$0</p> <p>s1770.2: Supplemental upgrade s1770.2: Rockwood 115 kV Substation - Adjust CT ratios and replace substation conductor and breaker disconnect (on Penn Mar – High Point – Rockwood 115 kV Line). The supplemental project has a projected in-service date of 06/01/2020. Project Type: CON Cost : \$0</p> <p>s1770.3: Supplemental upgrade s1770.3: Penn Mar 115 kV Substation - Adjust relaying and replace CTs, substation conductor, line drops, circuit breaker and disconnect switches (on Penn Mar – High Point – Rockwood 115 kV Line). The supplemental project has a projected in-service date of 06/01/2020. Project Type: CON Cost : \$0</p> | \$0 |

| ID | Index | Facility | Upgrade Description | Cost |
|----------|-------|--|---|------------|
| 41080612 | 1 | 26HOOVERSV 115.0 kV - 26SCALP L. 115.0 kV Ckt 1 | <p>PENELEC s2046: Supplemental upgrade s2046: Replace terminal equipment on the Hooversville – Scalp Level – Rachel Hill 115 kV Line.</p> <ul style="list-style-type: none"> • Hooversville 115 kV Substation – Replace line relaying and line trap on the Hooversville – Scalp Level I 115 kV Line. (s2046.1) • Scalp Level 115 kV Substation – Replace substation conductor on the Hooversville – Scalp Level – Rachel Hill 115 kV Line. (s2046.2) • Rachel Hill 115 kV Substation – Replace line relaying, line trap, and substation conductor on the Scalp Level – Rachel Hill 115 kV Line. (s2046.3) <p>The supplemental project has a projected in-service date of 12/01/2020. Project Type: FAC Cost : \$0</p> | \$0 |
| | | | TOTAL COST | \$0 |

12.6 Flow Gate Details

The following indices contain additional information about each flowgate presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

12.6.1 Contingency Descriptions

| Contingency Name | Contingency Definition |
|--------------------|---|
| Base Case | |
| PN-P7-1-PN-230-001 | CONTINGENCY 'PN-P7-1-PN-230-001' /* HOMER CITY - HOOVERSVILLE 230KV & SEWARD - TOWER 51 115KV DISCONNECT BRANCH FROM BUS 200767 TO BUS 200768 CKT 1 /* 26HOMER CT 230 26QUEMAHON 230 DISCONNECT BRANCH FROM BUS 200768 TO BUS 200796 CKT 1 /* 26QUEMAHON 230 26HOOVRSVL 230 DISCONNECT BRANCH FROM BUS 200796 TO BUS 200743 CKT 3 /* 26HOOVRSVL 230 26HOOVERSV 115 DISCONNECT BRANCH FROM BUS 200741 TO BUS 200742 CKT 1 /* 26SEWARD 115 26TOWER 51 115 END |
| AP-P1-3-PN-115-010 | CONTINGENCY 'AP-P1-3-PN-115-010' /* GARRETT 138/115KV XFMR FAULT OPEN BRANCH FROM BUS 235469 TO BUS 235470 CKT 1 /* 01GARRET 138.00 01GARRET 115.00 END |

12.6.2 Index 1

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|----------|-----------|------------|---------------|---------|-----------|-------------|--------|--------------------|-------|------------|-----------------------|------------------------|-------|-----------|
| 41080612 | 200743 | 26HOOVERSV | PENELEC | 200734 | 26SCALP L | PENELEC | 1 | PN-P7-1-PN-230-001 | tower | 190.0 | 95.27 | 100.59 | DC | 10.1 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 200813 | 26YOUGH | 0.2053 |
| 200834 | 26SW_E13_K22 | 0.1055 |
| 200835 | 26DSGENWIN | 0.5191 |
| 200840 | 26DEEPCRK1 | 0.1896 |
| 200841 | 26DEEPCRK2 | 0.1896 |
| 200846 | 26FORWARD | 0.3701 |
| 200864 | K-013 E | 10.6056 |
| 200889 | 26STNY CRK | 0.5144 |
| 200890 | 26BF_G21_K23 | 0.2546 |
| 200891 | 26CSLMN_L13 | 0.3993 |
| 200892 | 26LOOKOUT | 0.3793 |
| 202225 | 26SCI_S29B | 0.1640 |
| 202652 | 26RGH_Y1-033 | 0.1949 |
| 292350 | K-023 | 11.7647 |
| 292542 | L-013 1 | 11.4429 |
| 293432 | R-040 E | 0.6437 |
| 293902 | O-048 E | 10.2986 |
| 294903 | P-060 E | 14.7403 |
| 913142 | Y1-033 E OP1 | 9.5368 |
| 917672 | Z2-108 E | 6.4366 |
| 930262 | AB1-065 E | 0.4692 |
| 938351 | AE1-053 | 3.5759 |
| 938881 | AE1-116 | 1.8887 |
| 938991 | AE1-128 C | 19.0440 |
| 938992 | AE1-128 E | 12.6960 |
| 942361 | AE2-249 C | 2.1425 |
| 942362 | AE2-249 E | 1.4283 |
| 943301 | AF1-001 C | 0.2377 |
| 943302 | AF1-001 E | 0.2651 |
| 943711 | AF1-039 C O1 | 2.5230 |
| 943712 | AF1-039 E O1 | 1.6820 |
| 944781 | AF1-143 C | 21.4554 |
| 944782 | AF1-143 E | 14.3036 |
| 945671 | AF1-232 C O1 | 38.2169 |
| 945672 | AF1-232 E O1 | 20.5783 |
| 945901 | AF1-255 C | 1.0487 |
| 945902 | AF1-255 E | 1.4482 |
| 946081 | AF1-273 C O1 | 22.0482 |
| 946082 | AF1-273 E O1 | 14.6988 |
| 946191 | AF1-284 C O1 | 2.6866 |
| 946192 | AF1-284 E O1 | 1.6120 |

| Bus # | Bus | MW Impact |
|--------------|--------------|------------------|
| 946241 | AF1-289 C O1 | 0.8594 |
| 946242 | AF1-289 E O1 | 0.5730 |
| 946571 | AF1-321 C O1 | 6.0616 |
| 946572 | AF1-321 E O1 | 4.0410 |
| LGEE | LGEE | 0.0764 |
| CPL | CPL | 0.1125 |
| WEC | WEC | 0.0394 |
| CBM-W2 | CBM-W2 | 1.1302 |
| NY | NY | 0.2229 |
| CBM-W1 | CBM-W1 | 1.4387 |
| TVA | TVA | 0.2044 |
| O-066 | O-066 | 1.4851 |
| CBM-S2 | CBM-S2 | 0.9537 |
| CBM-S1 | CBM-S1 | 1.2269 |
| G-007 | G-007 | 0.2236 |
| MADISON | MADISON | 0.0020 |
| MEC | MEC | 0.2066 |

12.6.3 Index 2

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|----------|-----------|------------|---------------|---------|-------------|-------------|--------|--------------------|-------|------------|-----------------------|------------------------|-------|-----------|
| 41080443 | 200746 | 26ROCKWOOD | PENELEC | 202650 | 26HIGHPOINT | PENELEC | 1 | PN-P7-1-PN-230-001 | tower | 179.0 | 134.56 | 136.9 | DC | 4.19 |

| Bus # | Bus | MW Impact |
|------------------|------------------|---------------|
| 200834 | 26SW_E13_K22 | 0.0701 |
| 200835 | 26DSGENWIN | 0.5597 |
| 200846 | 26FORWARD | 0.1641 |
| 200864 | K-013 E | 4.7029 |
| 200883 | Q-053 E | 3.2881 |
| 200888 | 26HIGHLAND | 0.2074 |
| 200889 | 26STNY CRK | 0.3411 |
| 200890 | 26BF_G21_K23 | 0.2745 |
| 200891 | 26CSLMN_L13 | 0.4306 |
| 200892 | 26LOOKOUT | 0.4090 |
| 200925 | 26R32 | 0.2393 |
| 202225 | 26SCI_S29B | 0.1090 |
| 292350 | K-023 | 12.6859 |
| 292542 | L-013 1 | 12.3389 |
| 293432 | R-040 E | 0.6941 |
| 293603 | O-018 E | 5.9441 |
| 293902 | O-048 E | 11.1050 |
| 294903 | P-060 E | 9.7738 |
| 296332 | R-032 E | 6.8586 |
| 917672 | Z2-108 E | 6.9406 |
| 938351 | AE1-053 | 3.8559 |
| 938881 | AE1-116 | 1.2553 |
| 938991 | AE1-128 C | 12.5662 |
| 938992 | AE1-128 E | 8.3774 |
| 942361 | AE2-249 C | 1.4137 |
| 942362 | AE2-249 E | 0.9425 |
| 944751 | AF1-140 C | 1.1212 |
| 944752 | AF1-140 E | 0.7475 |
| 944781 | AF1-143 C | 23.1354 |
| 944782 | AF1-143 E | 15.4236 |
| 945671 | AF1-232 C O1 | 25.3562 |
| 945672 | AF1-232 E O1 | 13.6534 |
| 945901 | AF1-255 C | 0.8591 |
| 945902 | AF1-255 E | 1.1863 |
| 946081 | AF1-273 C O1 | 14.6286 |
| 946082 | AF1-273 E O1 | 9.7524 |
| 946241 | AF1-289 C O1 | 2.9038 |
| 946242 | AF1-289 E O1 | 1.9358 |
| 946571 | AF1-321 C O1 | 2.5168 |
| 946572 | AF1-321 E O1 | 1.6778 |
| DUCKCREEK | DUCKCREEK | 0.3155 |

| Bus # | Bus | MW Impact |
|-------------------|------------|------------------|
| NEWTON | NEWTON | 0.3019 |
| FARMERCITY | FARMERCITY | 0.0158 |
| G-007A | G-007A | 0.9350 |
| VFT | VFT | 2.5671 |
| PRAIRIE | PRAIRIE | 0.7362 |
| COFFEEN | COFFEEN | 0.1480 |
| EDWARDS | EDWARDS | 0.0952 |
| CHEOAH | CHEOAH | 0.1577 |
| TILTON | TILTON | 0.1732 |
| GIBSON | GIBSON | 0.1534 |
| CALDERWOOD | CALDERWOOD | 0.1566 |
| BLUEG | BLUEG | 0.4930 |
| TRIMBLE | TRIMBLE | 0.1580 |
| CATAWBA | CATAWBA | 0.1162 |

Short Circuit

12.7 Short Circuit

The following Breakers are overdutied:

None

13 Network Impacts – Secondary Point of Interconnection

The Queue Project AF1-321 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection at the Quemahoning 230 kV substation in the PENELEC area. Project AF1-321 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF1-321 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

13.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

13.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

13.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

13.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

| ID | FROM BUS# | FROM BUS | kV | FROM BUS AREA | TO BUS# | TO BUS | kV | TO BUS AREA | CK T ID | CON T NAME | Type | Rating MVA | PRE PROJE CT LOADIN G % | POST PROJE CT LOADIN G % | AC D C | MW IMPAC T |
|----------|-----------|------------|-------|---------------|---------|-----------|-------|-------------|---------|--------------------|-----------|------------|-------------------------|--------------------------|--------|------------|
| 41422173 | 200742 | 26TOWER51 | 115.0 | PENELEC | 200741 | 26SEWARD | 115.0 | PENELEC | 1 | AP-P1-3-PN-115-010 | operation | 185.0 | 118.54 | 120.66 | DC | 3.93 |
| 41421883 | 200743 | 26HOOVERSV | 115.0 | PENELEC | 200742 | 26TOWER51 | 115.0 | PENELEC | 1 | AP-P1-3-PN-115-010 | operation | 172.0 | 140.84 | 143.15 | DC | 3.98 |
| 41421888 | 200743 | 26HOOVERSV | 115.0 | PENELEC | 200742 | 26TOWER51 | 115.0 | PENELEC | 1 | Base Case | operation | 137.0 | 113.16 | 115.73 | DC | 3.53 |

13.5 Flow Gate Details

The following indices contain additional information about each flowgate presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

13.5.1 Contingency Descriptions

| Contingency Name | Contingency Definition |
|--------------------|---|
| Base Case | |
| AP-P1-3-PN-115-010 | CONTINGENCY 'AP-P1-3-PN-115-010' /* GARRETT 138/115KV XFMR FAULT OPEN BRANCH FROM BUS 235469 TO BUS 235470 CKT 1 /* 01GARRET 138.00 01GARRET 115.00 END |

Short Circuit

13.6 Short Circuit

The following Breakers are overdutied:

None

Affected Systems

14 Affected Systems

14.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

14.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

14.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

14.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

14.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

Attachment 1
System Configuration