



# **Generation Interconnection**

## **Feasibility Study Report**

**for**

## **Queue Project AF2-011**

**TAIT 69 KV**

**20 MW Capacity / 0 MW Energy**

July 2020

# Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	5
4	Point of Interconnection.....	6
5	Cost Summary.....	6
6	Transmission Owner Scope of Work.....	8
6.1	Attachment Facilities.....	8
6.2	Direct Connection Cost Estimate.....	8
6.3	Non-Direct Connection Cost Estimate.....	8
7	Schedule.....	9
8	Transmission Owner Analysis.....	9
8.1	Power Flow Analysis & System Reinforcements.....	9
9	Interconnection Customer Requirements.....	9
	Power Factor Requirements.....	10
10	Revenue Metering and SCADA Requirements.....	10
10.1	PJM Requirements.....	10
10.2	Interconnected Transmission Owner Requirements.....	10
11	System Protection.....	11
12	Compliance Issues and Interconnection Customer Requirements.....	11
13	Power Factor Requirements.....	11
14	Summer Peak - Load Flow Analysis (Transmission System).....	11
14.1	Generation Deliverability.....	12
14.2	Multiple Facility Contingency.....	12
14.3	Contribution to Previously Identified Overloads.....	12
14.4	Potential Congestion due to Local Energy Deliverability.....	12
14.5	System Reinforcements - Summer Peak Load Flow (Transmission).....	12
15	Summer Peak - Load Flow Analysis (underlying transmission <100 kV system).....	12
16	Light Load Analysis.....	13
17	Short Circuit Analysis.....	13
18	Stability and Reactive Power Assessment.....	13
19	Affected Systems.....	13

19.1	MISO .....	13
19.2	LG&E.....	13

## 1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Dayton.

## 2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

### 3 General

The Interconnection Customer (IC) has proposed an uprate to an existing Natural Gas generating facility located in Montgomery, Ohio. This project is an increase to the Tait Generation Station. The AF2-011 queue position is a 0 MW uprate (20 MW Capacity uprate) to the Tait Generation Station. The proposed in-service date for this uprate project is May 31, 2020. This study does not imply a TO commitment to this in-service date.

<b>Queue Number</b>	<b>AF2-011</b>
<b>Project Name</b>	TAIT 69 KV
<b>State</b>	Ohio
<b>County</b>	Montgomery
<b>Transmission Owner</b>	Dayton
<b>MFO</b>	690
<b>MWE</b>	0
<b>MWC</b>	20
<b>Fuel</b>	Natural Gas
<b>Basecase Study Year</b>	2023

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

## 4 Point of Interconnection

AF2-011 will interconnect with the Dayton transmission system as an uprate to Tait Generation at the Tait 69 kV substation.

The AF2-011 “Tait 69 KV” uprate project will interconnect with The Dayton Power & Light Company transmission system via the existing Tait substation. This Project is Queue No. AF2-011 for an additional 20 MW summer capacity. Wet compression will not be available for winter operation due to the potential of the water freezing.

This project involves adding wet compression capability to the following Tait Generation Units: CT3, CT4, CT5, CT6, and CT7. CT1 and CT2. Wet compression will add 4 MW capacity to each of the existing generators listed above for a total of 20 MW. CT3 CIR would increase from 79 MW to 83 MW. CT4, CT5, CT6, and CT7 would each increase from 80 MW to 84 MW. This project is an efficiency project and adds to the output of existing generating equipment. There are no changes required for the generators, transformers, breakers, switches, interconnecting conductor, equipment relays, or any other electrical equipment on the Generator Owner's side of the interconnect.

Attachment 1 shows a one-line diagram of the proposed connection of the (AF2-011) generation project to the Dayton Power & Light transmission system. Attachment 2 provides the proposed location for the point of interconnection. IC will be responsible for constructing all the facilities on its side of the POI including the attachment line.

## 5 Cost Summary

The AF2-011 “Tait 69 KV” project is responsible for the interconnection facilities to the Dayton Power and Light system. AF2-012 “Tait 69 kV” will share the same interconnection facilities.

The AF2-011 project will be responsible for the following costs:

Description	Total Cost
<b>Total Physical Interconnection Costs</b>	\$30,000
<b>Total System Network Upgrade Costs</b>	\$0
<b>Total Costs</b>	<b>\$0</b>

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 88-129. If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

The required Attachment Facilities, Direct Connection and Non-Direct Connection work for the interconnection of the AF2-011 generation project to the Dayton Transmission System is detailed in the following sections. The associated one-line with the generation project attachment facilities and primary direct and non-direct connection are shown in Attachment 1.

Note that the Dayton findings were made from a conceptual review of this project. A more detailed review of the connection facilities and their cost will be identified in a future study phase. Further note that the cost estimate data contained in this document should be considered high level estimates since it was produced without a detailed engineering review. The applicant will be responsible for the actual cost of construction. Dayton herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any reinforcements to the transmission systems.

## 6 Transmission Owner Scope of Work

The AF2-011 project will use the existing interconnection facilities, so the only Transmission Owner work associated with this project is to provide engineering oversight and make relevant protection system and relay setting changes at the AF2-011 interconnection substation and other related adjacent substations.

This report assumes that the Interconnection Customer will use the existing attachment line from its generating facility into the proposed Point of Interconnection since this project is an upgrade to the existing generators as depicted on the one line diagram in Attachment 1. The IC will also be responsible for the fiber/OPGW that Dayton requires on the generator line for the communication assisted trip scheme. The costs included below are for the necessary protection system review and any subsequent field changes needed to coordinate with IC attachment facilities.

The total physical interconnection costs is given in the tables below:

### 6.1 Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Engineering review and commissioning	\$15,000
<b>Total Attachment Facility Costs</b>	<b>\$15,000</b>

### 6.2 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
None	\$0
<b>Total Direct Connection Facility Costs</b>	<b>\$0</b>

### 6.3 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Tait 69 kV Substation - relay setting changes	\$15,000
<b>Total Non-Direct Connection Facility Costs</b>	<b>\$15,000</b>

## 7 Schedule

Based on the extent of the Dayton primary Attachment Facilities and Non-Direct Connection work required to support the AF2-011 generation project, it is expected to take a minimum of **eighteen (18) months** from the date of a fully executed Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the IC to make a preliminary payment to Dayton which funds the Non-Direct Connection work and the first three months of engineering design that is related to the construction of the Attachment Facilities. It further assumes that the IC will provide all rights-of-way, permits, easements, etc. that will be needed. A further assumption is that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined Attachment Facilities and Non-Direct Connection work, and that all system outages will be allowed when requested.

## 8 Transmission Owner Analysis

### 8.1 Power Flow Analysis & System Reinforcements

Additionally, Dayton performed an analysis of its underlying transmission <100 kV system. The following issues were found to be existing in the Dayton transmission system.

Facility	Contingency Description	Existing Upgrade	Cost
253181 09NHOLLN - 253201 09ROBINS 69 kV ckt 1	Adkins - Beatty 345 kV	PJM Network Upgrade, N5456: From AC1-166, replace wave trap with 2000A wave trap. Project Cost: \$56,000 Time Estimate: 20 weeks	\$56,000
253099 09ATLNTA 69 kV - 253100 09ATLNTA 345 kV ckt 1	Atlanta - New Holland 69 kV Robinson - New Holland 69 kV	Reinforcement Project, r190012: Add a second 250 MVA 345/69kV transformer. Project Cost: \$5,000,000 Time Estimate: 24 months	\$5,000,000
		<b>TOTAL COST</b>	

This project does not currently have a financial responsibility towards these upgrades, but may get an allocation based on projects withdrawing from the queue. Allocations to upgrades are determined in the System Impact phase. The upgrades may need to be completed prior to initial operation of this facility.

## 9 Interconnection Customer Requirements

It is understood that the Interconnection Customer (IC) is responsible for all costs associated with this interconnection. The costs above are reimbursable to the Transmission Owner. The cost of the IC's generating plant and the costs for the line connecting the generating plant to the Point of Interconnection are not included in this report; these are assumed to be the IC's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for the Transmission Owner to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

## **Power Factor Requirements**

The IC shall design its synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.90 lagging (supplying VARs) measured at the generator terminals.

## **10 Revenue Metering and SCADA Requirements**

### **10.1 PJM Requirements**

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

### **10.2 Interconnected Transmission Owner Requirements**

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-dayton/dayton-facilities-connection-requirements.ashx>

<http://www.pjm.com/planning/design-engineering/to-tech-standards.aspx>

## 11 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dayton’s “Requirements for the connection of Facilities to the Dayton Power & Light company Transmission System” document located at: <https://www.pjm.com/planning/design-engineering/to-tech-standards/private-dayton.aspx>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

## 12 Compliance Issues and Interconnection Customer Requirements

The Dayton Power and Light Company (DP&L) has prepared this Facilities Connection Requirements document to ensure compliance with North American Electric Reliability Council (NERC) Reliability Standards and applicable Regional Reliability Organization, sub regional, Power Pool, and individual Transmission Owner planning criteria and facility connection requirements in compliance to NERC Standard FAC-001-2. These connection requirements apply to all generation facilities, transmission facilities, and end-users connecting to the DP&L transmission system. Detailed information outlining DP&L interconnection requirements can be reviewed utilizing the following link:

<https://www.pjm.com/~media/planning/plan-standards/private-dayton/dayton-facilities-connection-requirements.ashx>

## 13 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dayton transmission system.

## 14 Summer Peak - Load Flow Analysis (Transmission System)

The Queue Project AF2-011 was evaluated as a 20.0 MW (Capacity 20.0 MW) injection as an uprate to Tait Generation at the Tait 69 kV substation in the Dayton area. Project AF2-011 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF2-011 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

#### **14.1 Generation Deliverability**

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

#### **14.2 Multiple Facility Contingency**

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

#### **14.3 Contribution to Previously Identified Overloads**

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

#### **14.4 Potential Congestion due to Local Energy Deliverability**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

#### **14.5 System Reinforcements - Summer Peak Load Flow (Transmission)**

None

### **15 Summer Peak - Load Flow Analysis (underlying transmission <100 kV system)**

## **16 Light Load Analysis**

*Light Load Studies (As applicable)*

Not applicable.

## **17 Short Circuit Analysis**

The following Breakers are overdutied:

Not applicable.

## **18 Stability and Reactive Power Assessment**

*(Summary of the VAR requirements based upon the results of the dynamic studies)*

To be determined during later study phases.

## **19 Affected Systems**

### **19.1 MISO**

MISO Impacts to be determined during later study phases (as applicable).

### **19.2 LG&E**

LG&E Impacts to be determined during later study phases (as applicable).