



Generation Interconnection

Feasibility Study Report

for

Queue Project AF2-248

EDGEWOOD 12 KV I

3.4 MW Capacity / 7.2 MW Energy

July 2020

Table of Contents

- 1 Introduction..... 3
- 2 Preface..... 3
- 3 General 4
- 4 Point of Interconnection..... 4
- 5 Cost Summary 4
 - 5.1 DPL Costs..... 5
- 6 Transmission Owner Scope of Work..... 5
- 7 Schedule..... 5
- 8 Transmission Owner Analysis..... 5
- 9 Interconnection Customer Requirements..... 5
 - 9.1 Required Relaying and Communications..... 5
 - 9.2 Interconnection Customer Scope of Direct Connection Work 5
 - 9.3 Additional Interconnection Customer Responsibilities..... 6
- 10 Revenue Metering and SCADA Requirements 6
 - 10.1 PJM Requirements..... 6
 - 10.2 Interconnected Transmission Owner Requirements..... 6
- 11 Summer Peak - Load Flow Analysis 7
 - 11.1 Generation Deliverability 7
 - 11.2 Multiple Facility Contingency 7
 - 11.3 Contribution to Previously Identified Overloads..... 7
 - 11.4 Potential Congestion due to Local Energy Deliverability..... 7
 - 11.5 System Reinforcements - Summer Peak Load Flow - Primary POI..... 8
 - 11.6 Flow Gate Details.....10
 - 11.6.1 Index 1 11
 - 11.6.2 Index 2 14
 - 11.7 Queue Dependencies 17
 - 11.8 Contingency Descriptions..... 19
- 12 Short Circuit Analysis..... 19
- 13 Affected Systems 19

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is DPL.

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in Wicomico County, Maryland. The installed facilities will have a total capability of 7.2 MW with 3.4 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is June 01, 2020. This study does not imply a TO commitment to this in-service date.

Queue Number	AF2-248
Project Name	EDGEWOOD 12 KV I
State	Maryland
County	Wicomico
Transmission Owner	DPL
MFO	7.2
MWE	7.2
MWC	3.4
Fuel	Solar
Basecase Study Year	2023

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

AF2-248 will interconnect with the DPL transmission system behind the 69/12 kV transformer at Choptank Electric Cooperative's (CEC) Edgewood substation.

5 Cost Summary

The AF2-248 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$0
Total System Network Upgrade Costs	\$20,300,000
Total Costs	\$20,300,000

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 88-129. If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

5.1 DPL Costs

Cost estimates will further be refined as a part of the Impact Study and Facilities Study for this project. The Interconnection Customer will be responsible for all costs incurred by DPL in connection with the AF2-248 project. DPL reserves the right to reassess issues presented in this document and, upon appropriate justification, submit additional costs related to the AF2-248 project.

6 Transmission Owner Scope of Work

There is no Delmarva Power & Light attachment facility or direct connection work scope. Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect AF2-248 will be specified in a separate two party Interconnection Agreement (IA) between Choptank Electric Cooperative (CEC) and the Interconnection Customer as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT). The Interconnection Customer is responsible for contacting the Choptank Electric Cooperative (CEC) directly for attachment facilities work scope.

7 Schedule

The Interconnection Customer is responsible for contacting Choptank Electric Cooperative (CEC) directly for schedule to construct the physical interconnection for the AF2-248 project.

8 Transmission Owner Analysis

None

9 Interconnection Customer Requirements

9.1 Required Relaying and Communications

DPL will require over voltage relay protection on the high side of the Edgewood 69/12 kV transformer.

9.2 Interconnection Customer Scope of Direct Connection Work

The IC is responsible for all design and construction related to activities on their side of the Point of Interconnection. Site preparation, including grading and an access road, as necessary, is assumed to be by the IC. Route selection, line design, and right-of-way acquisition of the direct connect facilities is not included in this report and is the responsibility of the IC. Protective relaying and metering design and installation must comply with DPL's applicable standards. The IC is also required to provide revenue metering and real-time telemetering data to PJM in conformance with the requirements contained in PJM Manuals M-01 and M-14 and the PJM Tariff.

9.3 Additional Interconnection Customer Responsibilities

The Interconnection Customer is responsible for contacting Choptank Electric Cooperative (CEC) for any additional Interconnection Customer requirements.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

Metering for this project will be installed behind the Choptank transformer. DPL will require the following: The Interconnection Customer will grant permission for PJM to send DPL the following telemetry that the Interconnection Customer sends to PJM: real time MW, MVAR, volts, amperes, generator status, and interval MWH and MVARH

11 Summer Peak - Load Flow Analysis

The Queue Project AF2-248 was evaluated as a 7.2 MW (Capacity 3.4 MW) injection at the Edgewood 69 kV substation in the DPL area. Project AF2-248 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF2-248 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
101842293	232233	PRESTON	69.0	DP&L	232821	TANYARD	69.0	DP&L	1	DPL_P4 - 2_DP11	breaker	93.0	201.67	202.66	DC	0.93
101842278	232234	TODD	69.0	DP&L	232233	PRESTON	69.0	DP&L	1	DPL_P4 - 2_DP11	breaker	93.0	206.62	207.61	DC	0.93

11.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

11.5 System Reinforcements - Summer Peak Load Flow - Primary POI

ID	Idx	Facility	Upgrade Description	Cost
101842278	2	TODD 69.0 kV - PRESTON 69.0 kV Ckt 1	<p><u>DPL</u> b2946 (1013) : PJM baseline upgrade b2946 conversion of Preston station to a Ring Bus Project Type : CON Cost : \$6,000,000 Time Estimate : 30-36 Months</p> <p>ds6716r0001 (1025) : Previously identified in AB2-172, To mitigate the (DP&L) TODD to PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) overload will require substation reinforcements at Todd Substation. Replace 600A Disconnect Switch at Todd Project Type : FAC Cost : \$100,000 Time Estimate : 12.0 Months</p> <p>ds6716r0002 (1039) : To mitigate the (DP&L) Preston - Tanyard 69 kV line (from bus 232821 to bus 232233 ckt 1) overload, it will require increasing the emergency rating of the Preston-Tanyard 69 kV line by replacing the terminal equipment at the Tanyard Tap Project Type : FAC Cost : \$100,000 Time Estimate : 9-12 Months</p> <p>dt6716r0005 (1056) : To mitigate the (DP&L) Preston - Todd 69 kV line (from bus 232234 to bus 232233 ckt 1) overload, it will require increasing the emergency rating of the Preston-Todd 69 kV line by rebuilding the line. This includes installation of new poles, conductor, foundations, insulators and OPGW. Project Type : FAC Cost : \$9,000,000 Time Estimate : 36-48 Months</p>	\$9,200,000

ID	Idx	Facility	Upgrade Description	Cost
101842293	1	PRESTON 69.0 kV - TANYARD 69.0 kV Ckt 1	<p><u>DPL</u> b2946 (1013) : PJM baseline upgrade b2946 conversion of Preston station to a Ring Bus Project Type : CON Cost : \$6,000,000 Time Estimate : 30-36 Months</p> <p>dt6716r0001 (1038) : To mitigate the (DP&L) Preston - Tanyard 69 kV line (from bus 232821 to bus 232233 ckt 1) overload, it will require increasing the emergency rating of the Preston-Tanyard 69 kV line by rebuilding the line. This includes installation of new poles, foundations, insulators and OPGW. Project Type : FAC Cost : \$11,000,000 Time Estimate : 36-48 Months</p> <p>ds6716r0002 (1039) : To mitigate the (DP&L) Preston - Tanyard 69 kV line (from bus 232821 to bus 232233 ckt 1) overload, it will require increasing the emergency rating of the Preston-Tanyard 69 kV line by replacing the terminal equipment at the Tanyard Tap Project Type : FAC Cost : \$100,000 Time Estimate : 9-12 Months</p>	\$11,100,000
			TOTAL COST	\$20,300,000

11.6 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

11.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
101842293	232233	PRESTON	DP&L	232821	TANYARD	DP&L	1	DPL_P4-2_DP11	breaker	93.0	201.67	202.66	DC	0.93

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
232404	W1-003 C	0.3036	50/50	0.3036
232405	W1-003 E	0.5112	50/50	0.5112
232406	W1-004 FULL	0.3036	50/50	0.3036
232407	W1-004 E	0.5112	50/50	0.5112
232408	W1-005 C	0.3036	50/50	0.3036
232409	W1-005 E	0.5112	50/50	0.5112
232410	W1-006 C	0.3036	50/50	0.3036
232411	W1-006 E	0.5112	50/50	0.5112
232412	X1-032 E	0.4732	50/50	0.4732
232417	X3-008 C	0.5183	50/50	0.5183
232418	X3-008 E	4.9023	50/50	4.9023
232426	Y1-080 FULL	0.0598	50/50	0.0598
232427	Y1-080 E	0.5688	50/50	0.5688
232428	Y3-058 C	0.1521	50/50	0.1521
232429	Y3-058 E	1.4383	50/50	1.4383
232433	Z2-076 E	0.1512	Adder	0.18
232435	Z2-077 E	0.1512	Adder	0.18
232905	BAYVIEW1	0.2443	50/50	0.2443
232907	VN8	3.9453	50/50	3.9453
232919	VN10	0.3965	50/50	0.3965
232921	TASLEY2G	0.4282	50/50	0.4282
232926	CRISFLD1	0.2061	50/50	0.2061
293670	O-025 C	0.1383	50/50	0.1383
917081	Z2-012 C	0.1486	50/50	0.1486
917082	Z2-012 E	1.4052	50/50	1.4052
918831	AA1-102	0.7727	50/50	0.7727
923282	AB1-137 C	0.2879	Adder	0.34
923283	AB1-137 E	0.1234	Adder	0.15
924681	AB2-120 C OP	3.6460	Adder	4.29
924682	AB2-120 E OP	5.9488	Adder	7.0
924781	AB2-130 C OP	3.8511	50/50	3.8511
924782	AB2-130 E OP	6.2834	50/50	6.2834
924831	AB2-136 C	7.6302	50/50	7.6302
924832	AB2-136 E	8.0917	50/50	8.0917
925151	AB2-172 C OP	7.5117	50/50	7.5117
925152	AB2-172 E OP	12.2559	50/50	12.2559
925261	AB2-180 C	2.1652	50/50	2.1652
925262	AB2-180 E	0.9280	50/50	0.9280
927031	AC1-190 C	13.3011	50/50	13.3011
927032	AC1-190 E	5.7005	50/50	5.7005
927191	AC1-213 C	0.4276	50/50	0.4276
927192	AC1-213 E	0.2806	50/50	0.2806

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
930201	AB1-056 C	4.1164	Adder	4.84
930202	AB1-056 E	11.7229	Adder	13.79
930881	AB1-137 C	0.2879	Adder	0.34
930882	AB1-137 E	0.1234	Adder	0.15
932161	AC2-023 C	4.4912	50/50	4.4912
932162	AC2-023 E	3.2710	50/50	3.2710
938651	AE1-087 C	6.3256	50/50	6.3256
938652	AE1-087 E	1.5814	50/50	1.5814
938891	AE1-117 C O1	2.8516	Adder	3.35
938892	AE1-117 E O1	7.5929	Adder	8.93
938901	AE1-118 C O1 (Withdrawn : 07/10/2020)	2.8640	Adder	3.37
938902	AE1-118 E O1 (Withdrawn : 07/10/2020)	7.6258	Adder	8.97
939151	AE1-145	1.9210	Adder	2.26
939621	AE1-192 C O1	5.3260	50/50	5.3260
939622	AE1-192 E O1	2.6064	50/50	2.6064
942441	AE2-257 C	2.2451	Adder	2.64
942442	AE2-257 E	5.9190	Adder	6.96
943361	AF1-007 C	0.1214	Adder	0.14
943362	AF1-007 E	0.3452	Adder	0.41
944921	AF1-157 C O1	1.3116	Adder	1.54
944922	AF1-157 E O1	0.8744	Adder	1.03
945661	AF1-231 C	0.7320	Adder	0.86
945662	AF1-231 E	1.0980	Adder	1.29
945781	AF1-243	0.5666	50/50	0.5666
945791	AF1-244	0.9557	50/50	0.9557
945931	AF1-258	0.4949	50/50	0.4949
946041	AF1-269 (Withdrawn : 05/12/2020)	2.9792	50/50	2.9792
957611	AF2-055 C	3.9662	50/50	3.9662
957612	AF2-055 E	1.6998	50/50	1.6998
957661	AF2-060	0.4582	Adder	1.02
957671	AF2-061 O1	2.0363	Adder	4.52
959021	AF2-193 C O1	4.0314	Adder	8.95
959022	AF2-193 E O1	10.8747	Adder	24.14
959031	AF2-194 C O1	4.0314	Adder	8.95
959032	AF2-194 E O1	10.8747	Adder	24.14
959051	AF2-196 C	0.3245	Adder	0.72
959052	AF2-196 E	0.7572	Adder	1.68
959161	AF2-207 C O1	2.5390	50/50	2.5390
959162	AF2-207 E O1	3.8084	50/50	3.8084
959571	AF2-248 C	0.4379	50/50	0.4379
959572	AF2-248 E	0.4894	50/50	0.4894
959581	AF2-249 C	0.0773	50/50	0.0773
959582	AF2-249 E	0.3091	50/50	0.3091
959591	AF2-250 C	0.1417	50/50	0.1417
959592	AF2-250 E	0.1095	50/50	0.1095
960341	AF2-325 C	1.4218	50/50	1.4218
960342	AF2-325 E	1.9635	50/50	1.9635
960671	AF2-358 C O1	15.4410	50/50	15.4410

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
960672	AF2-358 E O1	10.2940	50/50	10.2940
960871	AF2-378 C	0.3573	50/50	0.3573
960872	AF2-378 E	0.4957	50/50	0.4957
960881	AF2-379 C	0.2067	50/50	0.2067
960882	AF2-379 E	0.2849	50/50	0.2849
960941	AF2-385 C O1	6.0451	50/50	6.0451
960942	AF2-385 E O1	3.4004	50/50	3.4004
961181	AF2-409 O1	14.9490	50/50	14.9490
NEWTON	NEWTON	0.0752	Confirmed LTF	0.0752
FARMERCITY	FARMERCITY	0.0039	Confirmed LTF	0.0039
CALDERWOOD	CALDERWOOD	0.0348	Confirmed LTF	0.0348
NY	NY	0.0288	Confirmed LTF	0.0288
PRAIRIE	PRAIRIE	0.1808	Confirmed LTF	0.1808
O-066	O-066	0.2890	Confirmed LTF	0.2890
CHEOAH	CHEOAH	0.0350	Confirmed LTF	0.0350
EDWARDS	EDWARDS	0.0245	Confirmed LTF	0.0245
TILTON	TILTON	0.0441	Confirmed LTF	0.0441
G-007	G-007	0.0374	Confirmed LTF	0.0374
GIBSON	GIBSON	0.0382	Confirmed LTF	0.0382
BLUEG	BLUEG	0.1215	Confirmed LTF	0.1215
TRIMBLE	TRIMBLE	0.0390	Confirmed LTF	0.0390
CATAWBA	CATAWBA	0.0245	Confirmed LTF	0.0245

11.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/DC	MW IMPACT
101842278	232234	TODD	DP&L	232233	PRESTON	DP&L	1	DPL_P4-2_DP11	breaker	93.0	206.62	207.61	DC	0.93

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
232404	W1-003 C	0.3036	50/50	0.3036
232405	W1-003 E	0.5112	50/50	0.5112
232406	W1-004 FULL	0.3036	50/50	0.3036
232407	W1-004 E	0.5112	50/50	0.5112
232408	W1-005 C	0.3036	50/50	0.3036
232409	W1-005 E	0.5112	50/50	0.5112
232410	W1-006 C	0.3036	50/50	0.3036
232411	W1-006 E	0.5112	50/50	0.5112
232412	X1-032 E	0.4732	50/50	0.4732
232417	X3-008 C	0.5183	50/50	0.5183
232418	X3-008 E	4.9023	50/50	4.9023
232426	Y1-080 FULL	0.0598	50/50	0.0598
232427	Y1-080 E	0.5688	50/50	0.5688
232428	Y3-058 C	0.1521	50/50	0.1521
232429	Y3-058 E	1.4383	50/50	1.4383
232433	Z2-076 E	0.1512	Adder	0.18
232435	Z2-077 E	0.1512	Adder	0.18
232905	BAYVIEW1	0.2443	50/50	0.2443
232907	VN8	3.9453	50/50	3.9453
232919	VN10	0.3965	50/50	0.3965
232921	TASLEY2G	0.4282	50/50	0.4282
232926	CRISFLD1	0.2061	50/50	0.2061
293670	O-025 C	0.1383	50/50	0.1383
917081	Z2-012 C	0.1486	50/50	0.1486
917082	Z2-012 E	1.4052	50/50	1.4052
918831	AA1-102	0.7727	50/50	0.7727
923282	AB1-137 C	0.2879	Adder	0.34
923283	AB1-137 E	0.1234	Adder	0.15
924681	AB2-120 C OP	3.6460	Adder	4.29
924682	AB2-120 E OP	5.9488	Adder	7.0
924781	AB2-130 C OP	3.8511	50/50	3.8511
924782	AB2-130 E OP	6.2834	50/50	6.2834
924831	AB2-136 C	7.6302	50/50	7.6302
924832	AB2-136 E	8.0917	50/50	8.0917
925151	AB2-172 C OP	7.5117	50/50	7.5117
925152	AB2-172 E OP	12.2559	50/50	12.2559
925261	AB2-180 C	2.1652	50/50	2.1652
925262	AB2-180 E	0.9280	50/50	0.9280
927031	AC1-190 C	13.3011	50/50	13.3011
927032	AC1-190 E	5.7005	50/50	5.7005
927191	AC1-213 C	0.4276	50/50	0.4276
927192	AC1-213 E	0.2806	50/50	0.2806

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
930201	AB1-056 C	4.1164	Adder	4.84
930202	AB1-056 E	11.7229	Adder	13.79
930881	AB1-137 C	0.2879	Adder	0.34
930882	AB1-137 E	0.1234	Adder	0.15
932161	AC2-023 C	4.4912	50/50	4.4912
932162	AC2-023 E	3.2710	50/50	3.2710
938651	AE1-087 C	6.3256	50/50	6.3256
938652	AE1-087 E	1.5814	50/50	1.5814
938891	AE1-117 C O1	2.8516	Adder	3.35
938892	AE1-117 E O1	7.5929	Adder	8.93
938901	AE1-118 C O1 (Withdrawn : 07/10/2020)	2.8640	Adder	3.37
938902	AE1-118 E O1 (Withdrawn : 07/10/2020)	7.6258	Adder	8.97
939151	AE1-145	1.9210	Adder	2.26
939621	AE1-192 C O1	5.3260	50/50	5.3260
939622	AE1-192 E O1	2.6064	50/50	2.6064
942441	AE2-257 C	2.2451	Adder	2.64
942442	AE2-257 E	5.9190	Adder	6.96
943361	AF1-007 C	0.1214	Adder	0.14
943362	AF1-007 E	0.3452	Adder	0.41
944921	AF1-157 C O1	1.3116	Adder	1.54
944922	AF1-157 E O1	0.8744	Adder	1.03
945661	AF1-231 C	0.7320	Adder	0.86
945662	AF1-231 E	1.0980	Adder	1.29
945781	AF1-243	0.5666	50/50	0.5666
945791	AF1-244	0.9557	50/50	0.9557
945931	AF1-258	0.4949	50/50	0.4949
946041	AF1-269 (Withdrawn : 05/12/2020)	2.9792	50/50	2.9792
957611	AF2-055 C	3.9662	50/50	3.9662
957612	AF2-055 E	1.6998	50/50	1.6998
957661	AF2-060	0.4582	Adder	1.02
957671	AF2-061 O1	2.0363	Adder	4.52
959021	AF2-193 C O1	4.0314	Adder	8.95
959022	AF2-193 E O1	10.8747	Adder	24.14
959031	AF2-194 C O1	4.0314	Adder	8.95
959032	AF2-194 E O1	10.8747	Adder	24.14
959051	AF2-196 C	0.3245	Adder	0.72
959052	AF2-196 E	0.7572	Adder	1.68
959161	AF2-207 C O1	2.5390	50/50	2.5390
959162	AF2-207 E O1	3.8084	50/50	3.8084
959571	AF2-248 C	0.4379	50/50	0.4379
959572	AF2-248 E	0.4894	50/50	0.4894
959581	AF2-249 C	0.0773	50/50	0.0773
959582	AF2-249 E	0.3091	50/50	0.3091
959591	AF2-250 C	0.1417	50/50	0.1417
959592	AF2-250 E	0.1095	50/50	0.1095
960341	AF2-325 C	1.4218	50/50	1.4218
960342	AF2-325 E	1.9635	50/50	1.9635
960671	AF2-358 C O1	15.4410	50/50	15.4410

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
960672	AF2-358 E O1	10.2940	50/50	10.2940
960871	AF2-378 C	0.3573	50/50	0.3573
960872	AF2-378 E	0.4957	50/50	0.4957
960881	AF2-379 C	0.2067	50/50	0.2067
960882	AF2-379 E	0.2849	50/50	0.2849
960941	AF2-385 C O1	6.0451	50/50	6.0451
960942	AF2-385 E O1	3.4004	50/50	3.4004
961181	AF2-409 O1	14.9490	50/50	14.9490
NEWTON	NEWTON	0.0752	Confirmed LTF	0.0752
FARMERCITY	FARMERCITY	0.0039	Confirmed LTF	0.0039
CALDERWOOD	CALDERWOOD	0.0348	Confirmed LTF	0.0348
NY	NY	0.0288	Confirmed LTF	0.0288
PRAIRIE	PRAIRIE	0.1808	Confirmed LTF	0.1808
O-066	O-066	0.2890	Confirmed LTF	0.2890
CHEOAH	CHEOAH	0.0350	Confirmed LTF	0.0350
EDWARDS	EDWARDS	0.0245	Confirmed LTF	0.0245
TILTON	TILTON	0.0441	Confirmed LTF	0.0441
G-007	G-007	0.0374	Confirmed LTF	0.0374
GIBSON	GIBSON	0.0382	Confirmed LTF	0.0382
BLUEG	BLUEG	0.1215	Confirmed LTF	0.1215
TRIMBLE	TRIMBLE	0.0390	Confirmed LTF	0.0390
CATAWBA	CATAWBA	0.0245	Confirmed LTF	0.0245

11.7 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AA1-102	Kings Creek-Loretto 138kV	Partially in Service - Under Construction
AB1-056	Indian River 230kV I	Engineering and Procurement
AB1-137	Frankford 25kV	Engineering and Procurement
AB2-120	Piney Grove-New Church 138kV	Active
AB2-130	Laurel 69kV	Active
AB2-136	West Cambridge-Vienna 69kV	Active
AB2-172	Todd 69kV	Active
AB2-180	Rockawalkin 69kV	Active
AC1-190	East New Market 69kV	Active
AC1-213	North Salisbury 25kV	Active
AC2-023	Hebron 69kV	Active
AE1-087	Todd 69 kV	Active
AE1-117	Bethany 138 kV	Active
AE1-118	Bethany-138th Street 138 kV	Withdrawn
AE1-145	Wallops Island 69 kV	Active
AE1-192	Belle Haven-Tasley 69 kV	Active
AE2-257	Cedar Neck 69 kV	Active
AF1-007	Indian River 230 kV I	Active
AF1-157	Laurel-Sussex 69 kV	Active
AF1-231	New Church 138 kV	Active
AF1-243	Tasley 25 kV	Active
AF1-244	Kingston 25 kV	Active
AF1-258	Rockawalkin 69 kV	Active
AF1-269	Airey-Golden Hill 69 kV	Withdrawn
AF2-055	Plantation 69 kV	Active
AF2-060	Wattsville 12 kV	Active
AF2-061	Wattsville 69kV	Active
AF2-193	Indian River 230 kV I	Active
AF2-194	Indian River 230 kV II	Active
AF2-196	Cedar Neck 69 kV II	Active
AF2-207	Nelson 69 kV	Active
AF2-248	Edgewood 12 kV I	Active
AF2-249	Edgewood 12 kV II	Active
AF2-250	Edgewood 12 kV III	Active
AF2-325	Jacktown 12 kV	Active
AF2-358	Airey-Vienna 69 kV	Active
AF2-378	Cambridge 12 kV	Active
AF2-379	Princess Anne 25 kV	Active
AF2-385	Nelson 69 kV	Active

Queue Number	Project Name	Status
AF2-409	Vienna 138 kV	Active
W1-003	Oak Hall	In Service
W1-004	Oak Hall	In Service
W1-005	Oak Hall	In Service
W1-006	Oak Hall	In Service
X1-032	Costen 25kV	In Service
X3-008	Todd 69kV	Under Construction
Y1-080	Dorchester 12kV	In Service
Y3-058	Rockawalkin 69kV	In Service
Z2-012	Weirwood-Eastville 69kV	In Service
Z2-076	Worcester South 25kV	In Service
Z2-077	Worcester North 25kV	In Service

11.8 Contingency Descriptions

Contingency Name	Contingency Definition
DPL_P4-2_DP11	CONTINGENCY 'DPL_P4-2_DP11' /*STEELE BUS BREAKER TO MILFORD DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1 /*MILFORD STEELE 230 230 DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1 /*STEELE VIENNA 230 230 END

12 Short Circuit Analysis

Short circuit will be studied in the System Impact Study phase.

13 Affected Systems

None