



**Generation Interconnection
Feasibility Study Report
for
Queue Project AG1-083
AHOSKIE 34.5 KV
12 MW Capacity / 20 MW Energy**

January 2021

Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	5
4	Point of Interconnection.....	6
5	Cost Summary.....	6
6	Transmission Owner Scope of Work.....	7
7	Transmission Owner Analysis.....	8
7.1	Power Flow Analysis.....	8
8	Interconnection Customer Requirements.....	8
8.1	System Protection.....	8
8.2	Compliance Issues and Interconnection Customer Requirements.....	9
8.3	Power Factor Requirements.....	9
9	Revenue Metering and SCADA Requirements.....	9
9.1	PJM Requirements.....	9
9.2	Meteorological Data Reporting Requirements.....	10
9.3	Interconnected Transmission Owner Requirements.....	10
10	Summer Peak - Load Flow Analysis.....	11
10.1	Generation Deliverability.....	12
10.2	Multiple Facility Contingency.....	12
10.3	Contribution to Previously Identified Overloads.....	12
10.4	Potential Congestion due to Local Energy Deliverability.....	12
10.5	System Reinforcements - Summer Peak Load Flow - Primary POI.....	15
10.6	Flow Gate Details.....	17
10.6.1	Index 1.....	18
10.6.2	Index 2.....	19
10.6.3	Index 3.....	23
10.6.4	Index 4.....	25
10.6.5	Index 5.....	27
10.6.6	Index 6.....	28
10.7	Queue Dependencies.....	29
10.8	Contingency Descriptions.....	31

11 Short Circuit Analysis.....33

12 Affected Systems.....34

 12.1 TVA.....34

 12.2 Duke Energy Progress.....34

13 Attachment 1: One Line Diagram35

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Dominion.

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed a Solar; Storage generating facility located in Hertford County, North Carolina. The installed facilities will have a total capability of 20 MW with 12 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is December 31, 2021. This study does not imply a TO commitment to this in-service date.

Queue Number	AG1-083
Project Name	AHOSKIE 34.5 KV
State	North Carolina
County	Hertford
Transmission Owner	Dominion
MFO	20
MWE	20
MWC	12
Fuel	Solar; Storage
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

AG1-083 will interconnect with the Dominion transmission system at the Ahoskie 115 kV substation.

5 Cost Summary

The AG1-083 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$ To be provided in the two-party IA with ITO
Total System Network Upgrade Costs	\$591,262,000 ¹
Total Costs	\$591,262,000

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 2016-36, 2016-25 I.R.B. (6/20/2016). If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

¹ This project currently causes and/or contributes to overloads of the Transmission System (see Summer Peak Load Flow Analysis section below) and therefore has potential to have cost allocation for the system reinforcements listed in the report. This will be re-evaluated in the System Impact phase. The results may vary with queue customers withdrawing from the queue and other generators deactivating over time. If a customer is the first to cause the need for a project (causes loading to exceed 100% of rating), then the customer is responsible. If a customer contributes to a facility that is already overloaded by a prior queue, then they may receive cost allocation.

6 Transmission Owner Scope of Work

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

7 Transmission Owner Analysis

Dominion assessed the impact of the proposed AG1-083 for compliance with NERC Reliability Criteria on the Dominion Transmission System. The system was assessed using the summer 2024 AG1 case provided to Dominion by PJM.

When performing a generation analysis, Dominion's main analysis includes load flow study results following a single contingency event for both normal and stressed system conditions. Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion's Planning Criteria and interconnection requirements can be found in the Company's Facility Connection Requirements which are publicly available at: <http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically, in Planning Studies, NERC Planning Event 3 and 6 Contingency Conditions (Loss of generator, transmission circuit, transformer, shunt device, or Single Pole of a DC line followed by the loss of a generator, transmission circuit, transformer, shunt device or single pole of a DC line) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

7.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2024 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system and no further deficiencies were identified.

8 Interconnection Customer Requirements

8.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion's "Dominion Energy Electric Transmission Generator Interconnection Requirements" documented in Dominion's Facility Interconnection Requirements "Exhibit C" located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

8.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC's GSU transformer(s).
2. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection section noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
4. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

8.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

9 Revenue Metering and SCADA Requirements

9.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

9.2 Meteorological Data Reporting Requirements

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Back Panel temperature (Fahrenheit) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Irradiance (Watts/meter²) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Ambient air temperature (Fahrenheit) - (Accepted, not required)
- Wind speed (meters/second) - (Accepted, not required)
- Wind direction (decimal degrees from true north) - (Accepted, not required)

9.3 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

10 Summer Peak - Load Flow Analysis

The Queue Project AG1-083 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection at the Ahoskie 115 kV substation in the Dominion area. Project AG1-083 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-083 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

10.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

10.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

10.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	KV	FROM BUS AREA	TO BUS#	TO BUS	KV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	ACID C	MW IMPACT
168923827	314551	3AHOSKIE	115.0	DVP	314568	3EARLEYS	115.0	DVP	1	DVP_P1-2: LN 108-A	single	141.0	182.07	190.58	DC	12.0
168923829	314551	3AHOSKIE	115.0	DVP	314568	3EARLEYS	115.0	DVP	1	DVP_P1-2: LN 140	single	141.0	137.88	144.96	DC	9.97
168923830	314551	3AHOSKIE	115.0	DVP	314568	3EARLEYS	115.0	DVP	1	Base Case	single	141.0	111.95	118.66	DC	9.47
163503870	314554	3BTLEBRO	115.0	DVP	304223	3ROCKYMT115T	115.0	CPL	1	DVP_P7-1: LN 2058-2181	tower	164.0	288.12	288.63	DC	1.83
168923915	314568	3EARLEYS	115.0	DVP	314569	6EARLEYS	230.0	DVP	2	DVP_P1-3: 6EARLEYS-TX#3	single	175.779998779	118.73	122.26	DC	6.21
168923959	314568	3EARLEYS	115.0	DVP	314569	6EARLEYS	230.0	DVP	1	DVP_P1-3: 6EARLEYS-TX#4	single	202.475997925	103.16	106.23	DC	6.22
168923847	314589	3MURPHYS	115.0	DVP	964800	AG1-343 TAP	115.0	DVP	1	Base Case	single	116.559997559	105.69	107.86	DC	2.53
168923800	964800	AG1-343 TAP	115.0	DVP	314558	3BOYKINS	115.0	DVP	1	Base Case	single	116.559997559	105.6	107.78	DC	2.53

10.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPAC T
168333837	313723	3PECAN	115.0	DVP	314559	3CAROLNA	115.0	DVP	1	DVP_P1-2: LN 68-A	operati on	224.660003662	159.15	160.65	DC	3.37
168333895	313737	3COPELDP	115.0	DVP	961850	AG1-027 TAP	115.0	DVP	1	DVP_P1-2: LN 1010	operati on	269.779998779	142.59	143.83	DC	3.36
168635047	314524	3FRNKLN	115.0	DVP	314539	3UNCAMP	115.0	DVP	1	Base Case	operati on	224.660003662	136.02	137.04	DC	2.3
168635091	314527	3HOLLAND	115.0	DVP	313737	3COPELDP	115.0	DVP	1	DVP_P1-2: LN 1010	operati on	269.779998779	146.07	147.32	DC	3.36
168923946	314539	3UNCAMP	115.0	DVP	938770	AE1-103 TAP	115.0	DVP	1	DVP_P1-2: LN 1010	operati on	224.660003662	162.04	163.54	DC	3.36
168923948	314539	3UNCAMP	115.0	DVP	938770	AE1-103 TAP	115.0	DVP	1	Base Case	operati on	224.660003662	134.79	135.82	DC	2.3
168923825	314551	3AHOSKIE	115.0	DVP	314568	3EARLEYS	115.0	DVP	1	DVP_P1-2: LN 108-A	operati on	141.0	268.94	283.13	DC	20.0
168923828	314551	3AHOSKIE	115.0	DVP	314568	3EARLEYS	115.0	DVP	1	Base Case	operati on	141.0	177.92	189.11	DC	15.78
168924004	314558	3BOYKINS	115.0	DVP	314587	3MARGT SV	115.0	DVP	1	DVP_P1-2: LN 68-B	operati on	280.119995117	134.74	135.95	DC	3.38
168923922	314561	6CAROLNA	230.0	DVP	314583	6LAKEVEW	230.0	DVP	1	DVP_P1-2: LN 246-B	operati on	375.059997559	122.79	124.08	DC	4.85
168923913	314568	3EARLEYS	115.0	DVP	314569	6EARLEYS	230.0	DVP	2	DVP_P1-3: 6EARLEYS-TX#3	operati on	175.779998779	171.17	177.06	DC	10.35
168923916	314568	3EARLEYS	115.0	DVP	314569	6EARLEYS	230.0	DVP	2	Base Case	operati on	167.414001465	103.99	107.7	DC	6.2
168923957	314568	3EARLEYS	115.0	DVP	314569	6EARLEYS	230.0	DVP	1	DVP_P1-3: 6EARLEYS-TX#4	operati on	202.475997925	148.73	153.85	DC	10.36
168923801	314569	6EARLEYS	230.0	DVP	314575	6NUCO TP	230.0	DVP	1	DVP_P1-2: LN 2092	operati on	571.520019531	257.29	258.3	DC	5.76
168923819	314575	6NUCO TP	230.0	DVP	957820	AF2-076 TAP	230.0	DVP	1	DVP_P1-2: LN 2092	operati on	571.520019531	248.62	249.62	DC	5.76
168924006	314587	3MARGT SV	115.0	DVP	314604	3SEABORD	115.0	DVP	1	DVP_P1-2: LN 68-B	operati on	280.119995117	134.49	135.7	DC	3.38
168923846	314589	3MURPHYS	115.0	DVP	964800	AG1-343 TAP	115.0	DVP	1	Base Case	operati on	116.559997559	153.02	156.64	DC	4.22
168635238	314594	6PLYMOTH	230.0	DVP	314203	6MACKES	230.0	DVP	1	DVP_P1-2: LN 246-B	operati on	789.599975586	99.81	100.27	DC	3.63
168333926	314604	3SEABORD	115.0	DVP	313723	3PECAN	115.0	DVP	1	DVP_P1-2: LN 68-B	operati on	280.119995117	132.85	134.05	DC	3.38
169555058	938770	AE1-103 TAP	115.0	DVP	314527	3HOLLAND	115.0	DVP	1	DVP_P1-2: LN 1010	operati on	224.660003662	179.59	181.09	DC	3.36
169555060	938770	AE1-103 TAP	115.0	DVP	314527	3HOLLAND	115.0	DVP	1	Base Case	operati on	224.660003662	143.62	144.65	DC	2.3
168923890	957520	AF2-046 TAP	115.0	DVP	314580	3MAPLETN	115.0	DVP	1	Base Case	operati on	142.880004883	97.67	100.63	DC	4.22
168634905	957820	AF2-076 TAP	230.0	DVP	314537	6SUFFOLK	230.0	DVP	1	DVP_P1-2: LN 2092	operati on	571.520019531	255.91	256.92	DC	5.76
169860676	961850	AG1-027 TAP	115.0	DVP	314536	3SUFFOLK	115.0	DVP	1	DVP_P1-2: LN 1010	operati on	269.779998779	187.73	188.98	DC	3.36

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC DC	MW IMPACT
168923799	964800	AG1-343 TAP	115.0	DVP	314558	3BOYKINS	115.0	DVP	1	Base Case	operation	116.559997559	152.94	156.56	DC	4.22

10.5 System Reinforcements - Summer Peak Load Flow - Primary POI

ID	Idx	Facility	Upgrade Description	Cost
168923915	3	3EARLEYS 115.0 kV - 6EARLEYS 230.0 kV Ckt 2	<u>DVP</u> dom-016 (1190) : Add additional 230/115 kV transformer at Earleys substation.	\$6,000,000
168923959	4	3EARLEYS 115.0 kV - 6EARLEYS 230.0 kV Ckt 1	Project Type : CON Cost : \$6,000,000 Time Estimate : 16-18 Months	
168923800	6	AG1-343 TAP 115.0 kV - 3BOYKINS 115.0 kV Ckt 1	<u>DVP</u> dom-418 (1644) : Reconductor 2.15 miles of 115 kV Line 108 from Boykins to AG1-343 with 768.2 ACSS 250 C. Replace Wave Trap and Breaker Switch at Boykins terminal. Project Type : FAC Cost : \$1,640,000 Time Estimate : 30-36 Months	\$1,640,000
168923829,168923830,168923827	1	3AHOSKIE 115.0 kV - 3EARLEYS 115.0 kV Ckt 1	<u>DVP</u> dom-313 (1539) : Reconductor 6.81 miles of 115 kV Line 136 from Earleys to Ahoskie with 768.2 ACSS 250 C. Replace Wave Trap, Relay (CT and Secondary CT) at Earleys terminal. Replace Line Switch and Line Lead at Ahoskie terminal. Project Type : FAC Cost : \$4,676,000 Time Estimate : 30-36 Months	\$4,676,000
168923847	5	3MURPHYS 115.0 kV - AG1-343 TAP 115.0 kV Ckt 1	<u>DVP</u> dom-319 (1545) : Reconductor 10.36 miles of 115 kV Line 108 from Murphys to AG1-343 with 768.2 ACSS 250 C. Project Type : FAC Cost : \$6,216,000 Time Estimate : 36-40 Months	\$6,216,000

ID	Idx	Facility	Upgrade Description	Cost
163503870	2	3BTLEBRO 115.0 kV - 3ROCKYMT115T 115.0 kV Ckt 1	<p><u>DVP</u> dom-007 (1179) : Build new 500 kV line between Everetts and Suffolk. Project Type : CON Cost : \$570,000,000 Time Estimate : 48-60 Months</p> <p><u>DEP</u> The external (i.e. Non-PJM) Transmission Owner, DEP, will not evaluate this violation until the impact study phase.</p> <p>Scope: Reconductor the circuit to 1590 ACSR will bring the rating to 185/205/214 MVA. Upgrading the terminal equipment at Rocky Mount will bring the rating to 301/301/301 MVA (Limited by 1590 ACSR conductor). Project Type: FAC Cost: TBD Time Estimate: 36 Months</p> <p>Note 1: Mitigations have been identified to achieve a DEP end rating of 301/301/301 MVA. However, no queue customer has yet officially agreed to construct the upgrade. Therefore, no construction plans have been put in place to date.</p> <p>Note 2: PJM is coordinating with Duke Energy Progress (DEP) and Dominion Energy (DVP) to evaluate remedies to alleviate the higher loading seen in the AG1 study on the Battleboro to Rocky Mountain 115 kV line. Reinforcements for the PJM queue project driving the need for this upgrade have been scoped while the best solution for the loading seen in AG1 is still being evaluated by both DEP and DVP.</p>	\$570,000,000
			TOTAL COST	\$591,262,000¹

10.6 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

10.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168923827	314551	3AHOSKIE	DVP	314568	3EARLEYS	DVP	1	DVP_P1-2: LN 108-A	single	141.0	182.07	190.58	DC	12.0

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314589	3MURPHYS	0.5096	80/20	0.5096
316140	AB2-099 C (Suspended)	3.4999	80/20	3.4999
943171	AE2-346 C	8.3998	80/20	8.3998
957521	AF2-046 C	99.7980	80/20	99.7980
961681	AG1-008 C	99.9980	80/20	99.9980
961931	AG1-036 C	8.0998	80/20	8.0998
961941	AG1-037 C	2.9999	80/20	2.9999
962331	AG1-082 C	11.9998	80/20	11.9998
962341	AG1-083 C	11.9998	80/20	11.9998
964801	AG1-343 C	34.9993	80/20	34.9993
CALDERWOOD	CALDERWOOD	0.0010	Confirmed LTF	0.0010
NY	NY	0.0011	Confirmed LTF	0.0011
PRAIRIE	PRAIRIE	0.0052	Confirmed LTF	0.0052
CHEOAH	CHEOAH	0.0010	Confirmed LTF	0.0010
COTTONWOOD	COTTONWOOD	0.0042	Confirmed LTF	0.0042
HAMLET	HAMLET	0.0012	Confirmed LTF	0.0012
GIBSON	GIBSON	0.0011	Confirmed LTF	0.0011
BLUEG	BLUEG	0.0035	Confirmed LTF	0.0035
TRIMBLE	TRIMBLE	0.0011	Confirmed LTF	0.0011
CATAWBA	CATAWBA	0.0007	Confirmed LTF	0.0007

10.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
163503870	314554	3BTLEBRO	DVP	304223	3ROCKYMT115T	CPL	1	DVP_P7-1: LN 2058-2181	tower	164.0	288.12	288.63	DC	1.83

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
313506	AB1-173 C OP	3.1181	Adder	3.67
313719	3CHESTNUT	2.4261	50/50	2.4261
314541	3WATKINS	0.2172	Adder	0.26
314572	3EMPORIA	0.1704	Adder	0.2
314582	3KELFORD	0.3112	50/50	0.3112
314623	3WITAKRS	0.5240	50/50	0.5240
315126	1ROARAP2	0.8712	50/50	0.8712
315128	1ROARAP4	0.8314	50/50	0.8314
315131	1EDGEEMA (Deactivation : 22/04/2019)	12.5808	50/50	12.5808
315132	1EDGEEMB (Deactivation : 22/04/2019)	12.5808	50/50	12.5808
315136	1ROSEMG1	1.5086	50/50	1.5086
315137	1ROSEMS1	0.9355	50/50	0.9355
315138	1ROSEMG2	0.7070	50/50	0.7070
315139	1GASTONA	1.9383	50/50	1.9383
315141	1GASTONB	1.9383	50/50	1.9383
315293	1DOMTR9	2.0513	Adder	2.41
315294	1DOMTR10	2.5139	Adder	2.96
315601	1CONETOE2SOL	1.1895	50/50	1.1895
315606	3AA2-053SOLA	0.9246	50/50	0.9246
316020	AB2-059 C OP	4.4268	50/50	4.4268
316088	AB2-174 E	2.8075	Adder	3.3
316097	AB2-100 E1	1.0834	Adder	1.27
316099	AB2-100 E2	1.0834	Adder	1.27
316103	AB2-015 C	2.5912	Adder	3.05
316104	AB2-015 E	2.1248	Adder	2.5
316129	AC1-054 C	2.5555	Adder	3.01
316140	AB2-099 C (Suspended)	0.2729	Adder	0.32
316141	AB2-099 E (Suspended)	0.1170	Adder	0.14
900672	V4-068 E	0.1280	Adder	0.15
917332	Z2-043 E	0.9284	50/50	0.9284
917342	Z2-044 E	1.4235	50/50	1.4235
917512	Z2-088 E OP1	7.0561	50/50	7.0561
918492	AA1-063AE OP	2.0088	Adder	2.36
918512	AA1-065 E OP	1.4796	Adder	1.74
918532	AA1-067 E	0.2544	Adder	0.3
919692	AA2-053 E OP	2.4062	50/50	2.4062
919702	AA2-057 E OP	7.2586	50/50	7.2586
920042	AA2-088 E OP	4.1496	Adder	4.88
920591	AA2-165 C	0.3257	50/50	0.3257

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
920592	AA2-165 E	0.9976	50/50	0.9976
922922	AB1-081 C OP	3.7561	50/50	3.7561
922923	AB1-081 E OP	10.2031	50/50	10.2031
923262	AB1-132 C OP (Suspended)	9.3820	50/50	9.3820
923263	AB1-132 E OP (Suspended)	4.0208	50/50	4.0208
923573	AB1-173 E OP	0.4862	Adder	0.57
923991	AB2-040 C O1	3.3959	Adder	4.0
923992	AB2-040 E O1	2.7785	Adder	3.27
924152	AB2-059 E OP	14.4544	50/50	14.4544
925122	AB2-169 E	1.8344	Adder	2.16
925591	AC1-034 C	18.1743	50/50	18.1743
925592	AC1-034 E	13.7104	50/50	13.7104
925785	AC1-054 E	1.1772	Adder	1.38
926070	AC1-086 C	13.8161	50/50	13.8161
926071	AC1-086 E	6.2881	50/50	6.2881
926201	AC1-098 C	8.8191	50/50	8.8191
926202	AC1-098 E	5.2539	50/50	5.2539
926211	AC1-099 C	2.9553	50/50	2.9553
926212	AC1-099 E	1.7357	50/50	1.7357
927024	AC1-189 C	6.2804	50/50	6.2804
927025	AC1-189 E	3.1284	50/50	3.1284
927145	AC1-208 C	14.0422	50/50	14.0422
927146	AC1-208 E	6.2100	50/50	6.2100
932631	AC2-084 C	12.5719	50/50	12.5719
932632	AC2-084 E	6.1921	50/50	6.1921
933991	AD1-023 C	4.0327	Adder	4.74
933992	AD1-023 E	2.1954	Adder	2.58
934331	AD1-057 C O1	10.5448	50/50	10.5448
934332	AD1-057 E O1	5.6251	50/50	5.6251
936401	AD2-051 C O1	3.2781	Adder	3.86
936402	AD2-051 E O1	1.4076	Adder	1.66
938222	AE1-035 E	0.4069	Adder	0.48
940571	AE2-044 C	11.9036	50/50	11.9036
940572	AE2-044 E	5.1016	50/50	5.1016
941542	AE2-151 E (Withdrawn : 01/08/2021)	0.2794	Adder	0.33
942471	AE2-260 C O1	5.1280	Adder	6.03
942472	AE2-260 E O1	7.2735	Adder	8.56
943171	AE2-346 C	0.6550	Adder	0.77
943172	AE2-346 E	0.2807	Adder	0.33
944141	AF1-082	7.6523	50/50	7.6523
946281	AF1-292 C	0.5743	Adder	0.68
946282	AF1-292 E	0.3872	Adder	0.46
957521	AF2-046 C	7.3234	Adder	8.62
957522	AF2-046 E	3.6837	Adder	4.33
957861	AF2-080 C	5.7041	50/50	5.7041
957862	AF2-080 E	2.5286	50/50	2.5286
959511	AF2-242 C	2.4228	Adder	2.85
959512	AF2-242 E	1.8844	Adder	2.22
960081	AF2-299 C	0.9680	Adder	1.14
960082	AF2-299 E	0.6453	Adder	0.76

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
961091	AF2-400 C	0.1399	Adder	0.16
961092	AF2-400 E	0.2296	Adder	0.27
961671	AG1-007 C	1.2437	50/50	1.2437
961672	AG1-007 E	0.6945	50/50	0.6945
961681	AG1-008 C	3.8892	Adder	8.63
961682	AG1-008 E	1.9446	Adder	4.32
961931	AG1-036 C	0.3255	Adder	0.72
961932	AG1-036 E	0.2170	Adder	0.48
961941	AG1-037 C	0.1240	Adder	0.28
961942	AG1-037 E	0.0826	Adder	0.18
962331	AG1-082 C	0.4959	Adder	1.1
962332	AG1-082 E	0.3306	Adder	0.73
962341	AG1-083 C	0.4959	Adder	1.1
962342	AG1-083 E	0.3306	Adder	0.73
962351	AG1-084 C	0.4442	Adder	0.99
962352	AG1-084 E	0.2961	Adder	0.66
962361	AG1-085 C	0.4442	Adder	0.99
962362	AG1-085 E	0.2961	Adder	0.66
962571	AG1-106 C	3.8421	50/50	3.8421
962572	AG1-106 E	1.7424	50/50	1.7424
964491	AG1-312 C O1	3.5814	Adder	7.95
964492	AG1-312 E O1	0.8953	Adder	1.99
964501	AG1-313 C O1	2.8627	50/50	2.8627
964502	AG1-313 E O1	1.9084	50/50	1.9084
964801	AG1-343 C	1.2896	Adder	2.86
964802	AG1-343 E	1.0133	Adder	2.25
965291	AG1-394 C	0.4384	Adder	0.97
965292	AG1-394 E	0.2923	Adder	0.65
965691	AG1-437 C O1	1.7375	Adder	3.86
965692	AG1-437 E O1	1.1583	Adder	2.57
965701	AG1-438 C O1	1.7375	Adder	3.86
965702	AG1-438 E O1	1.1583	Adder	2.57
965711	AG1-439 C O1	21.3390	50/50	21.3390
965712	AG1-439 E O1	14.2260	50/50	14.2260
965741	AG1-442 O1	1.0135	Adder	2.25
965751	AG1-443 O1	1.0135	Adder	2.25
965761	AG1-444 O1	11.3808	50/50	11.3808
966621	AG1-532 C	0.2770	Adder	0.61
966622	AG1-532 E	0.1847	Adder	0.41
966751	AG1-546 C	3.1668	Adder	7.03
966752	AG1-546 E	1.6992	Adder	3.77
966801	AG1-551 C	0.4089	Adder	0.91
966802	AG1-551 E	0.1753	Adder	0.39
966811	AG1-552 C	1.3832	50/50	1.3832
966812	AG1-552 E	0.5928	50/50	0.5928
G-007A	G-007A	0.4867	Confirmed LTF	0.4867
VFT	VFT	1.2964	Confirmed LTF	1.2964
CALDERWOOD	CALDERWOOD	0.7087	Confirmed LTF	0.7087
PRAIRIE	PRAIRIE	2.4719	Confirmed LTF	2.4719
CHEOAH	CHEOAH	0.7262	Confirmed LTF	0.7262
CBM-N	CBM-N	0.2340	Confirmed LTF	0.2340
COTTONWOOD	COTTONWOOD	2.6313	Confirmed LTF	2.6313

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
HAMLET	HAMLET	1.5263	Confirmed LTF	1.5263
GIBSON	GIBSON	0.4390	Confirmed LTF	0.4390
BLUEG	BLUEG	1.3558	Confirmed LTF	1.3558
TRIMBLE	TRIMBLE	0.4307	Confirmed LTF	0.4307
CATAWBA	CATAWBA	0.7581	Confirmed LTF	0.7581

10.6.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168923915	314568	3EARLEYS	DVP	314569	6EARLEYS	DVP	2	DVP_P1-3: 6EARLEYS-TX#3	single	175.78	118.73	122.26	DC	6.21

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
313506	AB1-173 C OP	2.8357	80/20	2.8357
313719	3CHESTNUT	0.7616	80/20	0.7616
314582	3KELFORD	0.9905	80/20	0.9905
314589	3MURPHYS	0.1590	80/20	0.1590
314623	3WITAKRS	0.0972	80/20	0.0972
315115	1S HAMPT1	1.0912	80/20	1.0912
315126	1ROARAP2	0.8570	80/20	0.8570
315128	1ROARAP4	0.8178	80/20	0.8178
315606	3AA2-053SOLA	1.6715	80/20	1.6715
315607	3AA1-063SOLA	1.1232	80/20	1.1232
315608	3AA2-088SOLA	1.0808	80/20	1.0808
316087	AB2-174 C	0.4137	80/20	0.4137
316103	AB2-015 C	5.8060	80/20	5.8060
316129	AC1-054 C	3.1960	80/20	3.1960
316140	AB2-099 C (Suspended)	1.8114	80/20	1.8114
920591	AA2-165 C	0.1022	80/20	0.1022
923991	AB2-040 C O1	3.0884	80/20	3.0884
926201	AC1-098 C	9.2342	80/20	9.2342
926211	AC1-099 C	3.0944	80/20	3.0944
927145	AC1-208 C	8.4058	80/20	8.4058
932631	AC2-084 C	13.1636	80/20	13.1636
938771	AE1-103 C	1.7850	80/20	1.7850
941541	AE2-151 C (Withdrawn : 01/08/2021)	0.6001	80/20	0.6001
943171	AE2-346 C	4.3473	80/20	4.3473
957521	AF2-046 C	34.9879	80/20	34.9879
961091	AF2-400 C	0.3135	80/20	0.3135
961681	AG1-008 C	35.0580	80/20	35.0580
961931	AG1-036 C	3.5583	80/20	3.5583
961941	AG1-037 C	1.5526	80/20	1.5526
962331	AG1-082 C	6.2105	80/20	6.2105
962341	AG1-083 C	6.2105	80/20	6.2105
962351	AG1-084 C	6.1440	80/20	6.1440
962361	AG1-085 C	6.1440	80/20	6.1440
964501	AG1-313 C O1	8.0106	80/20	8.0106
964801	AG1-343 C	7.3500	80/20	7.3500
965291	AG1-394 C	2.2658	80/20	2.2658
965721	AG1-440 C	2.4102	80/20	2.4102
965731	AG1-441 C	2.4102	80/20	2.4102
965771	AG1-445	1.3926	80/20	1.3926
965781	AG1-446	1.3926	80/20	1.3926

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
966751	AG1-546 C	7.3830	80/20	7.3830
966811	AG1-552 C	1.3607	80/20	1.3607
WEC	WEC	0.0110	Confirmed LTF	0.0110
LGEE	LGEE	0.0239	Confirmed LTF	0.0239
CPL	CPL	0.0969	Confirmed LTF	0.0969
CBM-W2	CBM-W2	0.4928	Confirmed LTF	0.4928
NY	NY	0.0343	Confirmed LTF	0.0343
TVA	TVA	0.0952	Confirmed LTF	0.0952
SIGE	SIGE	0.0114	Confirmed LTF	0.0114
CBM-S2	CBM-S2	1.3676	Confirmed LTF	1.3676
CBM-S1	CBM-S1	0.0239	Confirmed LTF	0.0239
MEC	MEC	0.0667	Confirmed LTF	0.0667
LAGN	LAGN	0.1155	Confirmed LTF	0.1155
CBM-W1	CBM-W1	0.4486	Confirmed LTF	0.4486

10.6.4 Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168923959	314568	3EARLEYS	DVP	314569	6EARLEYS	DVP	1	DVP_P1-3: 6EARLEYS-TX#4	single	202.48	103.16	106.23	DC	6.22

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
313506	AB1-173 C OP	2.8389	80/20	2.8389
313719	3CHESTNUT	0.7625	80/20	0.7625
314582	3KELFORD	0.9917	80/20	0.9917
314589	3MURPHYS	0.1592	80/20	0.1592
314623	3WITAKRS	0.0973	80/20	0.0973
315115	1S HAMPT1	1.0924	80/20	1.0924
315126	1ROARAP2	0.8579	80/20	0.8579
315128	1ROARAP4	0.8187	80/20	0.8187
315606	3AA2-053SOLA	1.6734	80/20	1.6734
315607	3AA1-063SOLA	1.1244	80/20	1.1244
315608	3AA2-088SOLA	1.0820	80/20	1.0820
316087	AB2-174 C	0.4142	80/20	0.4142
316103	AB2-015 C	5.8125	80/20	5.8125
316129	AC1-054 C	3.1996	80/20	3.1996
316140	AB2-099 C (Suspended)	1.8134	80/20	1.8134
920591	AA2-165 C	0.1024	80/20	0.1024
923991	AB2-040 C O1	3.0919	80/20	3.0919
926201	AC1-098 C	9.2447	80/20	9.2447
926211	AC1-099 C	3.0980	80/20	3.0980
927145	AC1-208 C	8.4153	80/20	8.4153
932631	AC2-084 C	13.1786	80/20	13.1786
938771	AE1-103 C	1.7869	80/20	1.7869
941541	AE2-151 C (Withdrawn : 01/08/2021)	0.6008	80/20	0.6008
943171	AE2-346 C	4.3522	80/20	4.3522
957521	AF2-046 C	35.0268	80/20	35.0268
961091	AF2-400 C	0.3139	80/20	0.3139
961681	AG1-008 C	35.0970	80/20	35.0970
961931	AG1-036 C	3.5624	80/20	3.5624
961941	AG1-037 C	1.5544	80/20	1.5544
962331	AG1-082 C	6.2174	80/20	6.2174
962341	AG1-083 C	6.2174	80/20	6.2174
962351	AG1-084 C	6.1509	80/20	6.1509
962361	AG1-085 C	6.1509	80/20	6.1509
964501	AG1-313 C O1	8.0195	80/20	8.0195
964801	AG1-343 C	7.3584	80/20	7.3584
965291	AG1-394 C	2.2684	80/20	2.2684
965721	AG1-440 C	2.4129	80/20	2.4129
965731	AG1-441 C	2.4129	80/20	2.4129
965771	AG1-445	1.3941	80/20	1.3941
965781	AG1-446	1.3941	80/20	1.3941

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
966751	AG1-546 C	7.3918	80/20	7.3918
966811	AG1-552 C	1.3622	80/20	1.3622
WEC	WEC	0.0110	Confirmed LTF	0.0110
LGEE	LGEE	0.0239	Confirmed LTF	0.0239
CPL	CPL	0.0969	Confirmed LTF	0.0969
CBM-W2	CBM-W2	0.4928	Confirmed LTF	0.4928
NY	NY	0.0343	Confirmed LTF	0.0343
TVA	TVA	0.0952	Confirmed LTF	0.0952
SIGE	SIGE	0.0114	Confirmed LTF	0.0114
CBM-S2	CBM-S2	1.3676	Confirmed LTF	1.3676
CBM-S1	CBM-S1	0.0239	Confirmed LTF	0.0239
MEC	MEC	0.0667	Confirmed LTF	0.0667
LAGN	LAGN	0.1155	Confirmed LTF	0.1155
CBM-W1	CBM-W1	0.4486	Confirmed LTF	0.4486

10.6.5 Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168923847	314589	3MURPHYS	DVP	964800	AG1-343 TAP	DVP	1	Base Case	single	116.56	105.69	107.86	DC	2.53

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314582	3KELFORD	0.1546	80/20	0.1546
314589	3MURPHYS	0.2851	80/20	0.2851
316140	AB2-099 C (Suspended)	0.7384	80/20	0.7384
941541	AE2-151 C (Withdrawn : 01/08/2021)	0.0988	80/20	0.0988
943171	AE2-346 C	1.7721	80/20	1.7721
957521	AF2-046 C	49.3142	80/20	49.3142
961091	AF2-400 C	-0.3384	Adder	-0.4
961681	AG1-008 C	49.4130	80/20	49.4130
961931	AG1-036 C	2.7836	80/20	2.7836
961941	AG1-037 C	0.6329	80/20	0.6329
962331	AG1-082 C	2.5315	80/20	2.5315
962341	AG1-083 C	2.5315	80/20	2.5315
962351	AG1-084 C	1.0111	80/20	1.0111
962361	AG1-085 C	1.0111	80/20	1.0111
WEC	WEC	0.0186	Confirmed LTF	0.0186
LGEE	LGEE	0.0371	Confirmed LTF	0.0371
CPL	CPL	0.1931	Confirmed LTF	0.1931
CBM-W2	CBM-W2	0.7526	Confirmed LTF	0.7526
NY	NY	0.0050	Confirmed LTF	0.0050
TVA	TVA	0.1372	Confirmed LTF	0.1372
SIGE	SIGE	0.0081	Confirmed LTF	0.0081
CBM-S2	CBM-S2	2.0567	Confirmed LTF	2.0567
CBM-S1	CBM-S1	0.0346	Confirmed LTF	0.0346
MEC	MEC	0.1065	Confirmed LTF	0.1065
LAGN	LAGN	0.1715	Confirmed LTF	0.1715
CBM-W1	CBM-W1	0.7851	Confirmed LTF	0.7851

10.6.6 Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168923800	964800	AG1-343 TAP	DVP	314558	3BOYKINS	DVP	1	Base Case	single	116.56	105.6	107.78	DC	2.53

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314582	3KELFORD	0.1546	80/20	0.1546
314589	3MURPHYS	0.2851	80/20	0.2851
316140	AB2-099 C (Suspended)	0.7384	80/20	0.7384
941541	AE2-151 C (Withdrawn : 01/08/2021)	0.0988	80/20	0.0988
943171	AE2-346 C	1.7721	80/20	1.7721
957521	AF2-046 C	49.3142	80/20	49.3142
961091	AF2-400 C	-0.3384	Adder	-0.4
961681	AG1-008 C	49.4130	80/20	49.4130
961931	AG1-036 C	2.7836	80/20	2.7836
961941	AG1-037 C	0.6329	80/20	0.6329
962331	AG1-082 C	2.5315	80/20	2.5315
962341	AG1-083 C	2.5315	80/20	2.5315
962351	AG1-084 C	1.0111	80/20	1.0111
962361	AG1-085 C	1.0111	80/20	1.0111
964801	AG1-343 C	25.6393	80/20	25.6393
WEC	WEC	0.0186	Confirmed LTF	0.0186
LGEE	LGEE	0.0371	Confirmed LTF	0.0371
CPL	CPL	0.1931	Confirmed LTF	0.1931
CBM-W2	CBM-W2	0.7526	Confirmed LTF	0.7526
NY	NY	0.0050	Confirmed LTF	0.0050
TVA	TVA	0.1372	Confirmed LTF	0.1372
SIGE	SIGE	0.0081	Confirmed LTF	0.0081
CBM-S2	CBM-S2	2.0567	Confirmed LTF	2.0567
CBM-S1	CBM-S1	0.0346	Confirmed LTF	0.0346
MEC	MEC	0.1065	Confirmed LTF	0.1065
LAGN	LAGN	0.1715	Confirmed LTF	0.1715
CBM-W1	CBM-W1	0.7851	Confirmed LTF	0.7851

10.7 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AA1-063	Huntsville (Cabin Creek) 69kV	Withdrawn
AA1-063A	Carolina–Seaboard 115kV	In Service
AA1-065	Earleys 230kV	In Service
AA1-067	Everetts 34.5kV	In Service
AA2-053	Carolina-Jackson 115kV	In Service
AA2-057	Hornertown-Whitakers 115kV	In Service
AA2-088	Boykins-Handsome 115kV	In Service
AA2-165	Hornertown-Whitakers 115kV	In Service
AB1-081	Anaconda-Mayo Dunbar 115kV	In Service
AB1-132	Thelma 230kV	Suspended
AB1-173	Brink-Trego 115kV	Engineering and Procurement
AB2-015	Franklin 115kV	Engineering and Procurement
AB2-040	Brink 115kV	Engineering and Procurement
AB2-059	Benson-Dunbar 115kV	Partially in Service - Under Construction
AB2-099	Ahoskie 34.5kV	Suspended
AB2-100	Clubhouse-Lakeview 230kV	Under Construction
AB2-169	Pantago-Five Points 115kV	Partially in Service - Under Construction
AB2-174	Emporia-Trego 115kV	In Service
AC1-034	Heartsease DP - Mayo Dunbar 115kV	Engineering and Procurement
AC1-054	Kerr Dam–Eatons Ferry 115 kV	Engineering and Procurement
AC1-086	Thelma 230kV	Active
AC1-098	Dawson-South Justice 115kV	Engineering and Procurement
AC1-099	Dawson-South Justice 115kV	Engineering and Procurement
AC1-189	Chinquapin-Everetts 230kV	Active
AC1-208	Cox-Whitakers 115kV	Engineering and Procurement
AC2-084	Dawson-South Justice 115kV	Active
AD1-023	Cashie-Trowbridge 230 kV	Active
AD1-057	Hornertown-Hathaway 230 kV	Active
AD2-051	Earleys – Northampton 230kV	Active
AE1-035	Earleys 230 kV	Partially in Service - Under Construction
AE1-103	Holland-Union Camp 115 kV	Active
AE2-044	Anaconda-Dunbar 115 kV	Active
AE2-151	Earleys 34.5kV	Withdrawn
AE2-260	Clubhouse 230 kV	Active
AE2-346	Ahoskie 34.5 kV	Active
AF1-082	Heartsease-Mayo Dunbar DP	Active
AF1-292	Fields 34.5kV	Active
AF2-046	Tunis-Mapleton 115 kV	Active
AF2-080	Chinquapin-Everetts 230 kV	Active
AF2-242	Wharton 115 kV	Active
AF2-299	Fields 34.5 kV	Active
AF2-400	Franklin 13.2 kV	Engineering and Procurement
AG1-007	Tar River 12.5 kV	Active

Queue Number	Project Name	Status
AG1-008	Tunis-Mapleton 115 kV	Active
AG1-036	Tunis 34.5 kV	Active
AG1-037	Earlys 34.5 kV	Active
AG1-082	Ahoskie 34.5 kV	Active
AG1-083	Ahoskie 34.5 kV	Active
AG1-084	Earlys 34.5 kV	Active
AG1-085	Earlys 34.5	Active
AG1-106	Thelma 230 kV	Active
AG1-312	Earleys-Cashie 230 kV	Active
AG1-313	Jackson DP-Occoneechee 115 kV	Active
AG1-343	Boykins-Murphy 115 kV	Active
AG1-394	Boykins 34.5 kV	Active
AG1-437	Cashie-Earleys 230 kV	Active
AG1-438	Cashie-Earleys 230 kV	Active
AG1-439	Chinquapin 230 kV	Active
AG1-440	Palmer Springs 115 kV	Active
AG1-441	Palmer Springs 115 kV	Active
AG1-442	Cashie-Earleys 230 kV	Active
AG1-443	Cashie-Earleys 230 kV	Active
AG1-444	Chinquapin 230 kV	Active
AG1-445	Palmer Spring 115 kV	Active
AG1-446	Palmer Springs 115 kV	Active
AG1-532	Fields 34.5 kV	Active
AG1-546	Ebony-Elams Road 115 kV	Active
AG1-551	Parmele 12.5 kV	Active
AG1-552	Carolina 13.2 kV	Active
V4-068	Murphy's 34.5kV	In Service
Z2-043	Kelford 34.5kV	In Service
Z2-044	Whitakers 34.5kV	In Service
Z2-088	Tarboro-Everetts 230kV	In Service

10.8 Contingency Descriptions

Contingency Name	Contingency Definition
DVP_P1-2: LN 246-B	CONTINGENCY 'DVP_P1-2: LN 246-B' OPEN BRANCH FROM BUS 957820 TO BUS 314575 CKT 1 /* AF2-076 230.00 - 6NUCO TP 230.00 OPEN BRANCH FROM BUS 314569 TO BUS 314575 CKT 1 /* 6EARLEYS 230.00 - 6NUCO TP 230.00 OPEN BRANCH FROM BUS 314575 TO BUS 314590 CKT 1 /* 6NUCO TP 230.00 - 6NUCOR 230.00 OPEN BUS 314575 /* ISLAND: 6NUCO TP 230.00 OPEN BUS 314590 /* ISLAND: 6NUCOR 230.00 END
DVP_P1-3: 6EARLEYS-TX#3	CONTINGENCY 'DVP_P1-3: 6EARLEYS-TX#3' OPEN BRANCH FROM BUS 314568 TO BUS 314569 CKT 1 /* 3EARLEYS 115.00 - 6EARLEYS 230.00 END
DVP_P1-2: LN 108-A	CONTINGENCY 'DVP_P1-2: LN 108-A' OPEN BRANCH FROM BUS 314558 TO BUS 964800 CKT 1 /* 3BOYKINS 115.00 - AG1-343 TAP 115.00 END
DVP_P1-2: LN 1010	CONTINGENCY 'DVP_P1-2: LN 1010' OPEN BRANCH FROM BUS 313723 TO BUS 314559 CKT 1 /* 3PECAN 115.00 - 3CAROLNA 115.00 OPEN BRANCH FROM BUS 314559 TO BUS 314835 CKT 1 /* 3CAROLNA 115.00 - 3CAROL_1 115.00 OPEN BUS 314835 /* ISLAND: 3CAROL_1 115.00 END
DVP_P1-2: LN 2092	CONTINGENCY 'DVP_P1-2: LN 2092' OPEN BRANCH FROM BUS 313714 TO BUS 314662 CKT 1 /* 6PERQUIMANS 230.00 - 6S HERTFORD 230.00 OPEN BRANCH FROM BUS 314651 TO BUS 314662 CKT 1 /* 6WINFALL 230.00 - 6S HERTFORD 230.00 OPEN BUS 314662 /* ISLAND: 6S HERTFORD 230.00 END
DVP_P1-2: LN 140	CONTINGENCY 'DVP_P1-2: LN 140' OPEN BRANCH FROM BUS 313720 TO BUS 314526 CKT 1 /* 3NEWSOMS 115.00 - 3HANDSOM 115.00 OPEN BRANCH FROM BUS 314526 TO BUS 314534 CKT 1 /* 3HANDSOM 115.00 - 3SHAMPT 115.00 OPEN BUS 314526 /* ISLAND: 3HANDSOM 115.00 END

Contingency Name	Contingency Definition
DVP_P1-2: LN 68-B	CONTINGENCY 'DVP_P1-2: LN 68-B' OPEN BRANCH FROM BUS 961850 TO BUS 314536 CKT 1 /* 3COPELD DP 115.00 - 3SUFFOLK 115.00 END
DVP_P1-2: LN 68-A	CONTINGENCY 'DVP_P1-2: LN 68-A' OPEN BRANCH FROM BUS 313737 TO BUS 314527 CKT 1 /* 3COPELD DP 115.00 - 3HOLLAND 115.00 OPEN BRANCH FROM BUS 313737 TO BUS 961850 CKT 1 /* 3COPELD DP 115.00 - 3SUFFOLK 115.00 OPEN BRANCH FROM BUS 314527 TO BUS 938770 CKT 1 /* 3HOLLAND 115.00 - AE1- 103 TAP 115.00 OPEN BUS 313737 /* ISLAND: 3COPELD DP 115.00 OPEN BUS 314527 /* ISLAND: 3HOLLAND 115.00 END
Base Case	
DVP_P1-3: 6EARLEYS-TX#4	CONTINGENCY 'DVP_P1-3: 6EARLEYS-TX#4' OPEN BRANCH FROM BUS 314568 TO BUS 314569 CKT 2 /* 3EARLEYS 115.00 - 6EARLEYS 230.00 END
DVP_P7-1: LN 2058-2181	CONTINGENCY 'DVP_P7-1: LN 2058-2181' /* . OPEN BRANCH FROM BUS 304222 TO BUS 313845 CKT 1 /* 6ROCKYMT230T230.00 - 6HATHAWAY 230.00 OPEN BRANCH FROM BUS 313844 TO BUS 313845 CKT 2 /* 3HATHAWAY 115.00 - 6HATHAWAY 230.00 OPEN BUS 304226 /* ISLAND: 6PA-RMOUNT#4115.00 OPEN BRANCH FROM BUS 304226 TO BUS 314591 CKT 1 /* 6PA-RMOUNT#4230.00 - 6NASH 230.00 OPEN BRANCH FROM BUS 313845 TO BUS 314591 CKT 1 /* 6HATHAWAY 230.00 - 6NASH 230.00 OPEN BUS 314591 /* ISLAND: 6NASH 230.00 END

11 Short Circuit Analysis

The following Breakers are overdutied:

None

12 Affected Systems

12.1 TVA

TVA Impacts to be determined during later study phases (as applicable).

12.2 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

13 Attachment 1: One Line Diagram