



**Generation Interconnection
Feasibility Study Report
for
Queue Project AG1-134
KINGS DOMINION DP 115 KV
60 MW Capacity / 100 MW Energy**

January 2021

Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	6
4	Point of Interconnection.....	7
4.1	Primary Point of Interconnection	7
4.2	Secondary Point of Interconnection.....	7
5	Cost Summary	7
6	Transmission Owner Scope of Work.....	8
7	Schedule.....	10
8	Transmission Owner Analysis.....	10
8.1	Power Flow Analysis	10
9	Interconnection Customer Requirements.....	11
9.1	System Protection.....	11
9.2	Compliance Issues and Interconnection Customer Requirements	11
9.3	Power Factor Requirements.....	11
10	Revenue Metering and SCADA Requirements	12
10.1	PJM Requirements	12
10.2	Meteorological Data Reporting Requirements	12
10.3	Interconnected Transmission Owner Requirements.....	12
11	Summer Peak - Load Flow Analysis	13
11.1	Generation Deliverability	14
11.2	Multiple Facility Contingency	14
11.3	Contribution to Previously Identified Overloads.....	14
11.4	Potential Congestion due to Local Energy Deliverability.....	15
11.5	System Reinforcements - Summer Peak Load Flow - Primary POI.....	17
11.6	Flow Gate Details.....	19
11.6.1	Index 1	20
11.6.2	Index 2	21
11.6.3	Index 3	22
11.6.4	Index 4	24
11.6.5	Index 5	26

11.6.6	Index 6	28
11.6.7	Index 7	30
11.6.8	Index 8	32
11.6.9	Index 9	37
11.7	Queue Dependencies	42
11.8	Contingency Descriptions.....	46
12	Short Circuit Analysis.....	48
12.1	System Reinforcements - Short Circuit.....	48
13	Affected Systems	49
13.1	TVA.....	49
13.2	Duke Energy Progress.....	49
14	Attachment 1: One Line Diagram	50

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Dominion.

The AG1-134 customer will be an interconnection to Rappahannock Electric Cooperative (REC) facilities. The Interconnection Customer (IC) will need to coordinate with REC for scope, cost and schedule for this physical interconnection. This PJM report identifies the effects on the transmission system. AG1-134 will interconnect within the Rappahannock Electric Cooperative (REC) system which interconnects with the Dominion transmission system at Kings Dominion DP 115 kV.

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real

estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in King William County, Virginia. The installed facilities will have a total capability of 100 MW with 60 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is December 01, 2024. This study does not imply a TO commitment to this in-service date.

Final attachment facilities and local upgrades (if required) along with terms and conditions to interconnect AG1-134 will be specified in a separate two party Interconnection Agreement (IA) between REC and the Interconnection Customer as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT).

From the transmission perspective, the impacts are were analyzed and detailed in the “Network Impacts” section below.

Queue Number	AG1-134
Project Name	KINGS DOMINION DP 115 KV
State	Virginia
County	King William
Transmission Owner	Dominion – REC connection
MFO	100
MWE	100
MWC	60
Fuel	Solar
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

4.1 Primary Point of Interconnection

AG1-134 "Kings Dominion DP 115 kV" will interconnect within the Rappahannock Electric Cooperative (REC) system which interconnects with the Dominion transmission system at Kings Dominion DP 115 kV.

Attachment 1 shows a one-line diagram of the proposed interconnection facilities.

4.2 Secondary Point of Interconnection

There is no secondary point of interconnection specified for AG1-134.

5 Cost Summary

The costs associated with interconnecting AG1-134 to the Rappahannock Electric Cooperative (REC) system will be documented in the two-party Interconnection Agreement between the IC and Rappahannock Electric Cooperative (REC).

The AG1-134 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$7,600,000 + Costs from REC To be provided in the Interconnection Agreement
Total System Network Upgrade Costs	\$97,422,500 ¹
Total Costs	\$105,022,500

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 2016-36, 2016-25 I.R.B. (6/20/2016). If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

¹ This project currently causes and/or contributes to overloads of the Transmission System (see Summer Peak Load Flow Analysis section below) and therefore has potential to have cost allocation for the system reinforcements listed in the report. This will be re-evaluated in the System Impact phase. The results may vary with queue customers withdrawing from the queue and other generators deactivating over time. If a customer is the first to cause the need for a project (causes loading to exceed 100% of rating), then the customer is responsible. If a customer contributes to a facility that is already overloaded by a prior queue, then they may receive cost allocation.

6 Transmission Owner Scope of Work

The required Attachment Facilities, Direct Connection and Non-Direct Connection work for the interconnection of AG1-134 to the Dominion Transmission System is detailed in the following sections. The associated one-line showing the generation project attachment facilities and primary direct and non-direct connection is shown in Attachment 1.

Note that the ITO findings were made from a conceptual review of this project. A more detailed review of the connection facilities and their cost will be identified in a future study phase. Further note that the cost estimate data contained in this document should be considered high level estimates since it was produced without a detailed engineering review. The applicant will be responsible for the actual cost of construction. ITO herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any reinforcements to the transmission systems.

The total physical interconnection costs is given in the table below:

Description	Total Cost
<i>Attachment Facilities</i>	\$500,000
<i>115 kV Three Breaker Ring-Bus Substation</i>	\$5,500,000
<i>Re-arrange line and tie-in new substation</i>	\$1,600,000
REC Interconnection Work	Interconnection Customer to contact REC
Total Physical Interconnection Costs	\$7,600,000 + Costs from REC to be determined

AG1-134 "Kings Dominion DP 115 kV" will interconnect within the Rappahannock Electric Cooperative (REC) system which interconnects with the Dominion transmission system at Kings Dominion DP 115 kV.

These costs are dependent on the interconnection of AD1-105 which is proposing to interconnect on the same REC transmission line. This AD1-105 interconnection may result in the construction of a new three breaker ring bus at Kings Dominion Delivery Point. Should the AD1-105 project withdraw from the Interconnection Queue, the AG1-134 project will assume the Attachment, Direct Connection, and Non-Direct Connection costs identified in the table above for connection to the Dominion system. If the AD1-105 project does not withdraw from the Interconnection Queue, the associated interconnection costs for this project as identified in the table above would require modification.

It is estimated to take 18-30 months to complete this work upon execution of an Interconnection Construction Service Agreement (ICSA). These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase.

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and

interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

7 Schedule

The estimated schedule for the Attachment Facilities, Direct Connection and Non-Direct Connection work will be identified by REC and included in the Interconnection Agreement between Dominion and REC.

The estimated schedule for the required Network Impact Reinforcements is identified in the “System Reinforcements” section of this report.

These schedules will be more clearly identified in future study phases.

If the customer is ultimately responsible for network upgrades, then the schedule for those upgrades will be refined in future study phases. The customer would need to wait for those upgrades to be completed prior to commercial operation unless determined deliverable by an interim deliverability study. The elapsed time to complete any network upgrades is provided in the System Reinforcements table of this report¹.

8 Transmission Owner Analysis

Dominion assessed the impact of the proposed project for compliance with NERC Reliability Criteria on the Dominion Transmission System. The system was assessed using the summer 2024 AG1 case provided to Dominion by PJM.

When performing a generation analysis, Dominion’s main analysis includes load flow study results following a single contingency event for both normal and stressed system conditions. Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion’s Planning Criteria and interconnection requirements can be found in the Company’s Facility Connection Requirements which are publicly available at: <http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically, in Planning Studies, NERC Planning Event 3 and 6 Contingency Conditions (Loss of generator, transmission circuit, transformer, shunt device, or Single Pole of a DC line followed by the loss of a generator, transmission circuit, transformer, shunt device or single pole of a DC line) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

8.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2024 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system and no further deficiencies were identified.

9 Interconnection Customer Requirements

9.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion’s “Dominion Energy Electric Transmission Generator Interconnection Requirements” documented in Dominion’s Facility Interconnection Requirements “Exhibit C” located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

9.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion’s “Dominion’s Facility Interconnection Requirements” document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC’s GSU transformer(s).
2. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection section noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition (“SCADA”) equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
4. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion’s “Dominion’s Facility Interconnection Requirements” document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

9.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 Meteorological Data Reporting Requirements

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Back Panel temperature (Fahrenheit) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Irradiance (Watts/meter²) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Ambient air temperature (Fahrenheit) - (Accepted, not required)
- Wind speed (meters/second) - (Accepted, not required)
- Wind direction (decimal degrees from true north) - (Accepted, not required)

10.3 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

11 Summer Peak - Load Flow Analysis

The Queue Project AG1-134 was evaluated as a 100.0 MW (Capacity 60.0 MW) injection at the Kings Dominion DP 115 kV substation in the Dominion area. Project AG1-134 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-134 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJE T LOADIN G %	POST PROJE T LOADIN G %	AC D C	MW IMPAC T
1686628 61	31422 0	3FOURRIVE RS	115. 0	DVP	31422 1	3HANOV ER	115. 0	DVP	1	314222 6HANOV ER 230 939750 AE1-206 TAP 230 1	single	187.0599975 59	96.64	119.7	DC	43.14
1686628 62	31422 0	3FOURRIVE RS	115. 0	DVP	31422 1	3HANOV ER	115. 0	DVP	1	Base Case	single	187.0599975 59	84.57	107.7	DC	43.26
1686628 67	31422 1	3HANOVER	115. 0	DVP	31421 7	3ELMON T	115. 0	DVP	1	314212 6FOUR RIVERS 230 939750 AE1-206 TAP 230 1	single	187.0599975 59	96.59	119.65	DC	43.14
1686628 68	31422 1	3HANOVER	115. 0	DVP	31421 7	3ELMON T	115. 0	DVP	1	Base Case	single	187.0599975 59	84.51	107.64	DC	43.26

11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None.

11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJE T LOADIN G %	POST PROJE T LOADIN G %	AC D C	MW IMPAC T
1686631 62	31410 5	6AQUIA	230. 0	DVP	31418 6	6FULLER ROAD	230. 0	DVP	1	DVP_P 1-2: LN 2089	single	678.679992 676	103.9	105.08	DC	9.55
1686630 20	31413 4	6CRANES	230. 0	DVP	31414 2	6STAFORD	230. 0	DVP	1	DVP_P 1-2: LN 2089	single	678.679992 676	129.28	130.45	DC	9.55
1686630 22	31413 4	6CRANES	230. 0	DVP	31414 2	6STAFORD	230. 0	DVP	1	DVP_P 1-2: LN 568	single	678.679992 676	119.94	120.82	DC	7.5
1686630 93	31414 2	6STAFORD	230. 0	DVP	31414 5	6AQUI_HAR B_B	230. 0	DVP	1	DVP_P 1-2: LN 2089	single	678.679992 676	114.1	115.28	DC	9.55
1686630 95	31414 2	6STAFORD	230. 0	DVP	31414 5	6AQUI_HAR B_B	230. 0	DVP	1	DVP_P 1-2: LN 568	single	678.679992 676	104.76	105.65	DC	7.5
1686631 45	31414 4	6AQUI_HARB _A	230. 0	DVP	31410 5	6AQUIA	230. 0	DVP	1	DVP_P 1-2: LN 2089	single	678.679992 676	107.98	109.16	DC	9.55
1686631 72	31418 6	6FULLER ROAD	230. 0	DVP	31407 4	6POSSUM	230. 0	DVP	1	DVP_P 1-2: LN 2089	single	678.679992 676	102.86	104.03	DC	9.55

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168662998	314218	6ELMONT	230.0	DVP	314908	8ELMONT	500.0	DVP	2	DVP_P 1-2: LN 557	single	879.840026855	151.22	152.19	DC	9.87
168663026	314218	6ELMONT	230.0	DVP	314908	8ELMONT	500.0	DVP	1	DVP_P 1-2: LN 557	single	920.918029785	145.15	146.09	DC	9.91
168662858	314220	3FOURRIVERS	115.0	DVP	314221	3HANOVER	115.0	DVP	1	DVP_P 1-2: LN 47	single	187.059997559	140.48	172.53	DC	59.95
168662864	314221	3HANOVER	115.0	DVP	314217	3ELMONT	115.0	DVP	1	DVP_P 1-2: LN 47	single	187.059997559	140.38	172.42	DC	59.95

11.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663161	314105	6AQUIA	230.0	DVP	314186	6FULLER ROAD	230.0	DVP	1	DVP_P 1-2: LN 2089	operation	678.679992676	116.08	117.01	DC	15.92
168663019	314134	6CRANES	230.0	DVP	314142	6STAFORD	230.0	DVP	1	DVP_P 1-2: LN 2089	operation	678.679992676	141.39	142.32	DC	15.92
168663023	314134	6CRANES	230.0	DVP	314142	6STAFORD	230.0	DVP	1	Base Case	operation	678.679992676	102.65	103.39	DC	11.51
168663263	314137	6FREDBRG	230.0	DVP	314134	6CRANES	230.0	DVP	1	DVP_P 1-2: LN 2089	operation	984.179992676	103.58	104.22	DC	15.92
168663092	314142	6STAFORD	230.0	DVP	314145	6AQUI_HAR B_B	230.0	DVP	1	DVP_P 1-2: LN 2089	operation	678.679992676	126.28	127.21	DC	15.92
168663144	314144	6AQUI_HAR B_A	230.0	DVP	314105	6AQUIA	230.0	DVP	1	DVP_P 1-2: LN 2089	operation	678.679992676	120.17	121.09	DC	15.92
168663230	314151	3SLABTWN	115.0	DVP	314136	3FREDBRG	115.0	DVP	1	DVP_P 1-2: LN 73	operation	331.820007324	95.71	125.82	DC	99.91
168663196	314152	3S JOHNS	115.0	DVP	314153	3WOODPCK	115.0	DVP	1	DVP_P 1-2: LN 73	operation	331.820007324	103.0	133.11	DC	99.91

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663198	314153	3WOODPCK	115.0	DVP	314151	3SLABTWN	115.0	DVP	1	DVP_P 1-2: LN 73	operation	331.820007324	102.67	132.78	DC	99.91
168663171	314186	6FULLER ROAD	230.0	DVP	314074	6POSSUM	230.0	DVP	1	DVP_P 1-2: LN 2089	operation	678.679992676	115.04	115.96	DC	15.92
168663192	314216	3PINEWOOD	115.0	DVP	314152	3S JOHNS	115.0	DVP	1	DVP_P 1-2: LN 73	operation	331.820007324	104.81	134.92	DC	99.91
168663245	314217	3ELMONT	115.0	DVP	314237	3NRTHWST	115.0	DVP	1	DVP_P 1-2: LN 47	operation	220.899993896	102.86	120.1	DC	38.09
168662997	314218	6ELMONT	230.0	DVP	314908	8ELMONT	500.0	DVP	2	DVP_P 1-2: LN 557	operation	879.840026855	167.84	167.97	DC	16.45
168663025	314218	6ELMONT	230.0	DVP	314908	8ELMONT	500.0	DVP	1	DVP_P 1-2: LN 557	operation	920.918029785	161.1	161.22	DC	16.52
168662857	314220	3FOURRIVERS	115.0	DVP	314221	3HANOVER	115.0	DVP	1	DVP_P 1-2: LN 47	operation	187.059997559	185.92	239.33	DC	99.91
168662860	314220	3FOURRIVERS	115.0	DVP	314221	3HANOVER	115.0	DVP	1	Base Case	operation	187.059997559	117.09	155.64	DC	72.11
168662863	314221	3HANOVER	115.0	DVP	314217	3ELMONT	115.0	DVP	1	DVP_P 1-2: LN 47	operation	187.059997559	185.81	239.22	DC	99.91
168662866	314221	3HANOVER	115.0	DVP	314217	3ELMONT	115.0	DVP	1	Base Case	operation	187.059997559	117.04	155.59	DC	72.11
168663166	314223	3KINGS DOM DP	115.0	DVP	314216	3PINEWOOD	115.0	DVP	1	DVP_P 1-2: LN 73	operation	331.820007324	107.28	137.39	DC	99.91

11.5 System Reinforcements - Summer Peak Load Flow - Primary POI

ID	Idx	Facility	Upgrade Description	Cost
168662862,168662861,168662858	1	3FOURRIVERS 115.0 kV - 3HANOVER 115.0 kV Ckt 1	<u>DVP</u> n6163 (1405) : Rebuild 5.67 miles of 115 kV Line 73 from Four Rivers to Hanover with 2-636 ACSR. Project Type : FAC Cost : \$8,505,000 Time Estimate : 30-36 Months	\$8,505,000
168662868,168662867,168662864	2	3HANOVER 115.0 kV - 3ELMONT 115.0 kV Ckt 1	<u>DVP</u> n6164 (1406) : Rebuild 3.3 miles of 115 kV Line 73 from Hanover to Elmont with 2-636 ACSR. Project Type : FAC Cost : \$4,950,000 Time Estimate : 30-36 Months	\$4,950,000
168663095,168663093	5	6STAFORD 230.0 kV - 6AQUI_HARB_B 230.0 kV Ckt 1	<u>DVP</u> n6382 (1269) : Rebuild 0.32 miles of 230 kV Line2104 from Stafford to Aquia Harbor with 2-636 ACSR. Project Type : FAC Cost : \$500,000 Time Estimate : 30-36 Months	\$500,000
168663172	7	6FULLER ROAD 230.0 kV - 6POSSUM 230.0 kV Ckt 1	<u>DVP</u> dom-290 (1516) : Rebuild 3.41 mi miles of 230 kV Line 252 from Fuller Road to Possum Point with 2-636 ACSR (24/7) 150 C. Replace wave trap at Possum Point terminal. Project Type : FAC Cost : \$8,725,000 Time Estimate : 30-36 Months	\$8,725,000
168663026	9	6ELMONT 230.0 kV - 8ELMONT 500.0 kV Ckt 1	<u>DVP</u> n6127 (1386) : Add additional 500/230 kV transformer at Elmont Substation Project Type : CON Cost : \$22,000,000 Time Estimate : 16-18 Months	\$22,000,000
168663020,168663022	4	6CRANES 230.0 kV - 6STAFORD 230.0 kV Ckt 1	<u>DVP</u> n6131 (1388) : Rebuild 7.62 miles of 230 kV Line 2104 from Cranes Corner to Stafford with 2-636 ACSR. Project Type : FAC Cost : \$11,430,000 Time Estimate : 30-36 Months	\$11,430,000
168663162	3	6AQUIA 230.0 kV - 6FULLER ROAD 230.0 kV Ckt 1	<u>DVP</u> dom-280 (1506) : Rebuild 4.7 miles of 230 kV Line 252 from Aquia to Fuller Road with 2-636 ACSR (24/7) 150 C. Replace Line lead at Aquia terminal. Project Type : FAC Cost : \$11,750,000 Time Estimate : 30-36 Months	\$11,750,000

ID	Idx	Facility	Upgrade Description	Cost
168663145	6	6AQUI_HARB_A 230.0 kV - 6AQUIA 230.0 kV Ckt 1	<u>DVP</u> dom-284 (1510) : Rebuild 3.745 miles of 230 kV Line 252 from Aquia to Aquia Harbor with 2-636 ACSR (24/7) 150 C. Replace Line lead at Aquia terminal and wave trap at Aquia Harbor terminal. Project Type : FAC Cost : \$9,562,500 Time Estimate : 30-36 Months	\$9,562,500
168662998	8	6ELMONT 230.0 kV - 8ELMONT 500.0 kV Ckt 2	<u>DVP</u> dom-155 (1332) : Replace existing 500/230 kV transformer No 2 at Elmont. Project Type : FAC Cost : \$20,000,000 Time Estimate : 30-36 Months <u>DVP</u> n6127 (1386) : Add additional 500/230 kV transformer at Elmont Substation Project Type : CON Cost : \$22,000,000 Time Estimate : 16-18 Months	\$42,000,000
			TOTAL COST	\$97,422,500

11.6 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

11.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168662858	314220	3FOURRIVERS	DVP	314221	3HANOVER	DVP	1	DVP_P1-2: LN 47	single	187.06	140.48	172.53	DC	59.95

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
315050	1FOURRIVERG	26.7969	80/20	26.7969
934781	AD1-105 C	45.3896	80/20	45.3896
943601	AF1-031 C	60.6360	80/20	60.6360
943991	AF1-067 C	29.9733	80/20	29.9733
962851	AG1-134 C	59.9466	80/20	59.9466
CALDERWOOD	CALDERWOOD	0.0442	Confirmed LTF	0.0442
NY	NY	0.0492	Confirmed LTF	0.0492
PRAIRIE	PRAIRIE	0.2299	Confirmed LTF	0.2299
CHEOAH	CHEOAH	0.0445	Confirmed LTF	0.0445
COTTONWOOD	COTTONWOOD	0.1869	Confirmed LTF	0.1869
HAMLET	HAMLET	0.0514	Confirmed LTF	0.0514
GIBSON	GIBSON	0.0486	Confirmed LTF	0.0486
BLUEG	BLUEG	0.1545	Confirmed LTF	0.1545
TRIMBLE	TRIMBLE	0.0495	Confirmed LTF	0.0495
CATAWBA	CATAWBA	0.0312	Confirmed LTF	0.0312

11.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168662864	314221	3HANOVER	DVP	314217	3ELMONT	DVP	1	DVP_P1-2: LN 47	single	187.06	140.38	172.42	DC	59.95

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
315050	1FOURRIVERG	26.7969	80/20	26.7969
934781	AD1-105 C	45.3896	80/20	45.3896
943601	AF1-031 C	60.6360	80/20	60.6360
943991	AF1-067 C	29.9733	80/20	29.9733
962851	AG1-134 C	59.9466	80/20	59.9466
CALDERWOOD	CALDERWOOD	0.0442	Confirmed LTF	0.0442
NY	NY	0.0492	Confirmed LTF	0.0492
PRAIRIE	PRAIRIE	0.2299	Confirmed LTF	0.2299
CHEOAH	CHEOAH	0.0445	Confirmed LTF	0.0445
COTTONWOOD	COTTONWOOD	0.1869	Confirmed LTF	0.1869
HAMLET	HAMLET	0.0514	Confirmed LTF	0.0514
GIBSON	GIBSON	0.0486	Confirmed LTF	0.0486
BLUEG	BLUEG	0.1545	Confirmed LTF	0.1545
TRIMBLE	TRIMBLE	0.0495	Confirmed LTF	0.0495
CATAWBA	CATAWBA	0.0312	Confirmed LTF	0.0312

11.6.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663162	314105	6AQUIA	DVP	314186	6FULLER ROAD	DVP	1	DVP_P1-2: LN 2089	single	678.68	103.9	105.08	DC	9.55

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314131	6ARNOLDS	0.5419	80/20	0.5419
314134	6CRANES	0.1739	80/20	0.1739
314190	6WESTMOR	0.5171	80/20	0.5171
315033	1BIRCHWDA	100.9501	80/20	100.9501
315034	1NORNECKC1	0.7558	80/20	0.7558
315035	1NORNECKC2	0.7284	80/20	0.7284
315037	1LDYSMT1	9.1596	80/20	9.1596
315038	1LDYSMT2	9.1596	80/20	9.1596
315039	1LDYSMT3	8.8175	80/20	8.8175
315040	1LDYSMT4	8.8340	80/20	8.8340
315041	1LDYSMT5	8.8616	80/20	8.8616
315043	1FOUR RIVERA	2.4950	80/20	2.4950
315044	1FOUR RIVERB	2.4950	80/20	2.4950
315045	1FOUR RIVERC	3.0495	80/20	3.0495
315046	1FOUR RIVERD	2.4950	80/20	2.4950
315047	1FOUR RIVERE	2.4950	80/20	2.4950
315048	1FOUR RIVERF	3.0495	80/20	3.0495
315050	1FOURRIVERG	3.9569	80/20	3.9569
315051	1AA1-145 CT1	3.9274	80/20	3.9274
315052	1AA1-145 CT2	3.9274	80/20	3.9274
316077	AC2-138 C	0.1912	80/20	0.1912
316156	AD2-030 C	0.2139	80/20	0.2139
925863	AC1-065 C	3.4588	Adder	4.07
927044	AC1-191 C	4.3397	Adder	5.11
934141	AD1-041 C	3.0009	80/20	3.0009
934781	AD1-105 C	7.2320	80/20	7.2320
936581	AD2-073 C	2.9660	80/20	2.9660
936591	AD2-074 C	5.1755	80/20	5.1755
938961	AE1-124 C	0.6019	80/20	0.6019
939245	AE1-155 C	12.6418	80/20	12.6418
939261	AE1-157 C O1	22.6227	80/20	22.6227
939271	AE1-158 C O1	23.0879	80/20	23.0879
939611	AE1-191 C	6.0018	80/20	6.0018
939755	AE1-206 C	22.0351	80/20	22.0351
940231	AE2-005 C	0.6289	Adder	0.74
940551	AE2-041	3.2514	Adder	3.83
942191	AE2-231 C O1	6.7729	80/20	6.7729
943431	AF1-014 C	0.5958	Adder	0.7
943471	AF1-018	3.2514	Adder	3.83
943601	AF1-031 C	9.6612	80/20	9.6612
943741	AF1-042 C	2.7081	80/20	2.7081

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
943991	AF1-067 C	4.7757	80/20	4.7757
944491	AF1-114 C	12.9805	80/20	12.9805
945831	AF1-248	0.0637	80/20	0.0637
946001	AF1-265	19.3290	80/20	19.3290
957191	AF2-013	37.1160	80/20	37.1160
957411	AF2-035 C	12.3144	80/20	12.3144
957551	AF2-049 C	10.0319	80/20	10.0319
957601	AF2-054 C	1.2358	80/20	1.2358
957971	AF2-091 C	4.4134	80/20	4.4134
958261	AF2-120 C	6.1782	80/20	6.1782
960091	AF2-300 C	3.0786	80/20	3.0786
961781	AG1-019	37.1160	80/20	37.1160
961951	AG1-038 C	2.9932	80/20	2.9932
962131	AG1-057	0.8616	Adder	1.91
962851	AG1-134 C	9.5514	80/20	9.5514
962861	AG1-135 C	5.8626	80/20	5.8626
962971	AG1-146 C	2.5699	80/20	2.5699
962981	AG1-147 C	5.9963	80/20	5.9963
963051	AG1-154 C	6.9948	80/20	6.9948
963341	AG1-183 C	9.1127	80/20	9.1127
963381	AG1-187	3.7148	80/20	3.7148
963611	AG1-210 C	0.7695	80/20	0.7695
963621	AG1-213 C	1.0262	80/20	1.0262
964021	AG1-256 C	1.6539	80/20	1.6539
964211	AG1-282 C	2.1487	80/20	2.1487
964591	AG1-322 O1	29.6912	80/20	29.6912
965231	AG1-388 C	2.1487	80/20	2.1487
965441	AG1-412 C	30.2480	80/20	30.2480
966661	AG1-536 C	5.3229	80/20	5.3229
966711	AG1-541 C	8.2096	80/20	8.2096
966871	AG1-558 C	0.5169	Adder	1.15
966881	AG1-559 C	3.0786	80/20	3.0786
WEC	WEC	0.1673	Confirmed LTF	0.1673
LGEE	LGEE	0.3619	Confirmed LTF	0.3619
CPL	CPL	1.7861	Confirmed LTF	1.7861
CBM-W2	CBM-W2	7.7862	Confirmed LTF	7.7862
NY	NY	0.7891	Confirmed LTF	0.7891
TVA	TVA	1.5036	Confirmed LTF	1.5036
SIGE	SIGE	0.2340	Confirmed LTF	0.2340
CBM-S2	CBM-S2	21.7674	Confirmed LTF	21.7674
CBM-S1	CBM-S1	0.3735	Confirmed LTF	0.3735
MEC	MEC	1.0313	Confirmed LTF	1.0313
LAGN	LAGN	1.8427	Confirmed LTF	1.8427
CBM-W1	CBM-W1	6.7436	Confirmed LTF	6.7436

11.6.4 Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663020	314134	6CRANES	DVP	314142	6STAFORD	DVP	1	DVP_P1-2: LN 2089	single	678.68	129.28	130.45	DC	9.55

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314131	6ARNOLDS	0.5419	80/20	0.5419
314134	6CRANES	0.1739	80/20	0.1739
314190	6WESTMOR	0.5171	80/20	0.5171
315033	1BIRCHWDA	100.9501	80/20	100.9501
315034	1NORNECKC1	0.7558	80/20	0.7558
315035	1NORNECKC2	0.7284	80/20	0.7284
315037	1LDYSMT1	9.1596	80/20	9.1596
315038	1LDYSMT2	9.1596	80/20	9.1596
315039	1LDYSMT3	8.8175	80/20	8.8175
315040	1LDYSMT4	8.8340	80/20	8.8340
315041	1LDYSMT5	8.8616	80/20	8.8616
315043	1FOUR RIVERA	2.4950	80/20	2.4950
315044	1FOUR RIVERB	2.4950	80/20	2.4950
315045	1FOUR RIVERC	3.0495	80/20	3.0495
315046	1FOUR RIVERD	2.4950	80/20	2.4950
315047	1FOUR RIVERE	2.4950	80/20	2.4950
315048	1FOUR RIVERF	3.0495	80/20	3.0495
315050	1FOURRIVERG	3.9569	80/20	3.9569
315051	1AA1-145 CT1	3.9274	80/20	3.9274
315052	1AA1-145 CT2	3.9274	80/20	3.9274
316077	AC2-138 C	0.1912	80/20	0.1912
316156	AD2-030 C	0.2139	80/20	0.2139
925863	AC1-065 C	3.4588	Adder	4.07
927044	AC1-191 C	4.3397	Adder	5.11
934141	AD1-041 C	3.0009	80/20	3.0009
934781	AD1-105 C	7.2320	80/20	7.2320
936581	AD2-073 C	2.9660	80/20	2.9660
936591	AD2-074 C	5.1755	80/20	5.1755
938961	AE1-124 C	0.6019	80/20	0.6019
939245	AE1-155 C	12.6418	80/20	12.6418
939261	AE1-157 C O1	22.6227	80/20	22.6227
939271	AE1-158 C O1	23.0879	80/20	23.0879
939611	AE1-191 C	6.0018	80/20	6.0018
939755	AE1-206 C	22.0351	80/20	22.0351
940231	AE2-005 C	0.6289	Adder	0.74
940551	AE2-041	3.2514	Adder	3.83
942191	AE2-231 C O1	6.7729	80/20	6.7729
943431	AF1-014 C	0.5958	Adder	0.7
943471	AF1-018	3.2514	Adder	3.83
943601	AF1-031 C	9.6612	80/20	9.6612
943741	AF1-042 C	2.7081	80/20	2.7081

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
943991	AF1-067 C	4.7757	80/20	4.7757
944491	AF1-114 C	12.9805	80/20	12.9805
945831	AF1-248	0.0637	80/20	0.0637
946001	AF1-265	19.3290	80/20	19.3290
957191	AF2-013	37.1160	80/20	37.1160
957411	AF2-035 C	12.3144	80/20	12.3144
957551	AF2-049 C	10.0319	80/20	10.0319
957601	AF2-054 C	1.2358	80/20	1.2358
957971	AF2-091 C	4.4134	80/20	4.4134
958261	AF2-120 C	6.1782	80/20	6.1782
960091	AF2-300 C	3.0786	80/20	3.0786
961781	AG1-019	37.1160	80/20	37.1160
961951	AG1-038 C	2.9932	80/20	2.9932
962131	AG1-057	0.8616	Adder	1.91
962851	AG1-134 C	9.5514	80/20	9.5514
962861	AG1-135 C	5.8626	80/20	5.8626
962971	AG1-146 C	2.5699	80/20	2.5699
962981	AG1-147 C	5.9963	80/20	5.9963
963051	AG1-154 C	6.9948	80/20	6.9948
963341	AG1-183 C	9.1127	80/20	9.1127
963381	AG1-187	3.7148	80/20	3.7148
963611	AG1-210 C	0.7695	80/20	0.7695
963621	AG1-213 C	1.0262	80/20	1.0262
964021	AG1-256 C	1.6539	80/20	1.6539
964211	AG1-282 C	2.1487	80/20	2.1487
964591	AG1-322 O1	29.6912	80/20	29.6912
965231	AG1-388 C	2.1487	80/20	2.1487
965441	AG1-412 C	30.2480	80/20	30.2480
966661	AG1-536 C	5.3229	80/20	5.3229
966711	AG1-541 C	8.2096	80/20	8.2096
966871	AG1-558 C	0.5169	Adder	1.15
966881	AG1-559 C	3.0786	80/20	3.0786
WEC	WEC	0.1673	Confirmed LTF	0.1673
LGEE	LGEE	0.3619	Confirmed LTF	0.3619
CPL	CPL	1.7861	Confirmed LTF	1.7861
CBM-W2	CBM-W2	7.7862	Confirmed LTF	7.7862
NY	NY	0.7891	Confirmed LTF	0.7891
TVA	TVA	1.5036	Confirmed LTF	1.5036
SIGE	SIGE	0.2340	Confirmed LTF	0.2340
CBM-S2	CBM-S2	21.7674	Confirmed LTF	21.7674
CBM-S1	CBM-S1	0.3735	Confirmed LTF	0.3735
MEC	MEC	1.0313	Confirmed LTF	1.0313
LAGN	LAGN	1.8427	Confirmed LTF	1.8427
CBM-W1	CBM-W1	6.7436	Confirmed LTF	6.7436

11.6.5 Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663093	314142	6STAFORD	DVP	314145	6AQUI_HARB_B	DVP	1	DVP_P1-2: LN 2089	single	678.68	114.1	115.28	DC	9.55

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314131	6ARNOLDS	0.5419	80/20	0.5419
314134	6CRANES	0.1739	80/20	0.1739
314190	6WESTMOR	0.5171	80/20	0.5171
315033	1BIRCHWDA	100.9501	80/20	100.9501
315034	1NORNECKC1	0.7558	80/20	0.7558
315035	1NORNECKC2	0.7284	80/20	0.7284
315037	1LDYSMT1	9.1596	80/20	9.1596
315038	1LDYSMT2	9.1596	80/20	9.1596
315039	1LDYSMT3	8.8175	80/20	8.8175
315040	1LDYSMT4	8.8340	80/20	8.8340
315041	1LDYSMT5	8.8616	80/20	8.8616
315043	1FOUR RIVERA	2.4950	80/20	2.4950
315044	1FOUR RIVERB	2.4950	80/20	2.4950
315045	1FOUR RIVERC	3.0495	80/20	3.0495
315046	1FOUR RIVERD	2.4950	80/20	2.4950
315047	1FOUR RIVERE	2.4950	80/20	2.4950
315048	1FOUR RIVERF	3.0495	80/20	3.0495
315050	1FOURRIVERG	3.9569	80/20	3.9569
315051	1AA1-145 CT1	3.9274	80/20	3.9274
315052	1AA1-145 CT2	3.9274	80/20	3.9274
316077	AC2-138 C	0.1912	80/20	0.1912
316156	AD2-030 C	0.2139	80/20	0.2139
925863	AC1-065 C	3.4588	Adder	4.07
927044	AC1-191 C	4.3397	Adder	5.11
934141	AD1-041 C	3.0009	80/20	3.0009
934781	AD1-105 C	7.2320	80/20	7.2320
936581	AD2-073 C	2.9660	80/20	2.9660
936591	AD2-074 C	5.1755	80/20	5.1755
938961	AE1-124 C	0.6019	80/20	0.6019
939245	AE1-155 C	12.6418	80/20	12.6418
939261	AE1-157 C O1	22.6227	80/20	22.6227
939271	AE1-158 C O1	23.0879	80/20	23.0879
939611	AE1-191 C	6.0018	80/20	6.0018
939755	AE1-206 C	22.0351	80/20	22.0351
940231	AE2-005 C	0.6289	Adder	0.74
940551	AE2-041	3.2514	Adder	3.83
942191	AE2-231 C O1	6.7729	80/20	6.7729
943431	AF1-014 C	0.5958	Adder	0.7
943471	AF1-018	3.2514	Adder	3.83
943601	AF1-031 C	9.6612	80/20	9.6612
943741	AF1-042 C	2.7081	80/20	2.7081

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
943991	AF1-067 C	4.7757	80/20	4.7757
944491	AF1-114 C	12.9805	80/20	12.9805
945831	AF1-248	0.0637	80/20	0.0637
946001	AF1-265	19.3290	80/20	19.3290
957191	AF2-013	37.1160	80/20	37.1160
957411	AF2-035 C	12.3144	80/20	12.3144
957551	AF2-049 C	10.0319	80/20	10.0319
957601	AF2-054 C	1.2358	80/20	1.2358
957971	AF2-091 C	4.4134	80/20	4.4134
958261	AF2-120 C	6.1782	80/20	6.1782
960091	AF2-300 C	3.0786	80/20	3.0786
961781	AG1-019	37.1160	80/20	37.1160
961951	AG1-038 C	2.9932	80/20	2.9932
962131	AG1-057	0.8616	Adder	1.91
962851	AG1-134 C	9.5514	80/20	9.5514
962861	AG1-135 C	5.8626	80/20	5.8626
962971	AG1-146 C	2.5699	80/20	2.5699
962981	AG1-147 C	5.9963	80/20	5.9963
963051	AG1-154 C	6.9948	80/20	6.9948
963341	AG1-183 C	9.1127	80/20	9.1127
963381	AG1-187	3.7148	80/20	3.7148
963611	AG1-210 C	0.7695	80/20	0.7695
963621	AG1-213 C	1.0262	80/20	1.0262
964021	AG1-256 C	1.6539	80/20	1.6539
964211	AG1-282 C	2.1487	80/20	2.1487
964591	AG1-322 O1	29.6912	80/20	29.6912
965231	AG1-388 C	2.1487	80/20	2.1487
965441	AG1-412 C	30.2480	80/20	30.2480
966661	AG1-536 C	5.3229	80/20	5.3229
966711	AG1-541 C	8.2096	80/20	8.2096
966871	AG1-558 C	0.5169	Adder	1.15
966881	AG1-559 C	3.0786	80/20	3.0786
WEC	WEC	0.1673	Confirmed LTF	0.1673
LGEE	LGEE	0.3619	Confirmed LTF	0.3619
CPL	CPL	1.7861	Confirmed LTF	1.7861
CBM-W2	CBM-W2	7.7862	Confirmed LTF	7.7862
NY	NY	0.7891	Confirmed LTF	0.7891
TVA	TVA	1.5036	Confirmed LTF	1.5036
SIGE	SIGE	0.2340	Confirmed LTF	0.2340
CBM-S2	CBM-S2	21.7674	Confirmed LTF	21.7674
CBM-S1	CBM-S1	0.3735	Confirmed LTF	0.3735
MEC	MEC	1.0313	Confirmed LTF	1.0313
LAGN	LAGN	1.8427	Confirmed LTF	1.8427
CBM-W1	CBM-W1	6.7436	Confirmed LTF	6.7436

11.6.6 Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663145	314144	6AQUI_HARB_A	DVP	314105	6AQUIA	DVP	1	DVP_P1-2: LN 2089	single	678.68	107.98	109.16	DC	9.55

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314131	6ARNOLDS	0.5419	80/20	0.5419
314134	6CRANES	0.1739	80/20	0.1739
314190	6WESTMOR	0.5171	80/20	0.5171
315033	1BIRCHWDA	100.9501	80/20	100.9501
315034	1NORNECKC1	0.7558	80/20	0.7558
315035	1NORNECKC2	0.7284	80/20	0.7284
315037	1LDYSMT1	9.1596	80/20	9.1596
315038	1LDYSMT2	9.1596	80/20	9.1596
315039	1LDYSMT3	8.8175	80/20	8.8175
315040	1LDYSMT4	8.8340	80/20	8.8340
315041	1LDYSMT5	8.8616	80/20	8.8616
315043	1FOUR RIVERA	2.4950	80/20	2.4950
315044	1FOUR RIVERB	2.4950	80/20	2.4950
315045	1FOUR RIVERC	3.0495	80/20	3.0495
315046	1FOUR RIVERD	2.4950	80/20	2.4950
315047	1FOUR RIVERE	2.4950	80/20	2.4950
315048	1FOUR RIVERF	3.0495	80/20	3.0495
315050	1FOURRIVERG	3.9569	80/20	3.9569
315051	1AA1-145 CT1	3.9274	80/20	3.9274
315052	1AA1-145 CT2	3.9274	80/20	3.9274
316077	AC2-138 C	0.1912	80/20	0.1912
316156	AD2-030 C	0.2139	80/20	0.2139
925863	AC1-065 C	3.4588	Adder	4.07
927044	AC1-191 C	4.3397	Adder	5.11
934141	AD1-041 C	3.0009	80/20	3.0009
934781	AD1-105 C	7.2320	80/20	7.2320
936581	AD2-073 C	2.9660	80/20	2.9660
936591	AD2-074 C	5.1755	80/20	5.1755
938961	AE1-124 C	0.6019	80/20	0.6019
939245	AE1-155 C	12.6418	80/20	12.6418
939261	AE1-157 C O1	22.6227	80/20	22.6227
939271	AE1-158 C O1	23.0879	80/20	23.0879
939611	AE1-191 C	6.0018	80/20	6.0018
939755	AE1-206 C	22.0351	80/20	22.0351
940231	AE2-005 C	0.6289	Adder	0.74
940551	AE2-041	3.2514	Adder	3.83
942191	AE2-231 C O1	6.7729	80/20	6.7729
943431	AF1-014 C	0.5958	Adder	0.7
943471	AF1-018	3.2514	Adder	3.83
943601	AF1-031 C	9.6612	80/20	9.6612
943741	AF1-042 C	2.7081	80/20	2.7081

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
943991	AF1-067 C	4.7757	80/20	4.7757
944491	AF1-114 C	12.9805	80/20	12.9805
945831	AF1-248	0.0637	80/20	0.0637
946001	AF1-265	19.3290	80/20	19.3290
957191	AF2-013	37.1160	80/20	37.1160
957411	AF2-035 C	12.3144	80/20	12.3144
957551	AF2-049 C	10.0319	80/20	10.0319
957601	AF2-054 C	1.2358	80/20	1.2358
957971	AF2-091 C	4.4134	80/20	4.4134
958261	AF2-120 C	6.1782	80/20	6.1782
960091	AF2-300 C	3.0786	80/20	3.0786
961781	AG1-019	37.1160	80/20	37.1160
961951	AG1-038 C	2.9932	80/20	2.9932
962131	AG1-057	0.8616	Adder	1.91
962851	AG1-134 C	9.5514	80/20	9.5514
962861	AG1-135 C	5.8626	80/20	5.8626
962971	AG1-146 C	2.5699	80/20	2.5699
962981	AG1-147 C	5.9963	80/20	5.9963
963051	AG1-154 C	6.9948	80/20	6.9948
963341	AG1-183 C	9.1127	80/20	9.1127
963381	AG1-187	3.7148	80/20	3.7148
963611	AG1-210 C	0.7695	80/20	0.7695
963621	AG1-213 C	1.0262	80/20	1.0262
964021	AG1-256 C	1.6539	80/20	1.6539
964211	AG1-282 C	2.1487	80/20	2.1487
964591	AG1-322 O1	29.6912	80/20	29.6912
965231	AG1-388 C	2.1487	80/20	2.1487
965441	AG1-412 C	30.2480	80/20	30.2480
966661	AG1-536 C	5.3229	80/20	5.3229
966711	AG1-541 C	8.2096	80/20	8.2096
966871	AG1-558 C	0.5169	Adder	1.15
966881	AG1-559 C	3.0786	80/20	3.0786
WEC	WEC	0.1673	Confirmed LTF	0.1673
LGEE	LGEE	0.3619	Confirmed LTF	0.3619
CPL	CPL	1.7861	Confirmed LTF	1.7861
CBM-W2	CBM-W2	7.7862	Confirmed LTF	7.7862
NY	NY	0.7891	Confirmed LTF	0.7891
TVA	TVA	1.5036	Confirmed LTF	1.5036
SIGE	SIGE	0.2340	Confirmed LTF	0.2340
CBM-S2	CBM-S2	21.7674	Confirmed LTF	21.7674
CBM-S1	CBM-S1	0.3735	Confirmed LTF	0.3735
MEC	MEC	1.0313	Confirmed LTF	1.0313
LAGN	LAGN	1.8427	Confirmed LTF	1.8427
CBM-W1	CBM-W1	6.7436	Confirmed LTF	6.7436

11.6.7 Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663172	314186	6FULLER ROAD	DVP	314074	6POSSUM	DVP	1	DVP_P1-2: LN 2089	single	678.68	102.86	104.03	DC	9.55

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314131	6ARNOLDS	0.5419	80/20	0.5419
314134	6CRANES	0.1739	80/20	0.1739
314190	6WESTMOR	0.5171	80/20	0.5171
315033	1BIRCHWDA	100.9501	80/20	100.9501
315034	1NORNECKC1	0.7558	80/20	0.7558
315035	1NORNECKC2	0.7284	80/20	0.7284
315037	1LDYSMT1	9.1596	80/20	9.1596
315038	1LDYSMT2	9.1596	80/20	9.1596
315039	1LDYSMT3	8.8175	80/20	8.8175
315040	1LDYSMT4	8.8340	80/20	8.8340
315041	1LDYSMT5	8.8616	80/20	8.8616
315043	1FOUR RIVERA	2.4950	80/20	2.4950
315044	1FOUR RIVERB	2.4950	80/20	2.4950
315045	1FOUR RIVERC	3.0495	80/20	3.0495
315046	1FOUR RIVERD	2.4950	80/20	2.4950
315047	1FOUR RIVERE	2.4950	80/20	2.4950
315048	1FOUR RIVERF	3.0495	80/20	3.0495
315050	1FOURRIVERG	3.9569	80/20	3.9569
315051	1AA1-145 CT1	3.9274	80/20	3.9274
315052	1AA1-145 CT2	3.9274	80/20	3.9274
316077	AC2-138 C	0.1912	80/20	0.1912
316156	AD2-030 C	0.2139	80/20	0.2139
925863	AC1-065 C	3.4588	Adder	4.07
927044	AC1-191 C	4.3397	Adder	5.11
934141	AD1-041 C	3.0009	80/20	3.0009
934781	AD1-105 C	7.2320	80/20	7.2320
936581	AD2-073 C	2.9660	80/20	2.9660
936591	AD2-074 C	5.1755	80/20	5.1755
938961	AE1-124 C	0.6019	80/20	0.6019
939245	AE1-155 C	12.6418	80/20	12.6418
939261	AE1-157 C O1	22.6227	80/20	22.6227
939271	AE1-158 C O1	23.0879	80/20	23.0879
939611	AE1-191 C	6.0018	80/20	6.0018
939755	AE1-206 C	22.0351	80/20	22.0351
940231	AE2-005 C	0.6289	Adder	0.74
940551	AE2-041	3.2514	Adder	3.83
942191	AE2-231 C O1	6.7729	80/20	6.7729
943431	AF1-014 C	0.5958	Adder	0.7
943471	AF1-018	3.2514	Adder	3.83
943601	AF1-031 C	9.6612	80/20	9.6612
943741	AF1-042 C	2.7081	80/20	2.7081

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
943991	AF1-067 C	4.7757	80/20	4.7757
944491	AF1-114 C	12.9805	80/20	12.9805
945831	AF1-248	0.0637	80/20	0.0637
946001	AF1-265	19.3290	80/20	19.3290
957191	AF2-013	37.1160	80/20	37.1160
957411	AF2-035 C	12.3144	80/20	12.3144
957551	AF2-049 C	10.0319	80/20	10.0319
957601	AF2-054 C	1.2358	80/20	1.2358
957971	AF2-091 C	4.4134	80/20	4.4134
958261	AF2-120 C	6.1782	80/20	6.1782
960091	AF2-300 C	3.0786	80/20	3.0786
961781	AG1-019	37.1160	80/20	37.1160
961951	AG1-038 C	2.9932	80/20	2.9932
962131	AG1-057	0.8616	Adder	1.91
962851	AG1-134 C	9.5514	80/20	9.5514
962861	AG1-135 C	5.8626	80/20	5.8626
962971	AG1-146 C	2.5699	80/20	2.5699
962981	AG1-147 C	5.9963	80/20	5.9963
963051	AG1-154 C	6.9948	80/20	6.9948
963341	AG1-183 C	9.1127	80/20	9.1127
963381	AG1-187	3.7148	80/20	3.7148
963611	AG1-210 C	0.7695	80/20	0.7695
963621	AG1-213 C	1.0262	80/20	1.0262
964021	AG1-256 C	1.6539	80/20	1.6539
964211	AG1-282 C	2.1487	80/20	2.1487
964591	AG1-322 O1	29.6912	80/20	29.6912
965231	AG1-388 C	2.1487	80/20	2.1487
965441	AG1-412 C	30.2480	80/20	30.2480
966661	AG1-536 C	5.3229	80/20	5.3229
966711	AG1-541 C	8.2096	80/20	8.2096
966871	AG1-558 C	0.5169	Adder	1.15
966881	AG1-559 C	3.0786	80/20	3.0786
WEC	WEC	0.1673	Confirmed LTF	0.1673
LGEE	LGEE	0.3619	Confirmed LTF	0.3619
CPL	CPL	1.7861	Confirmed LTF	1.7861
CBM-W2	CBM-W2	7.7862	Confirmed LTF	7.7862
NY	NY	0.7891	Confirmed LTF	0.7891
TVA	TVA	1.5036	Confirmed LTF	1.5036
SIGE	SIGE	0.2340	Confirmed LTF	0.2340
CBM-S2	CBM-S2	21.7674	Confirmed LTF	21.7674
CBM-S1	CBM-S1	0.3735	Confirmed LTF	0.3735
MEC	MEC	1.0313	Confirmed LTF	1.0313
LAGN	LAGN	1.8427	Confirmed LTF	1.8427
CBM-W1	CBM-W1	6.7436	Confirmed LTF	6.7436

11.6.8 Index 8

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168662998	314218	6ELMONT	DVP	314908	8ELMONT	DVP	2	DVP_P1-2: LN 557	single	879.84	151.22	152.19	DC	9.87

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314229	6MT RD221	0.1393	80/20	0.1393
314236	6NRTHST	0.1832	80/20	0.1832
314241	6GOLDCHRC	0.8548	80/20	0.8548
314250	6ROCKVILLE	0.3145	80/20	0.3145
314309	6IRON208	0.3968	80/20	0.3968
315043	1FOUR RIVERA	3.0873	80/20	3.0873
315044	1FOUR RIVERB	3.0873	80/20	3.0873
315045	1FOUR RIVERC	3.7734	80/20	3.7734
315046	1FOUR RIVERD	3.0873	80/20	3.0873
315047	1FOUR RIVERE	3.0873	80/20	3.0873
315048	1FOUR RIVERF	3.7734	80/20	3.7734
315050	1FOURRIVERG	4.6210	80/20	4.6210
315051	1AA1-145 CT1	4.8597	80/20	4.8597
315052	1AA1-145 CT2	4.8597	80/20	4.8597
315058	1CHESTF3 (Deactivation : 13/12/2018)	16.7010	80/20	16.7010
315059	1CHESTF4 (Deactivation : 13/12/2018)	27.0723	80/20	27.0723
315060	1CHESTF5 (Deactivation : 31/05/2023)	56.0665	80/20	56.0665
315061	1CHESTG7	3.3032	80/20	3.3032
315062	1CHESTS7	1.5164	80/20	1.5164
315063	1CHESTG8	3.2501	80/20	3.2501
315064	1CHESTS8	1.6731	80/20	1.6731
315065	1CHESTF6 (Deactivation : 31/05/2023)	91.6222	Adder	107.79
315067	1DARBY 1	2.4661	80/20	2.4661
315068	1DARBY 2	2.4690	80/20	2.4690
315069	1DARBY 3	2.4776	80/20	2.4776
315070	1DARBY 4	2.4805	80/20	2.4805
315074	1HOPCGN1 (Deactivation : 25/06/2019)	0.0129	Adder	0.02
315075	1HOPCGN2 (Deactivation : 25/06/2019)	0.0129	Adder	0.02
315083	1SPRUNCA (Deactivation : 12/01/2021)	7.8772	Adder	9.27
315084	1SPRUNCB (Deactivation : 12/01/2021)	7.8772	Adder	9.27
316075	AC2-137 C	0.2994	80/20	0.2994
316083	AB2-161 C (Suspended)	2.1134	Adder	2.49
316103	AB2-015 C	4.3635	Adder	5.13
316108	AB2-160 C (Suspended)	3.7946	Adder	4.46

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
316112	AB2-068 CT1 (Withdrawn : 01/11/2021)	31.7658	Adder	37.37
316113	AB2-068 CT2 (Withdrawn : 01/11/2021)	31.7658	Adder	37.37
316114	AB2-068 ST (Withdrawn : 01/11/2021)	55.0309	Adder	64.74
316132	AB2-190 C	13.4527	Adder	15.83
316134	AC1-107 G1	59.6504	Adder	70.18
316135	AC1-107 G2	59.6504	Adder	70.18
316136	AC1-107 G3	59.6616	Adder	70.19
925863	AC1-065 C	4.9550	Adder	5.83
926754	AC1-161 C	15.6838	Adder	18.45
926784	AC1-164 C	29.3625	Adder	34.54
927044	AC1-191 C	11.0570	80/20	11.0570
932044	AC2-012 C	5.4501	Adder	6.41
932501	AC2-070 C	0.2809	80/20	0.2809
932581	AC2-078 C O1	2.5477	Adder	3.0
932591	AC2-079 C O1	3.3547	Adder	3.95
933294	AC2-141 C	15.6838	Adder	18.45
933991	AD1-023 C	6.3205	Adder	7.44
934014	AD1-025 C	11.0985	Adder	13.06
934061	AD1-033 C	3.9598	Adder	4.66
934141	AD1-041 C	3.5032	Adder	4.12
934521	AD1-076 C	26.3163	Adder	30.96
934575	AD1-082 C	4.8163	Adder	5.67
934781	AD1-105 C	7.4723	80/20	7.4723
935164	AD1-151 C	10.8102	Adder	12.72
936041	AD2-007 C	0.5302	Adder	0.62
936051	AD2-008 C	1.9322	Adder	2.27
936151	AD2-021	0.0341	80/20	0.0341
936581	AD2-073 C	1.1747	Adder	1.38
936591	AD2-074 C	3.3545	Adder	3.95
936661	AD2-085 C	1.9427	Adder	2.29
936761	AD2-097 C	1.4939	Adder	1.76
937221	AD2-160 C O1	3.0701	Adder	3.61
938535	AE1-072 C	9.2178	Adder	10.84
938634	AE1-085 C	5.6087	Adder	6.6
938771	AE1-103 C	1.8803	Adder	2.21
939195	AE1-149 C	6.8610	Adder	8.07
939245	AE1-155 C	7.6706	Adder	9.02
939414	AE1-173_C1	14.0087	Adder	16.48
939415	AE1-173_C2	12.0074	Adder	14.13
939416	AE1-173_C3	14.0087	Adder	16.48
939431	AE1-175 C	1.5371	Adder	1.81
939611	AE1-191 C	7.0064	Adder	8.24
939755	AE1-206 C	33.2373	80/20	33.2373
940061	AE2-000BC O1	6.6229	Adder	7.79
940231	AE2-005 C	0.9009	Adder	1.06
940251	AE2-007 O1 (Withdrawn : 12/11/2020)	92.3294	Adder	108.62
940431	AE2-027 C O1	9.4713	Adder	11.14
940481	AE2-033 C	8.3782	Adder	9.86
940491	AE2-034 C	3.5500	Adder	4.18

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
940541	AE2-040	1.4982	Adder	1.76
940551	AE2-041	4.7631	Adder	5.6
940651	AE2-052	2.2870	Adder	2.69
940891	AE2-078 C	1.4322	Adder	1.68
940901	AE2-079 C	1.4322	Adder	1.68
941101	AE2-104 C O1	1.8038	Adder	2.12
941281	AE2-122 C O1	15.0624	Adder	17.72
941291	AE2-123 C O1	15.4795	Adder	18.21
941301	AE2-124 C O1	14.0640	Adder	16.55
941501	AE2-147 C	8.1916	Adder	9.64
941581	AE2-155 C	0.1069	80/20	0.1069
941591	AE2-156 O1	9.5557	Adder	11.24
942001	AE2-212 C	1.5155	Adder	1.78
942131	AE2-225 C	1.1264	Adder	1.33
942151	AE2-227 C	2.0256	80/20	2.0256
942161	AE2-228 C	1.5941	Adder	1.88
942171	AE2-229 C	0.8448	Adder	0.99
942191	AE2-231 C O1	2.2128	Adder	2.6
942341	AE2-247 C	0.8426	Adder	0.99
942371	AE2-250 C O1	6.7404	Adder	7.93
942401	AE2-253 C	3.2293	Adder	3.8
942471	AE2-260 C O1	7.1645	Adder	8.43
942551	AE2-270	17.8270	Adder	20.97
943431	AF1-014 C	0.8535	Adder	1.0
943461	AF1-017 C	0.7623	Adder	0.9
943471	AF1-018	4.7631	Adder	5.6
943601	AF1-031 C	9.9823	80/20	9.9823
943611	AF1-032 C	0.9199	Adder	1.08
943621	AF1-033 C	1.4322	Adder	1.68
943741	AF1-042 C	1.7552	Adder	2.06
943991	AF1-067 C	4.9344	80/20	4.9344
944581	AF1-123 C O1	25.0863	Adder	29.51
944591	AF1-124 C O1	25.0863	Adder	29.51
944601	AF1-125 C O1	25.0863	Adder	29.51
944631	AF1-128 O1	49.1623	80/20	49.1623
944641	AF1-129	76.8810	Adder	90.45
944871	AF1-152 C	2.7305	Adder	3.21
945361	AF1-201 C O1	9.8494	Adder	11.59
945711	AF1-236 C O1	38.8641	Adder	45.72
946001	AF1-265	29.1555	80/20	29.1555
946011	AF1-266	7.0132	Adder	8.25
946261	AF1-291 C	1.5947	Adder	1.88
957411	AF2-035 C	4.0233	Adder	4.73
957491	AF2-043 C	1.1264	Adder	1.33
957531	AF2-047 C	8.4355	Adder	9.92
957601	AF2-054 C	1.3669	Adder	1.61
957631	AF2-057	1.9123	Adder	2.25
957711	AF2-065 C	9.0918	Adder	10.7
957821	AF2-076 C	2.7764	Adder	3.27
957831	AF2-077 C	1.3275	Adder	1.56
957871	AF2-081 C	5.2284	Adder	6.15
957911	AF2-085	2.0584	Adder	2.42

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
958141	AF2-108	1.1888	Adder	1.4
958161	AF2-110 C	0.7436	Adder	0.87
958261	AF2-120 C	3.7568	Adder	4.42
959641	AF2-255 C	0.5064	80/20	0.5064
959651	AF2-256 C	0.3985	Adder	0.47
959661	AF2-257 C	0.3987	Adder	0.47
959671	AF2-258 C	0.3789	Adder	0.45
959681	AF2-259 C	1.7832	Adder	2.1
960091	AF2-300 C	1.0058	Adder	1.18
961091	AF2-400 C	0.2356	Adder	0.28
961611	AG1-000B C	5.2231	Adder	11.59
961711	AG1-011	9.9910	Adder	22.18
961851	AG1-027 C	4.7644	Adder	10.58
961951	AG1-038 C	1.0282	Adder	2.28
962131	AG1-057	1.2622	Adder	2.8
962191	AG1-064 C	1.4123	80/20	1.4123
962201	AG1-065 C	1.4123	80/20	1.4123
962271	AG1-075 C O1	6.1657	Adder	13.69
962321	AG1-081 C (Withdrawn : 01/15/2021)	0.6901	Adder	1.53
962531	AG1-102 C	0.3612	Adder	0.8
962851	AG1-134 C	9.8688	80/20	9.8688
962861	AG1-135 C	1.9402	Adder	4.31
962961	AG1-145 C	0.7351	Adder	1.63
962971	AG1-146 C	1.0114	Adder	2.25
962981	AG1-147 C	2.3598	Adder	5.24
963221	AG1-171 C	0.7639	Adder	1.7
963231	AG1-172 C	0.7639	Adder	1.7
963241	AG1-173 C	0.7639	Adder	1.7
963251	AG1-174 C	0.7639	Adder	1.7
963261	AG1-175 C	0.7639	Adder	1.7
963291	AG1-178 C O1	8.9012	Adder	19.76
963341	AG1-183 C	1.5779	Adder	3.5
963351	AG1-184 O1	7.5174	Adder	16.69
963381	AG1-187	0.6433	Adder	1.43
963611	AG1-210 C	0.2021	Adder	0.45
963621	AG1-213 C	0.1777	Adder	0.39
963821	AG1-235 C O1	6.7197	Adder	14.92
964021	AG1-256 C	0.3910	Adder	0.87
964211	AG1-282 C	0.6321	Adder	1.4
964801	AG1-343 C	1.5171	Adder	3.37
964951	AG1-359 O1	7.4887	Adder	16.62
965001	AG1-364 C O1	2.0260	Adder	4.5
965181	AG1-383 C	0.7686	Adder	1.71
965231	AG1-388 C	0.6321	Adder	1.4
965291	AG1-394 C	0.5215	Adder	1.16
965631	AG1-431	11.9252	Adder	26.47
966491	AG1-518 O1	2.4874	Adder	5.52
966611	AG1-531 C	2.0603	Adder	4.57
966661	AG1-536 C	1.7118	Adder	3.8
966711	AG1-541 C	1.4216	Adder	3.16
966731	AG1-544 C	2.3216	Adder	5.15
966741	AG1-545 C	0.7727	Adder	1.72

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
966871	AG1-558 C	2.4847	80/20	2.4847
966881	AG1-559 C	0.5331	Adder	1.18
966931	AG1-431A	8.9595	Adder	19.89
WEC	WEC	0.0702	Confirmed LTF	0.0702
LGEE	LGEE	0.1502	Confirmed LTF	0.1502
CPL	CPL	3.2692	Confirmed LTF	3.2692
CBM-W2	CBM-W2	7.4816	Confirmed LTF	7.4816
NY	NY	0.7001	Confirmed LTF	0.7001
TVA	TVA	1.6660	Confirmed LTF	1.6660
SIGE	SIGE	0.1751	Confirmed LTF	0.1751
CBM-S2	CBM-S2	35.9554	Confirmed LTF	35.9554
CBM-S1	CBM-S1	0.3865	Confirmed LTF	0.3865
MEC	MEC	0.6896	Confirmed LTF	0.6896
LAGN	LAGN	2.0825	Confirmed LTF	2.0825
AA2-074	AA2-074	2.1551	LTF	2.1551
CBM-W1	CBM-W1	2.3133	Confirmed LTF	2.3133

11.6.9 Index 9

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168663026	314218	6ELMONT	DVP	314908	8ELMONT	DVP	1	DVP_P1-2: LN 557	single	920.92	145.15	146.09	DC	9.91

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
314229	6MT RD221	0.1400	80/20	0.1400
314236	6NRTHST	0.1840	80/20	0.1840
314241	6GOLDCHRC	0.8588	80/20	0.8588
314250	6ROCKVILLE	0.3160	80/20	0.3160
314309	6IRON208	0.3986	80/20	0.3986
315043	1FOUR RIVERA	3.1016	80/20	3.1016
315044	1FOUR RIVERB	3.1016	80/20	3.1016
315045	1FOUR RIVERC	3.7909	80/20	3.7909
315046	1FOUR RIVERD	3.1016	80/20	3.1016
315047	1FOUR RIVERE	3.1016	80/20	3.1016
315048	1FOUR RIVERF	3.7909	80/20	3.7909
315050	1FOURRIVERG	4.6424	80/20	4.6424
315051	1AA1-145 CT1	4.8822	80/20	4.8822
315052	1AA1-145 CT2	4.8822	80/20	4.8822
315058	1CHESTF3 (Deactivation : 13/12/2018)	16.7790	80/20	16.7790
315059	1CHESTF4 (Deactivation : 13/12/2018)	27.1988	80/20	27.1988
315060	1CHESTF5 (Deactivation : 31/05/2023)	56.3255	80/20	56.3255
315061	1CHESTG7	3.3185	80/20	3.3185
315062	1CHESTS7	1.5234	80/20	1.5234
315063	1CHESTG8	3.2651	80/20	3.2651
315064	1CHESTS8	1.6808	80/20	1.6808
315065	1CHESTF6 (Deactivation : 31/05/2023)	92.0429	Adder	108.29
315067	1DARBY 1	2.4776	80/20	2.4776
315068	1DARBY 2	2.4805	80/20	2.4805
315069	1DARBY 3	2.4892	80/20	2.4892
315070	1DARBY 4	2.4921	80/20	2.4921
315074	1HOPCGN1 (Deactivation : 25/06/2019)	0.0130	Adder	0.02
315075	1HOPCGN2 (Deactivation : 25/06/2019)	0.0130	Adder	0.02
315083	1SPRUNCA (Deactivation : 12/01/2021)	7.9136	Adder	9.31
315084	1SPRUNCB (Deactivation : 12/01/2021)	7.9136	Adder	9.31
316075	AC2-137 C	0.3008	80/20	0.3008
316083	AB2-161 C (Suspended)	2.1232	Adder	2.5
316103	AB2-015 C	4.3839	Adder	5.16
316108	AB2-160 C (Suspended)	3.8122	Adder	4.48

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
316112	AB2-068 CT1 (Withdrawn : 01/11/2021)	31.9131	Adder	37.54
316113	AB2-068 CT2 (Withdrawn : 01/11/2021)	31.9131	Adder	37.54
316114	AB2-068 ST (Withdrawn : 01/11/2021)	55.2860	Adder	65.04
316132	AB2-190 C	13.5146	Adder	15.9
316134	AC1-107 G1	59.9269	Adder	70.5
316135	AC1-107 G2	59.9269	Adder	70.5
316136	AC1-107 G3	59.9382	Adder	70.52
925863	AC1-065 C	4.9781	Adder	5.86
926754	AC1-161 C	15.7567	Adder	18.54
926784	AC1-164 C	29.4977	Adder	34.7
927044	AC1-191 C	11.1083	80/20	11.1083
932044	AC2-012 C	5.4753	Adder	6.44
932501	AC2-070 C	0.2822	80/20	0.2822
932581	AC2-078 C O1	2.5595	Adder	3.01
932591	AC2-079 C O1	3.3704	Adder	3.97
933294	AC2-141 C	15.7567	Adder	18.54
933991	AD1-023 C	6.3502	Adder	7.47
934014	AD1-025 C	11.1497	Adder	13.12
934061	AD1-033 C	3.9781	Adder	4.68
934141	AD1-041 C	3.5195	Adder	4.14
934521	AD1-076 C	26.4390	Adder	31.1
934575	AD1-082 C	4.8388	Adder	5.69
934781	AD1-105 C	7.5069	80/20	7.5069
935164	AD1-151 C	10.8599	Adder	12.78
936041	AD2-007 C	0.5326	Adder	0.63
936051	AD2-008 C	1.9411	Adder	2.28
936151	AD2-021	0.0343	80/20	0.0343
936581	AD2-073 C	1.1801	Adder	1.39
936591	AD2-074 C	3.3700	Adder	3.96
936661	AD2-085 C	1.9517	Adder	2.3
936761	AD2-097 C	1.5009	Adder	1.77
937221	AD2-160 C O1	3.0844	Adder	3.63
938535	AE1-072 C	9.2607	Adder	10.89
938634	AE1-085 C	5.6346	Adder	6.63
938771	AE1-103 C	1.8889	Adder	2.22
939195	AE1-149 C	6.8932	Adder	8.11
939245	AE1-155 C	7.7061	Adder	9.07
939414	AE1-173_C1	14.0744	Adder	16.56
939415	AE1-173_C2	12.0637	Adder	14.19
939416	AE1-173_C3	14.0744	Adder	16.56
939431	AE1-175 C	1.5443	Adder	1.82
939611	AE1-191 C	7.0390	Adder	8.28
939755	AE1-206 C	33.3912	80/20	33.3912
940061	AE2-000BC O1	6.6535	Adder	7.83
940231	AE2-005 C	0.9051	Adder	1.06
940251	AE2-007 O1 (Withdrawn : 12/11/2020)	92.7570	Adder	109.13
940431	AE2-027 C O1	9.5148	Adder	11.19
940481	AE2-033 C	8.4168	Adder	9.9
940491	AE2-034 C	3.5664	Adder	4.2

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
940541	AE2-040	1.5052	Adder	1.77
940551	AE2-041	4.7852	Adder	5.63
940651	AE2-052	2.2977	Adder	2.7
940891	AE2-078 C	1.4390	Adder	1.69
940901	AE2-079 C	1.4390	Adder	1.69
941101	AE2-104 C O1	1.8121	Adder	2.13
941281	AE2-122 C O1	15.1327	Adder	17.8
941291	AE2-123 C O1	15.5517	Adder	18.3
941301	AE2-124 C O1	14.1296	Adder	16.62
941501	AE2-147 C	8.2299	Adder	9.68
941581	AE2-155 C	0.1074	80/20	0.1074
941591	AE2-156 O1	9.5999	Adder	11.29
942001	AE2-212 C	1.5226	Adder	1.79
942131	AE2-225 C	1.1317	Adder	1.33
942151	AE2-227 C	2.0350	80/20	2.0350
942161	AE2-228 C	1.6015	Adder	1.88
942171	AE2-229 C	0.8488	Adder	1.0
942191	AE2-231 C O1	2.2229	Adder	2.62
942341	AE2-247 C	0.8465	Adder	1.0
942371	AE2-250 C O1	6.7716	Adder	7.97
942401	AE2-253 C	3.2442	Adder	3.82
942471	AE2-260 C O1	7.1975	Adder	8.47
942551	AE2-270	17.9099	Adder	21.07
943431	AF1-014 C	0.8575	Adder	1.01
943461	AF1-017 C	0.7659	Adder	0.9
943471	AF1-018	4.7852	Adder	5.63
943601	AF1-031 C	10.0284	80/20	10.0284
943611	AF1-032 C	0.9242	Adder	1.09
943621	AF1-033 C	1.4390	Adder	1.69
943741	AF1-042 C	1.7634	Adder	2.07
943991	AF1-067 C	4.9572	80/20	4.9572
944581	AF1-123 C O1	25.2045	Adder	29.65
944591	AF1-124 C O1	25.2045	Adder	29.65
944601	AF1-125 C O1	25.2045	Adder	29.65
944631	AF1-128 O1	49.3894	80/20	49.3894
944641	AF1-129	77.2341	Adder	90.86
944871	AF1-152 C	2.7433	Adder	3.23
945361	AF1-201 C O1	9.8953	Adder	11.64
945711	AF1-236 C O1	39.0439	Adder	45.93
946001	AF1-265	29.2905	80/20	29.2905
946011	AF1-266	7.0455	Adder	8.29
946261	AF1-291 C	1.6021	Adder	1.88
957411	AF2-035 C	4.0416	Adder	4.75
957491	AF2-043 C	1.1317	Adder	1.33
957531	AF2-047 C	8.4745	Adder	9.97
957601	AF2-054 C	1.3733	Adder	1.62
957631	AF2-057	1.9212	Adder	2.26
957711	AF2-065 C	9.1341	Adder	10.75
957821	AF2-076 C	2.7894	Adder	3.28
957831	AF2-077 C	1.3337	Adder	1.57
957871	AF2-081 C	5.2522	Adder	6.18
957911	AF2-085	2.0679	Adder	2.43

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
958141	AF2-108	1.1942	Adder	1.4
958161	AF2-110 C	0.7471	Adder	0.88
958261	AF2-120 C	3.7742	Adder	4.44
959641	AF2-255 C	0.5087	80/20	0.5087
959651	AF2-256 C	0.4004	Adder	0.47
959661	AF2-257 C	0.4005	Adder	0.47
959671	AF2-258 C	0.3806	Adder	0.45
959681	AF2-259 C	1.7914	Adder	2.11
960091	AF2-300 C	1.0104	Adder	1.19
961091	AF2-400 C	0.2367	Adder	0.28
961611	AG1-000B C	5.2476	Adder	11.65
961711	AG1-011	10.0371	Adder	22.28
961851	AG1-027 C	4.7866	Adder	10.63
961951	AG1-038 C	1.0330	Adder	2.29
962131	AG1-057	1.2681	Adder	2.81
962191	AG1-064 C	1.4189	80/20	1.4189
962201	AG1-065 C	1.4189	80/20	1.4189
962271	AG1-075 C O1	6.1943	Adder	13.75
962321	AG1-081 C (Withdrawn : 01/15/2021)	0.6933	Adder	1.54
962531	AG1-102 C	0.3628	Adder	0.81
962851	AG1-134 C	9.9144	80/20	9.9144
962861	AG1-135 C	1.9491	Adder	4.33
962961	AG1-145 C	0.7385	Adder	1.64
962971	AG1-146 C	1.0161	Adder	2.26
962981	AG1-147 C	2.3708	Adder	5.26
963221	AG1-171 C	0.7674	Adder	1.7
963231	AG1-172 C	0.7674	Adder	1.7
963241	AG1-173 C	0.7674	Adder	1.7
963251	AG1-174 C	0.7674	Adder	1.7
963261	AG1-175 C	0.7674	Adder	1.7
963291	AG1-178 C O1	8.9423	Adder	19.85
963341	AG1-183 C	1.5851	Adder	3.52
963351	AG1-184 O1	7.5521	Adder	16.76
963381	AG1-187	0.6462	Adder	1.43
963611	AG1-210 C	0.2030	Adder	0.45
963621	AG1-213 C	0.1785	Adder	0.4
963821	AG1-235 C O1	6.7507	Adder	14.98
964021	AG1-256 C	0.3928	Adder	0.87
964211	AG1-282 C	0.6351	Adder	1.41
964801	AG1-343 C	1.5242	Adder	3.38
964951	AG1-359 O1	7.5231	Adder	16.7
965001	AG1-364 C O1	2.0355	Adder	4.52
965181	AG1-383 C	0.7721	Adder	1.71
965231	AG1-388 C	0.6351	Adder	1.41
965291	AG1-394 C	0.5238	Adder	1.16
965631	AG1-431	11.9803	Adder	26.59
966491	AG1-518 O1	2.4991	Adder	5.55
966611	AG1-531 C	2.0699	Adder	4.59
966661	AG1-536 C	1.7197	Adder	3.82
966711	AG1-541 C	1.4280	Adder	3.17
966731	AG1-544 C	2.3324	Adder	5.18
966741	AG1-545 C	0.7762	Adder	1.72

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
966871	AG1-558 C	2.4962	80/20	2.4962
966881	AG1-559 C	0.5355	Adder	1.19
966931	AG1-431A	9.0010	Adder	19.98
WEC	WEC	0.0706	Confirmed LTF	0.0706
LGEE	LGEE	0.1508	Confirmed LTF	0.1508
CPL	CPL	3.2849	Confirmed LTF	3.2849
CBM-W2	CBM-W2	7.5085	Confirmed LTF	7.5085
NY	NY	0.7034	Confirmed LTF	0.7034
TVA	TVA	1.6744	Confirmed LTF	1.6744
SIGE	SIGE	0.1759	Confirmed LTF	0.1759
CBM-S2	CBM-S2	36.1224	Confirmed LTF	36.1224
CBM-S1	CBM-S1	0.3884	Confirmed LTF	0.3884
MEC	MEC	0.6912	Confirmed LTF	0.6912
LAGN	LAGN	2.0913	Confirmed LTF	2.0913
AA2-074	AA2-074	2.1654	LTF	2.1654
CBM-W1	CBM-W1	2.3273	Confirmed LTF	2.3273

11.7 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AA1-145	Four Rivers 230kV	In Service
AA2-074	CPLP-PJM	Confirmed
AB2-015	Franklin 115kV	Engineering and Procurement
AB2-068	Chickahominy 500kV	Withdrawn
AB2-160	Reams 115kV	Suspended
AB2-161	Waverly #2 DP 115kV	Suspended
AB2-190	Hopewell-Surry 230kV	Engineering and Procurement
AC1-065	Harmony Village-Shackleford 115kV	Engineering and Procurement
AC1-107	Chickahominy 500kV	Engineering and Procurement
AC1-161	Septa 500kV	Engineering and Procurement
AC1-164	Chickahominy 230kV	Engineering and Procurement
AC1-191	Elmont 115kV	Active
AC2-012	Grassfield-Great Bridge 115kV	Active
AC2-070	Old Church 34.5kV	Engineering and Procurement
AC2-078	Disputanta-Waverly 115kV	Engineering and Procurement
AC2-079	Ivor-Oak Ridge 115kV	Engineering and Procurement
AC2-137	Elko 34.5kV	Partially in Service - Under Construction
AC2-138	Northern Neck 34.5kV	Partially in Service - Under Construction
AC2-141	Septa 500kV	Active
AD1-023	Cashie-Trowbridge 230 kV	Active
AD1-025	Hopewell-Surry 230 kV	Active
AD1-033	Fentress-Landstown 230 kV	Engineering and Procurement
AD1-041	Harmony Village-Shackleford 115 kV	Engineering and Procurement
AD1-076	Trowbridge 230 kV	Active
AD1-082	Bakers Pond-Ivor 115kV	Engineering and Procurement
AD1-105	Kings Dominion DP 115 kV	Active
AD1-151	Hopewell-Surry 230 kV	Active
AD2-007	Hopewell-Surry 230 kV	Active
AD2-008	Hopewell-Surry 230 kV	Active
AD2-021	Elko 34.5 kV	Partially in Service - Under Construction
AD2-030	Wan 34.5 kV	In Service
AD2-073	Sanders DP 230 kV	Active
AD2-074	Garner DP-Lancaster 115 kV	Active
AD2-085	Myrtle-Windsor DP 115kV	Active
AD2-097	Spruance NUG 230kV	In Service
AD2-160	Hickory-Moyock 230kV	Active
AE1-072	Shawboro-Sligo 230 kV	Active
AE1-085	Bakers Pond-Bell Ave 115 kV	Active
AE1-103	Holland-Union Camp 115 kV	Active

Queue Number	Project Name	Status
AE1-124	Oak Grove 34.5 kV	Engineering and Procurement
AE1-149	Disputanta-Poe 115 kV	Active
AE1-155	Garner-Northern Neck 115 kV	Active
AE1-157	Ladysmith CT-St. Johns 230 kV	Active
AE1-158	Ladysmith CT-St. Johns 230 kV	Active
AE1-173	Carson-Suffolk 500 kV	Active
AE1-175	Light Foot 34.5 kV	Engineering and Procurement
AE1-191	Harmony Village-Shackleford 115 kV	Active
AE1-206	Four Rivers-Hanover 230 kV	Active
AE2-000B	N/A	N/A
AE2-005	Harmony Village-Shackleford 115 kV	Engineering and Procurement
AE2-007	Chesapeake 230 kV	Withdrawn
AE2-027	Harrowgate-Locks 115kV	Active
AE2-033	Clubhouse-Sappony 230 kV	Active
AE2-034	Mackeys 230 kV	Active
AE2-040	Sapony 34.5 kV	Active
AE2-041	Harmony Village 230 kV	Active
AE2-052	Disputanta-Poe 115 kV	Active
AE2-078	Poolesville 34.5 kV	Engineering and Procurement
AE2-079	Poolesville 34.5 kV	Engineering and Procurement
AE2-104	Suffolk 115 kV	Active
AE2-122	Birdneck-Landstown 230 kV	Active
AE2-123	Birdneck-Landstown 230 kV	Active
AE2-124	Landstown 230 kV	Active
AE2-147	Swamp 230 kV	Active
AE2-155	Old Church 34.5 kV	Partially in Service - Under Construction
AE2-156	Yadkin 115 kV	Active
AE2-212	Harrowgate 34 kV	Active
AE2-225	Suffolk 34 kV	Engineering and Procurement
AE2-227	Iron Bridge 34 kV	Engineering and Procurement
AE2-228	Tyler 34 kV	Engineering and Procurement
AE2-229	Suffolk 34 kV	Engineering and Procurement
AE2-231	St. Johns 115 kV	Active
AE2-247	Myrtle-Windsor 115 kV	Active
AE2-250	Purdy Sw.-Reams 115 kV	Active
AE2-253	Hickory-Moyock 230 kV	Active
AE2-260	Clubhouse 230 kV	Active
AE2-270	Hopewell-Surry 230 kV	Active
AF1-014	Harmony Village-Shackleford 115 kV	Active
AF1-017	Myrtle-Windsor 115 kV	Active
AF1-018	Harmony Village 230 kV	Active
AF1-031	Kings Dominion DP 115 kV	Active
AF1-032	Suffolk 34.5 kV	Engineering and Procurement
AF1-033	Poolesville 34 kV	Engineering and Procurement
AF1-042	Garner DP-Lancaster 115 kV	Active
AF1-067	Kings Dominion DP 115 kV	Active
AF1-114	Oak Grove-Dahlgren 230 kV	Active
AF1-123	Fentress 500 kV	Active
AF1-124	Fentress 500 kV	Active
AF1-125	Fentress 500 kV	Active
AF1-128	Chesterfield 230 kV	Active
AF1-129	Chesterfield 230 kV	Active

Queue Number	Project Name	Status
AF1-152	Swamp 230 kV	Active
AF1-201	Hayes-White Marsh 115 kV	Active
AF1-236	Mackeys 230 kV	Active
AF1-248	Northern Neck 34.5 kV	Partially in Service - Under Construction
AF1-265	Four Rivers-Hanover 230 kV	Active
AF1-266	Clubhouse-Sapony 230 kV	Active
AF1-291	Tyler 34.5 kV	Engineering and Procurement
AF2-013	Arnold's Corner-Dahlgren 230 kV	Active
AF2-035	St. Johns 115 kV	Active
AF2-043	Suffolk 34.5 kV	Engineering and Procurement
AF2-047	Creswell-Riders Creek 115 kV	Active
AF2-049	Ladysmith CT-St. Johns 230 kV	Active
AF2-054	Wan 34.5 kV	Active
AF2-057	Grassfield 34.5 kV	Active
AF2-065	Surry-Hopewell 230 kV	Active
AF2-076	Suffolk-Nucor Steel 230 kV	Active
AF2-077	White Marsh 34.5 kV	Active
AF2-081	Moyock 230 kV	Active
AF2-085	Midlothian 34.5 kV	Engineering and Procurement
AF2-091	Oak Grove-Dahlgren 230 kV	Active
AF2-108	Locks 34.5 kV	Active
AF2-110	Suffolk 115 kV	Active
AF2-120	Garner-Northern Neck 115 kV	Active
AF2-255	Iron Bridge 34.5 kV	Engineering and Procurement
AF2-256	Tyler 34.5 kV	Engineering and Procurement
AF2-257	Tyler 34.5 kV	Active
AF2-258	Harrowgate 34.5 kV	Active
AF2-259	Locks 34.5 kV	Active
AF2-300	St. Johns 115 kV	Active
AF2-400	Franklin 13.2 kV	Engineering and Procurement
AG1-000B	N/A	N/A
AG1-011	Colonial Trial 230 kV	Active
AG1-019	Arnold's Corner-Dahlgren 230 kV	Active
AG1-027	Suffolk-Holland 115 kV	Active
AG1-038	Garner DP-Lancaster 115 kV	Active
AG1-057	Harmony Village 230 kV	Active
AG1-064	Plaza 34.5 kV	Active
AG1-065	Plaza 34.5 kV	Active
AG1-075	Purdy-Sapony 115 kV	Active
AG1-081	Poolesville 34.5 kV	Withdrawn
AG1-102	White Marsh 34.5 kV	Active
AG1-134	Kings Dominion DP 115 kV	Active
AG1-135	Garner-Lancaster 115 kV	Active
AG1-145	Lightfoot 34.5 kV	Active
AG1-146	Garner DP-Lancaster 115 kV	Active
AG1-147	Garner DP-Lancaster 115 kV	Active
AG1-154	Ladysmith CT 230 kV	Active
AG1-171	Hopewell-Surry 230kV	Active
AG1-172	Hopewell-Surry 230 kV	Active
AG1-173	Hopewell-Surry 230 kV	Active
AG1-174	Hopewell-Surry 230 kV	Active
AG1-175	Hopewell-Surry 230 kV	Active

Queue Number	Project Name	Status
AG1-178	Carson-Septa 500 kV	Active
AG1-183	St. Johns DP-REC 115 kV	Active
AG1-184	Carson-Septa 500 kV	Active
AG1-187	St. Johns DP-REC 115 kV	Active
AG1-210	Northern Neck 34.5 kV	Active
AG1-213	St Johns 13.2 kV	Active
AG1-235	Fentress-Sligo 230 kV	Active
AG1-256	Northern Neck 230 kV	Active
AG1-282	Dunnsville 34.5 kV	Active
AG1-322	Birchwood 230 kV	Active
AG1-343	Boykins-Murphy 115 kV	Active
AG1-359	Fentress 230 kV	Active
AG1-364	Deep Creek 115 kV	Active
AG1-383	Hickory 34.5 kV	Active
AG1-388	Dunnsville 34.5 kV	Active
AG1-394	Boykins 34.5 kV	Active
AG1-412	Ladysmith CT-Mine Road 230 kV	Active
AG1-431	Mackeys 230 kV	Active
AG1-431A	Mackeys 230 kV	Active
AG1-518	Suffolk 230 kV	Active
AG1-531	Poolesville-Winchester 230 kV	Active
AG1-536	Garner-Northern Neck 115 kV	Active
AG1-541	St. Johns 115 kV	Active
AG1-544	Bakers Pond DP 115 kV	Active
AG1-545	W. Quaker Rd-Disputanta 34.5 kV	Active
AG1-558	Buckner 34.5 kV	Active
AG1-559	Caroline Pines 22 kV	Active

11.8 Contingency Descriptions

Contingency Name	Contingency Definition
DVP_P1-2: LN 557	CONTINGENCY 'DVP_P1-2: LN 557' OPEN BRANCH FROM BUS 314903 TO BUS 314908 CKT 1 /* 8CHCKAHM 500.00 - 8ELMONT 500.00 END
DVP_P1-2: LN 73	CONTINGENCY 'DVP_P1-2: LN 73' OPEN BRANCH FROM BUS 314217 TO BUS 314221 CKT 1 /* 3ELMONT 115.00 - 3HANOVER 115.00 OPEN BRANCH FROM BUS 314220 TO BUS 314221 CKT 1 /* 3FOURRIVERS 115.00 - 3HANOVER 115.00 OPEN BRANCH FROM BUS 314221 TO BUS 314405 CKT 1 /* 3HANOVER 115.00 - 3HANOV_1 115.00 OPEN BUS 314221 /* ISLAND: 3HANOVER 115.00 OPEN BUS 314405 /* ISLAND: 3HANOV_1 115.00 END
DVP_P1-2: LN 568	CONTINGENCY 'DVP_P1-2: LN 568' OPEN BRANCH FROM BUS 314911 TO BUS 314922 CKT 1 /* 8LADYSMITH 500.00 - 8POSSUM 500.00 END
DVP_P1-2: LN 47	CONTINGENCY 'DVP_P1-2: LN 47' OPEN BRANCH FROM BUS 314136 TO BUS 314151 CKT 1 /* 3FREDBRG 115.00 - 3SLABTWN 115.00 OPEN BRANCH FROM BUS 314151 TO BUS 314153 CKT 1 /* 3SLABTWN 115.00 - 3WOODPCK 115.00 OPEN BRANCH FROM BUS 314152 TO BUS 314153 CKT 1 /* 3S JOHNS 115.00 - 3WOODPCK 115.00 OPEN BRANCH FROM BUS 314152 TO BUS 314216 CKT 1 /* 3S JOHNS 115.00 - 3PINWOOD 115.00 OPEN BUS 314151 /* ISLAND: 3SLABTWN 115.00 OPEN BUS 314152 /* ISLAND: 3S JOHNS 115.00 OPEN BUS 314153 /* ISLAND: 3WOODPCK 115.00 END
DVP_P1-2: LN 2089	CONTINGENCY 'DVP_P1-2: LN 2089' OPEN BRANCH FROM BUS 314196 TO BUS 314197 CKT 1 /* 6LADYSMITH 230.00 - 6LDYSMITH CT230.00 END
Base Case	
314212 6FOUR RIVERS 230 939750 AE1-206 TAP 230 1	CONTINGENCY '314212 6FOUR RIVERS 230 939750 AE1-206 TAP 230 1' OPEN BRANCH FROM BUS 314212 TO BUS 939750 CKT 1 END

Contingency Name	Contingency Definition
314222 6HANOVER 230 939750 AE1-206 TAP 230 1	CONTINGENCY '314222 6HANOVER 230 939750 AE1-206 TAP 230 1' OPEN BRANCH FROM BUS 314222 TO BUS 939750 CKT 1 END

12 Short Circuit Analysis

The following Breakers are overdutied:

None.

12.1 System Reinforcements - Short Circuit

No short circuit impacts were identified for this project.

13 Affected Systems

13.1 TVA

TVA Impacts to be determined during later study phases (as applicable).

13.2 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

14 Attachment 1: One Line Diagram