



**Generation Interconnection
Feasibility Study Report
for
Queue Project AG1-310
CRYSTAL HILL-PERTH 115 KV
13.4 MW Capacity / 20 MW Energy**

January 2021

Table of Contents

- 1 Introduction..... 4
- 2 Preface..... 4
- 3 General..... 5
- 4 Point of Interconnection..... 6
 - 4.1 Primary Point of Interconnection 6
 - 4.2 Secondary Point of Interconnection..... 6
- 5 Cost Summary 6
- 6 Transmission Owner Scope of Work..... 7
- 7 Schedule..... 8
- 8 Transmission Owner Analysis..... 8
 - 8.1 Power Flow Analysis 8
- 9 Interconnection Customer Requirements..... 9
 - 9.1 System Protection..... 9
 - 9.2 Compliance Issues and Interconnection Customer Requirements 9
 - 9.3 Power Factor Requirements..... 9
- 10 Revenue Metering and SCADA Requirements10
 - 10.1 PJM Requirements10
 - 10.2 Meteorological Data Reporting Requirements10
 - 10.3 Interconnected Transmission Owner Requirements.....10
- 11 Summer Peak - Load Flow Analysis11
 - 11.1 Generation Deliverability11
 - 11.2 Multiple Facility Contingency11
 - 11.3 Contribution to Previously Identified Overloads.....11
 - 11.4 Potential Congestion due to Local Energy Deliverability.....11
 - 11.5 System Reinforcements - Summer Peak Load Flow - Primary POI.....13
 - 11.6 Flow Gate Details.....14
 - 11.6.1 Index 115
 - 11.6.2 Index 217
 - 11.6.3 Index 320
 - 11.7 Queue Dependencies23
 - 11.8 Contingency Descriptions.....25

12 Short Circuit Analysis.....27
12.1 System Reinforcements - Short Circuit.....27
13 Affected Systems28
13.1 TVA.....28
13.2 Duke Energy Progress.....28
14 Attachment 1: One Line Diagram29

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Dominion.

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in Halifax County, Virginia. The installed facilities will have a total capability of 20 MW with 13.4 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is October 03, 2022. This study does not imply a TO commitment to this in-service date.

Queue Number	AG1-310
Project Name	CRYSTAL HILL-PERTH 115 KV
State	Virginia
County	Halifax
Transmission Owner	Dominion
MFO	20
MWE	20
MWC	13.4
Fuel	Solar
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

4.1 Primary Point of Interconnection

AG1-310 "Crystal Hill-Perth 115 kV" will interconnect with the Dominion transmission system. The primary POI will be a newly constructed 115 kV three breaker ring bus located on the line between the Crystal Hill substation and Perth substation.

The IC is responsible for securing right-of-way, permits, and constructing the proposed attachment line from the generating facility site to the Point of Interconnection. The IC may not install any facilities on Dominion's right-of-way without first obtaining the necessary approval from Dominion Energy.

Attachment 1 shows a one-line diagram of the proposed interconnection facilities.

4.2 Secondary Point of Interconnection

There is no secondary point of interconnection specified for AG1-310.

5 Cost Summary

The AG1-310 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$ 8,800,000
Total System Network Upgrade Costs	\$ 7,570,000 ¹
Total Costs	\$16,370,000

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 2016-36, 2016-25 I.R.B. (6/20/2016). If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

¹ This project currently causes and/or contributes to overloads of the Transmission System (see Summer Peak Load Flow Analysis section below) and therefore has potential to have cost allocation for the system reinforcements listed in the report. This will be re-evaluated in the System Impact phase. The results may vary with queue customers withdrawing from the queue and other generators deactivating over time. If a customer is the first to cause the need for a project (causes loading to exceed 100% of rating), then the customer is responsible. If a customer contributes to a facility that is already overloaded by a prior queue, then they may receive cost allocation.

6 Transmission Owner Scope of Work

The required Attachment Facilities, Direct Connection and Non-Direct Connection work for the interconnection of AG1-310 to the Dominion Transmission System is detailed in the following sections. The associated one-line showing the generation project attachment facilities and primary direct and non-direct connection is shown in Attachment 1.

Note that the ITO findings were made from a conceptual review of this project. A more detailed review of the connection facilities and their cost will be identified in a future study phase. Further note that the cost estimate data contained in this document should be considered high level estimates since it was produced without a detailed engineering review. The applicant will be responsible for the actual cost of construction. ITO herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any reinforcements to the transmission systems.

The total physical interconnection costs are given in the table below:

Description	Total Cost
<i>Attachment Facilities</i>	\$1,700,000
<i>115 kV Three Breaker Ring-Bus Substation</i>	\$5,500,000
<i>Re-arrange line and tie-in new substation</i>	\$1,600,000
Total Physical Interconnection Costs	\$8,800,000

AG1-310 "Crystal Hill-Perth 115 kV" will interconnect with the Dominion transmission system. The primary POI will be a newly constructed 115 kV three breaker ring bus located on the line between the Crystal Hill substation and Perth substation.

It is estimated to take 18-30 months to complete this work upon execution of an Interconnection Construction Service Agreement (ICSA). These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase.

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

7 Schedule

The estimated schedule for the Attachment Facilities, Direct Connection and Non-Direct Connection work is identified in the “Transmission Owner Scope of Work” section of this report.

The estimated schedule for the required Network Impact Reinforcements is identified in the “System Reinforcements” section of this report.

If the customer is ultimately responsible for network upgrades, then the schedule for those upgrades will be refined in future study phases. The customer would need to wait for those upgrades to be completed prior to commercial operation unless determined deliverable by an interim deliverability study. The elapsed time to complete any network upgrades is provided in the System Reinforcements table of this report.

8 Transmission Owner Analysis

Dominion assessed the impact of the proposed AG1-310 for compliance with NERC Reliability Criteria on the Dominion Transmission System. The system was assessed using the summer 2024 AG1 case provided to Dominion by PJM.

When performing a generation analysis, Dominion’s main analysis includes load flow study results following a single contingency event for both normal and stressed system conditions. Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion’s Planning Criteria and interconnection requirements can be found in the Company’s Facility Connection Requirements which are publicly available at:

<http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically, in Planning Studies, NERC Planning Event 3 and 6 Contingency Conditions (Loss of generator, transmission circuit, transformer, shunt device, or Single Pole of a DC line followed by the loss of a generator, transmission circuit, transformer, shunt device or single pole of a DC line) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

8.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2024 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system and no further deficiencies were identified.

9 Interconnection Customer Requirements

9.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion’s “Dominion Energy Electric Transmission Generator Interconnection Requirements” documented in Dominion’s Facility Interconnection Requirements “Exhibit C” located at:

<https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

9.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion’s “Dominion’s Facility Interconnection Requirements” document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC’s GSU transformer(s).
1. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection section noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
2. The purchase and installation of supervisory control and data acquisition (“SCADA”) equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
3. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion’s “Dominion’s Facility Interconnection Requirements” document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

9.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 Meteorological Data Reporting Requirements

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Back Panel temperature (Fahrenheit) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Irradiance (Watts/meter²) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Ambient air temperature (Fahrenheit) - (Accepted, not required)
- Wind speed (meters/second) - (Accepted, not required)
- Wind direction (decimal degrees from true north) - (Accepted, not required)

10.3 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

11 Summer Peak - Load Flow Analysis

The Queue Project AG1-310 was evaluated as a 20.0 MW (Capacity 13.4 MW) injection tapping the Crystal Hill to Perth 115 kV line in the Dominion area. Project AG1-310 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-310 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJE CT LOADIN G %	POST PROJE CT LOADIN G %	AC D C	MW IMPAC T
163711897	314667	4ALTVSTA	138.0	DVP	242741	05OTTE R	138.0	AEP	1	DVP_P1-2: LN 1016-A	single	245.0	118.91	121.14	DC	5.45
169195683	314696	3SEEDGE HILL	115.0	DVP	314697	6SEEDGE HILL	230.0	DVP	1	DVP_P1-3: 6SEEDGE HILL-TX#2	single	226.727996826	142.87	145.9	DC	6.87
169195685	314696	3SEEDGE HILL	115.0	DVP	314697	6SEEDGE HILL	230.0	DVP	1	DVP_P1-2: LN 31-A	single	226.727996826	109.01	111.34	DC	5.27
169195699	314696	3SEEDGE HILL	115.0	DVP	314697	6SEEDGE HILL	230.0	DVP	2	DVP_P1-3: 6SEEDGE HILL-TX#1	single	256.055999756	126.12	128.8	DC	6.85

11.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection

Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	KV	FROM BUS AREA	TO BUS#	TO BUS	KV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168183455	242687	05JOHNMT	138.0	AEP	242734	05NEWLDN	138.0	AEP	1	Base Case	operation	167.0	179.54	180.06	DC	1.92
168183447	242741	05OTTER	138.0	AEP	242687	05JOHNMT	138.0	AEP	1	Base Case	operation	167.0	187.56	188.08	DC	1.92
169195792	314666	3ALTVSTA	115.0	DVP	314667	4ALTVSTA	138.0	DVP	2	DVP_P1-2:LN 1016-D	operation	130.472000122	128.87	137.06	DC	10.69
169195845	314666	3ALTVSTA	115.0	DVP	314667	4ALTVSTA	138.0	DVP	1	DVP_P1-3:4ALTVSTA-TX#4	operation	126.524002075	109.02	111.82	DC	3.54
163711891	314667	4ALTVSTA	138.0	DVP	242741	05OTTER	138.0	AEP	1	Base Case	operation	167.0	189.47	189.99	DC	1.92
163711892	314667	4ALTVSTA	138.0	DVP	242741	05OTTER	138.0	AEP	1	DVP_P1-2:LN 1016-A	operation	245.0	162.51	165.83	DC	8.14
169195898	314688	3CRSTLHILL	115.0	DVP	927260	AC1-222TAP	115.0	DVP	1	AEP_P1-2_#375_5201	operation	285.760009766	107.23	112.8	DC	15.93
169195976	314690	6BLACKWALNU	230.0	DVP	314686	6CLOVER	230.0	DVP	1	DVP_P1-2:LN 296-A	operation	814.979980469	99.99	101.28	DC	10.57
169195825	314694	3GRIT	115.0	DVP	314712	3OTTER R	115.0	DVP	1	DVP_P1-2:LN 1016-D	operation	285.760009766	119.42	126.42	DC	19.99
169195681	314696	3SEEDGEHILL	115.0	DVP	314697	6SEEDGEHILL	230.0	DVP	1	DVP_P1-3:6SEEDGEHILL-TX#2	operation	226.727996826	216.94	221.45	DC	10.25
169195684	314696	3SEEDGEHILL	115.0	DVP	314697	6SEEDGEHILL	230.0	DVP	1	Base Case	operation	223.531997681	124.98	127.7	DC	6.07
169195697	314696	3SEEDGEHILL	115.0	DVP	314697	6SEEDGEHILL	230.0	DVP	2	DVP_P1-3:6SEEDGEHILL-TX#1	operation	256.055999756	191.51	195.49	DC	10.22
169195700	314696	3SEEDGEHILL	115.0	DVP	314697	6SEEDGEHILL	230.0	DVP	2	Base Case	operation	253.235992432	109.21	111.59	DC	6.02
169195659	314697	6SEEDGEHILL	230.0	DVP	927250	AC1-221TAP	230.0	DVP	1	DVP_P1-2:LN 556-D	operation	674.91998291	237.42	238.68	DC	8.53
169195663	314697	6SEEDGEHILL	230.0	DVP	927250	AC1-221TAP	230.0	DVP	1	Base Case	operation	509.480010986	119.88	121.01	DC	5.73
169195817	314712	3OTTER R	115.0	DVP	314666	3ALTVSTA	115.0	DVP	1	DVP_P1-2:LN 1016-D	operation	269.779998779	119.19	126.6	DC	19.99
169195854	314714	3PERTH	115.0	DVP	942750	AE2-291TAP	115.0	DVP	1	DVP_P1-2:LN 556-D	operation	285.760009766	108.83	110.56	DC	4.91
163711855	927250	AC1-221TAP	230.0	DVP	304070	6PERSON230T	230.0	CPL	1	DVP_P1-2:LN 556-D	operation	718.0	240.52	241.71	DC	8.53
163711865	927250	AC1-221TAP	230.0	DVP	304070	6PERSON230T	230.0	CPL	1	Base Case	operation	542.0	131.16	132.22	DC	5.73
169195820	927260	AC1-222TAP	115.0	DVP	314696	3SEEDGEHILL	115.0	DVP	1	DVP_P1-2:LN 31-A	operation	285.760009766	120.5	127.5	DC	19.99
169195822	927260	AC1-222TAP	115.0	DVP	314696	3SEEDGEHILL	115.0	DVP	1	Base Case	operation	285.760009766	95.62	101.03	DC	15.45
169678586	942750	AE2-291TAP	115.0	DVP	314694	3GRIT	115.0	DVP	1	DVP_P1-2:LN 1016-D	operation	285.760009766	120.5	127.5	DC	19.99
169195849	964470	AG1-310TAP	115.0	DVP	314688	3CRSTLHILL	115.0	DVP	1	AEP_P1-2_#375_5201	operation	285.760009766	113.24	118.82	DC	15.93

11.5 System Reinforcements - Summer Peak Load Flow - Primary POI

ID	Idx	Facility	Upgrade Description	Cost
163711897	1	4ALTVSTA 138.0 kV - 05OTTER 138.0 kV Ckt 1	<p><u>AEP</u> AEPA0014a (77) : Rebuild / reconductor 0.9 miles of overhead conductor (ACSR ~ 397.5 ~ 30/7 ~ LARK) Project Type : FAC Cost : \$1,350,000 Time Estimate : 24-36 Months</p> <p>AEPA0014b (78) : Replace 795 AAC station conductors at Altavista Project Type : FAC Cost : \$100,000 Time Estimate : 12-18 Months</p> <p><u>DVP</u> dom-001 (1170) : Relay Change Outs (Secondary) at Altavista Substation Project Type : FAC Cost : \$120,000 Time Estimate : 6-12 Months</p>	\$1,570,000
169195683,169195685	2	3SEEDGE HILL 115.0 kV - 6SEEDGE HILL 230.0 kV Ckt 1	<p><u>DVP</u> dom-046 (1225) : Add additional 230/115 kV transformer at Sedge Hill substation. Project Type : CON Cost : \$6,000,000 Time Estimate : 16-18 Months</p>	\$6,000,000
169195699	3	3SEEDGE HILL 115.0 kV - 6SEEDGE HILL 230.0 kV Ckt 2	<p><u>DVP</u> dom-046 (1225) : Add additional 230/115 kV transformer at Sedge Hill substation. Project Type : CON Cost : \$6,000,000 Time Estimate : 16-18 Months</p>	\$6,000,000
			TOTAL COST	\$7,570,000

11.6 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

11.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
163711897	314667	4ALTVSTA	DVP	242741	05OTTER	AEP	1	DVP_P1-2: LN 1016-A	single	245.0	118.91	121.14	DC	5.45

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
246843	05SMG1	1.4386	80/20	1.4386
246844	05SMG2	3.9106	80/20	3.9106
246845	05SMG3	2.4517	80/20	2.4517
246846	05SMG4	3.8498	80/20	3.8498
246847	05SMG5	1.4994	80/20	1.4994
247284	05LEESVG	2.1373	80/20	2.1373
315156	1HALLBR1	3.3626	80/20	3.3626
316123	AC1-075 C	2.4578	80/20	2.4578
925661	AC1-042 C	6.7632	80/20	6.7632
926023	AC1-080 C	0.8214	80/20	0.8214
926051	AC1-083 C O1	3.5902	80/20	3.5902
926521	AC1-123 C O1	0.4996	80/20	0.4996
926645	AC1-145 C	1.2703	80/20	1.2703
933941	AD1-017 C	0.7180	80/20	0.7180
938451	AE1-064 C	7.0732	80/20	7.0732
939011	AE1-130 C	3.2262	80/20	3.2262
939941	AE1-230 C	3.0511	80/20	3.0511
940081	AE1-250 C	6.2325	80/20	6.2325
941801	AE2-185 C	15.2554	80/20	15.2554
941821	AE2-187 C	15.2554	80/20	15.2554
942671	AE2-283 C	16.7809	80/20	16.7809
942751	AE2-291 C	24.8931	80/20	24.8931
942761	AE2-292 C O1	30.9943	80/20	30.9943
945081	AF1-173	5.9115	80/20	5.9115
961121	AF2-403	3.3901	80/20	3.3901
963601	AG1-209 C	1.1865	80/20	1.1865
964141	AG1-275 C	5.0851	80/20	5.0851
964151	AG1-276 C	5.0851	80/20	5.0851
964471	AG1-310 C	5.4505	80/20	5.4505
966691	AG1-539 C	13.0160	80/20	13.0160
966761	AG1-547 C	13.7892	80/20	13.7892
CPLE	CPLE	0.3849	Confirmed LTF	0.3849
NY	NY	0.0514	Confirmed LTF	0.0514
PRAIRIE	PRAIRIE	0.0878	Confirmed LTF	0.0878
TVA	TVA	0.0420	Confirmed LTF	0.0420
SIGE	SIGE	0.0027	Confirmed LTF	0.0027
CBM-S2	CBM-S2	3.6853	Confirmed LTF	3.6853
CBM-S1	CBM-S1	0.0042	Confirmed LTF	0.0042
GIBSON	GIBSON	0.0382	Confirmed LTF	0.0382
BLUEG	BLUEG	0.1371	Confirmed LTF	0.1371
TRIMBLE	TRIMBLE	0.0445	Confirmed LTF	0.0445

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LAGN	LAGN	0.0612	Confirmed LTF	0.0612

11.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
169195683	314696	3SEEDGE HILL	DVP	314697	6SEEDGE HILL	DVP	1	DVP_P1-3: 6SEEDGE HILL-TX#2	single	226.73	142.87	145.9	DC	6.87

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
246843	05SMG1	0.5805	80/20	0.5805
246844	05SMG2	1.5779	80/20	1.5779
246845	05SMG3	0.9892	80/20	0.9892
246846	05SMG4	1.5534	80/20	1.5534
246847	05SMG5	0.6050	80/20	0.6050
247284	05LEESVG	0.7296	80/20	0.7296
313527	AB2-043 C	0.6460	80/20	0.6460
314429	3JTRSVLE	0.2980	80/20	0.2980
314704	3LAWRENC	0.1696	80/20	0.1696
315156	1HALLBR1	1.3548	80/20	1.3548
315158	1KERR 1	0.3699	80/20	0.3699
315159	1KERR 2	1.0357	80/20	1.0357
315160	1KERR 3	1.0357	80/20	1.0357
315161	1KERR 4	1.0357	80/20	1.0357
315162	1KERR 5	1.0357	80/20	1.0357
315163	1KERR 6	1.0357	80/20	1.0357
315164	1KERR 7	1.0357	80/20	1.0357
315266	1PLYWOOD A	3.6058	80/20	3.6058
316118	AC1-105 C	17.1934	80/20	17.1934
316123	AC1-075 C	2.2966	80/20	2.2966
316129	AC1-054 C	4.6827	80/20	4.6827
316131	AB2-060 C	1.8286	80/20	1.8286
924301	AB2-077 C O1 (Suspended)	2.6800	80/20	2.6800
924311	AB2-078 C O1 (Suspended)	2.6800	80/20	2.6800
924321	AB2-079 C O1 (Suspended)	2.6800	80/20	2.6800
925611	AC1-036 C	0.2218	80/20	0.2218
925661	AC1-042 C	2.1728	80/20	2.1728
926023	AC1-080 C	0.7675	80/20	0.7675
926645	AC1-145 C	0.4081	80/20	0.4081
927261	AC1-222 C	12.1290	80/20	12.1290
934311	AD1-055 C	8.4214	80/20	8.4214
935221	AD1-157 C	0.1446	80/20	0.1446
936265	AD2-033 C	13.5587	80/20	13.5587
936361	AD2-046 C O1	9.1138	80/20	9.1138
936485	AD2-063 C	17.6553	80/20	17.6553
938371	AE1-056 C	3.9510	80/20	3.9510
939181	AE1-148 C	9.0914	80/20	9.0914

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
939941	AE1-230 C	0.9802	80/20	0.9802
940661	AE2-053 O1	3.3672	80/20	3.3672
941801	AE2-185 C	4.9010	80/20	4.9010
941821	AE2-187 C	4.9010	80/20	4.9010
942451	AE2-258	3.0548	80/20	3.0548
942461	AE2-259 C O1	3.4716	80/20	3.4716
942671	AE2-283 C	5.3911	80/20	5.3911
942751	AE2-291 C	19.2878	80/20	19.2878
942761	AE2-292 C O1	24.0152	80/20	24.0152
943901	AF1-058 C	6.8587	80/20	6.8587
943911	AF1-059	14.0170	80/20	14.0170
945081	AF1-173	1.8992	80/20	1.8992
946301	AF1-294 C	3.0108	80/20	3.0108
958211	AF2-115 C	1.7711	80/20	1.7711
958801	AF2-171 C	10.7010	80/20	10.7010
959311	AF2-222 C	15.7000	80/20	15.7000
960061	AF2-297 C	27.4349	80/20	27.4349
961121	AF2-403	1.0891	80/20	1.0891
961791	AG1-021 C	1.4168	80/20	1.4168
961891	AG1-030 C	12.0555	80/20	12.0555
962041	AG1-048 C	8.8552	80/20	8.8552
962441	AG1-093 C O1	45.8491	80/20	45.8491
963171	AG1-166 C	1.4168	80/20	1.4168
963181	AG1-167 C	1.4168	80/20	1.4168
963191	AG1-168 C	1.4168	80/20	1.4168
963201	AG1-169 C	1.4168	80/20	1.4168
963211	AG1-170 C	1.4168	80/20	1.4168
963301	AG1-179 C	3.7689	80/20	3.7689
963311	AG1-180	1.8363	80/20	1.8363
963321	AG1-181 C O1	17.3096	80/20	17.3096
963361	AG1-185 O1	8.3749	80/20	8.3749
963601	AG1-209 C	0.3812	80/20	0.3812
963641	AG1-215 C	0.6612	80/20	0.6612
964111	AG1-272 C	2.5210	80/20	2.5210
964121	AG1-273 C	2.5210	80/20	2.5210
964131	AG1-274 C	2.5210	80/20	2.5210
964141	AG1-275 C	1.6337	80/20	1.6337
964151	AG1-276 C	1.6337	80/20	1.6337
964241	AG1-285 C O1	15.1590	80/20	15.1590
964251	AG1-286 C	0.6223	80/20	0.6223
964261	AG1-287 C	5.1440	80/20	5.1440
964471	AG1-310 C	6.8684	80/20	6.8684
964791	AG1-342 C	10.6934	80/20	10.6934
964821	AG1-345 C	0.5693	80/20	0.5693
965191	AG1-384 C	2.5210	80/20	2.5210
965281	AG1-393 C	1.4168	80/20	1.4168
965451	AG1-413 C O1	5.8922	80/20	5.8922
965591	AG1-427 C	14.2996	80/20	14.2996
965601	AG1-428 C O1	3.1464	80/20	3.1464
965641	AG1-432 C O1	6.9432	80/20	6.9432
965721	AG1-440 C	6.1934	80/20	6.1934
965731	AG1-441 C	6.1934	80/20	6.1934

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
965771	AG1-445	3.5784	80/20	3.5784
965781	AG1-446	3.5784	80/20	3.5784
965831	AG1-451	1.1572	80/20	1.1572
966691	AG1-539 C	10.0851	80/20	10.0851
966751	AG1-546 C	9.6117	80/20	9.6117
966761	AG1-547 C	4.4300	80/20	4.4300
966861	AG1-557 C O1 (Withdrawn : 12/14/2020)	0.6943	80/20	0.6943
WEC	WEC	0.0164	Confirmed LTF	0.0164
LGEE	LGEE	0.0509	Confirmed LTF	0.0509
CALDERWOOD	CALDERWOOD	0.1387	Confirmed LTF	0.1387
NY	NY	0.0547	Confirmed LTF	0.0547
PRAIRIE	PRAIRIE	0.0827	Confirmed LTF	0.0827
SIGE	SIGE	0.0181	Confirmed LTF	0.0181
CHEOAH	CHEOAH	0.1496	Confirmed LTF	0.1496
COTTONWOOD	COTTONWOOD	0.4284	Confirmed LTF	0.4284
HAMLET	HAMLET	0.6809	Confirmed LTF	0.6809
CATAWBA	CATAWBA	0.3041	Confirmed LTF	0.3041
CBM-W1	CBM-W1	0.7290	Confirmed LTF	0.7290

11.6.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
169195699	314696	3SEEDGE HILL	DVP	314697	6SEEDGE HILL	DVP	2	DVP_P1-3: 6SEEDGE HILL-TX#1	single	256.06	126.12	128.8	DC	6.85

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
246843	05SMG1	0.5788	80/20	0.5788
246844	05SMG2	1.5733	80/20	1.5733
246845	05SMG3	0.9864	80/20	0.9864
246846	05SMG4	1.5489	80/20	1.5489
246847	05SMG5	0.6032	80/20	0.6032
247284	05LEESVG	0.7274	80/20	0.7274
313527	AB2-043 C	0.6441	80/20	0.6441
314429	3JTRSVLE	0.2972	80/20	0.2972
314704	3LAWRENC	0.1691	80/20	0.1691
315156	1HALLBR1	1.3508	80/20	1.3508
315158	1KERR 1	0.3688	80/20	0.3688
315159	1KERR 2	1.0326	80/20	1.0326
315160	1KERR 3	1.0326	80/20	1.0326
315161	1KERR 4	1.0326	80/20	1.0326
315162	1KERR 5	1.0326	80/20	1.0326
315163	1KERR 6	1.0326	80/20	1.0326
315164	1KERR 7	1.0326	80/20	1.0326
315266	1PLYWOOD A	3.5951	80/20	3.5951
316118	AC1-105 C	17.1420	80/20	17.1420
316123	AC1-075 C	2.2897	80/20	2.2897
316129	AC1-054 C	4.6689	80/20	4.6689
316131	AB2-060 C	1.8231	80/20	1.8231
924301	AB2-077 C O1 (Suspended)	2.6719	80/20	2.6719
924311	AB2-078 C O1 (Suspended)	2.6719	80/20	2.6719
924321	AB2-079 C O1 (Suspended)	2.6719	80/20	2.6719
925611	AC1-036 C	0.2212	80/20	0.2212
925661	AC1-042 C	2.1663	80/20	2.1663
926023	AC1-080 C	0.7652	80/20	0.7652
926645	AC1-145 C	0.4069	80/20	0.4069
927261	AC1-222 C	12.0926	80/20	12.0926
934311	AD1-055 C	8.3962	80/20	8.3962
935221	AD1-157 C	0.1442	80/20	0.1442
936265	AD2-033 C	13.5182	80/20	13.5182
936361	AD2-046 C O1	9.0864	80/20	9.0864
936485	AD2-063 C	17.6022	80/20	17.6022
938371	AE1-056 C	3.9394	80/20	3.9394
939181	AE1-148 C	9.0639	80/20	9.0639

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
939941	AE1-230 C	0.9773	80/20	0.9773
940661	AE2-053 O1	3.3570	80/20	3.3570
941801	AE2-185 C	4.8863	80/20	4.8863
941821	AE2-187 C	4.8863	80/20	4.8863
942451	AE2-258	3.0456	80/20	3.0456
942461	AE2-259 C O1	3.4614	80/20	3.4614
942671	AE2-283 C	5.3749	80/20	5.3749
942751	AE2-291 C	19.2303	80/20	19.2303
942761	AE2-292 C O1	23.9436	80/20	23.9436
943901	AF1-058 C	6.8382	80/20	6.8382
943911	AF1-059	13.9753	80/20	13.9753
945081	AF1-173	1.8934	80/20	1.8934
946301	AF1-294 C	3.0019	80/20	3.0019
958211	AF2-115 C	1.7658	80/20	1.7658
958801	AF2-171 C	10.6686	80/20	10.6686
959311	AF2-222 C	15.6530	80/20	15.6530
960061	AF2-297 C	27.3528	80/20	27.3528
961121	AF2-403	1.0858	80/20	1.0858
961791	AG1-021 C	1.4126	80/20	1.4126
961891	AG1-030 C	12.0195	80/20	12.0195
962041	AG1-048 C	8.8290	80/20	8.8290
962441	AG1-093 C O1	45.7120	80/20	45.7120
963171	AG1-166 C	1.4126	80/20	1.4126
963181	AG1-167 C	1.4126	80/20	1.4126
963191	AG1-168 C	1.4126	80/20	1.4126
963201	AG1-169 C	1.4126	80/20	1.4126
963211	AG1-170 C	1.4126	80/20	1.4126
963301	AG1-179 C	3.7578	80/20	3.7578
963311	AG1-180	1.8309	80/20	1.8309
963321	AG1-181 C O1	17.2581	80/20	17.2581
963361	AG1-185 O1	8.3499	80/20	8.3499
963601	AG1-209 C	0.3800	80/20	0.3800
963641	AG1-215 C	0.6592	80/20	0.6592
964111	AG1-272 C	2.5135	80/20	2.5135
964121	AG1-273 C	2.5135	80/20	2.5135
964131	AG1-274 C	2.5135	80/20	2.5135
964141	AG1-275 C	1.6288	80/20	1.6288
964151	AG1-276 C	1.6288	80/20	1.6288
964241	AG1-285 C O1	15.1132	80/20	15.1132
964251	AG1-286 C	0.6204	80/20	0.6204
964261	AG1-287 C	5.1287	80/20	5.1287
964471	AG1-310 C	6.8479	80/20	6.8479
964791	AG1-342 C	10.6614	80/20	10.6614
964821	AG1-345 C	0.5676	80/20	0.5676
965191	AG1-384 C	2.5135	80/20	2.5135
965281	AG1-393 C	1.4126	80/20	1.4126
965451	AG1-413 C O1	5.8747	80/20	5.8747
965591	AG1-427 C	14.2570	80/20	14.2570
965601	AG1-428 C O1	3.1371	80/20	3.1371
965641	AG1-432 C O1	6.9228	80/20	6.9228
965721	AG1-440 C	6.1749	80/20	6.1749
965731	AG1-441 C	6.1749	80/20	6.1749

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
965771	AG1-445	3.5677	80/20	3.5677
965781	AG1-446	3.5677	80/20	3.5677
965831	AG1-451	1.1538	80/20	1.1538
966691	AG1-539 C	10.0550	80/20	10.0550
966751	AG1-546 C	9.5834	80/20	9.5834
966761	AG1-547 C	4.4167	80/20	4.4167
966861	AG1-557 C O1 (Withdrawn : 12/14/2020)	0.6923	80/20	0.6923
WEC	WEC	0.0161	Confirmed LTF	0.0161
LGEE	LGEE	0.0503	Confirmed LTF	0.0503
CALDERWOOD	CALDERWOOD	0.1387	Confirmed LTF	0.1387
NY	NY	0.0553	Confirmed LTF	0.0553
PRAIRIE	PRAIRIE	0.0827	Confirmed LTF	0.0827
SIGE	SIGE	0.0180	Confirmed LTF	0.0180
CHEOAH	CHEOAH	0.1496	Confirmed LTF	0.1496
COTTONWOOD	COTTONWOOD	0.4284	Confirmed LTF	0.4284
HAMLET	HAMLET	0.6791	Confirmed LTF	0.6791
CATAWBA	CATAWBA	0.3035	Confirmed LTF	0.3035
CBM-W1	CBM-W1	0.7150	Confirmed LTF	0.7150

11.7 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AB2-043	Chase City 115kV	Under Construction
AB2-060	Chase City-Lunenburg 115kV	In Service
AB2-077	Buggs Island-Chase City 115kV	Suspended
AB2-078	Buggs Island-Chase City 115kV	Suspended
AB2-079	Buggs Island-Chase City 115kV	Suspended
AC1-036	Twittys Creek 34.5kV	Partially in Service - Under Construction
AC1-042	Altavista-Mt. Airy 69kV	Engineering and Procurement
AC1-054	Kerr Dam-Eatons Ferry 115 kV	Engineering and Procurement
AC1-075	Perth-Hickory Grove 115kV	Engineering and Procurement
AC1-080	Perth-Hickory Grove 115kV	Engineering and Procurement
AC1-083	Smith Mountain-Bearskin 138kV	Active
AC1-105	Halifax-Mt. Laurel 115kV	Engineering and Procurement
AC1-123	Smith Mountain-Candler's Mountain 138kV	Under Construction
AC1-145	Gretna DP 69 kV	Engineering and Procurement
AC1-222	Crystal Hill-Halifax 115kV	Engineering and Procurement
AD1-017	Smith Mountain-Bearskin 138 kV	Active
AD1-055	Crystal Hill-Halifax 115 kV	Engineering and Procurement
AD1-157	South Creek 34.5 kV	Engineering and Procurement
AD2-033	Chase City-Lunenburg 115 kV	Active
AD2-046	Boydton DP-Kerr Dam 115 kV	Active
AD2-063	Central-Chase City 115kV	Active
AE1-056	Red House-South Creek 115 kV	Active
AE1-064	Rockcastle 138 kV	Active
AE1-130	Meads Store 138 kV	Active
AE1-148	Kerr Dam-Ridge Rd 115 kV	Active
AE1-230	Shockoe 69 kV	Active
AE1-250	Smith Mountain-E. Danville 138 kV	Active
AE2-053	Kerr Dam-Ridge Road 115 kV	Active
AE2-185	Gladys DP-Stonemill Switching Station 69 kV	Active
AE2-187	Shockoe DP-Chatham 69 kV	Active
AE2-258	Chase City 115 kV	Active
AE2-259	Curdsville-Willis Mtn 115 kV	Active
AE2-283	Gladys-Stone Mill 69 kV	Active
AE2-291	Grit DP-Perth 115 kV	Active
AE2-292	Grit DP-Perth 115 kV	Active
AF1-058	Welco 34.5 kV	Engineering and Procurement
AF1-059	Brodnax-South Hill 115 kV	Active
AF1-173	Gretna DP-Shockoe DP 69 kV	Active
AF1-294	Jetersville-Ponton 115 kV	Active

Queue Number	Project Name	Status
AF2-115	Jetersville-Ponton 115 kV	Active
AF2-171	Madisonville 115 kV	Active
AF2-222	Madisonville DP-Twitty's Creek 115 kV	Active
AF2-297	Sedge Hill 115 kV	Active
AF2-403	Shockoe DP-Chatham 69 kV	Active
AG1-021	Jetersville-Ponton 115 kV	Active
AG1-030	Victoria DP-Martin DP 115 kV	Active
AG1-048	Jetersville-Ponton 115 kV	Active
AG1-093	Halifax-Chase City 115 kV	Active
AG1-166	Lone Pine 115 kV	Active
AG1-167	Lone Pine 115 kV	Active
AG1-168	Lone Pine 115 kV	Active
AG1-169	Lone Pine 115 kV	Active
AG1-170	Lone Pine 115 kV	Active
AG1-179	Brunswick 69 kV	Active
AG1-180	Brunswick 69 kV	Active
AG1-181	Pamplin-Chase City 115 kV	Active
AG1-185	Pamplin-Chase City 115 kV	Active
AG1-209	Gretna 12.5 kV	Active
AG1-215	Fort Pickett 13.2 kV	Active
AG1-272	Twitty's Creek 115 kV	Active
AG1-273	Twitty's Creek 115 kV	Active
AG1-274	Twitty's Creek 115 kV	Active
AG1-275	Gladys DP-Stone Mill 69 kV	Active
AG1-276	Gladys DP-Stone Mill 69 kV	Active
AG1-285	Chase City-Central 115 kV	Active
AG1-286	Johnson Mountain 138 kV	Active
AG1-287	South Boston 12.5 kV	Active
AG1-310	Crystal Hill-Perth 115 kV	Active
AG1-342	Dryburg 115 kV	Active
AG1-345	Crewe 12.5 kV	Active
AG1-384	Twitty's Creek 115 kV	Active
AG1-393	Fort Pickett DP 34.5 kV	Active
AG1-413	South Hill-Bordnax 115 kV	Active
AG1-427	Chase City-Drakes Branch 115 kV	Active
AG1-428	Danieltown 69 kV	Active
AG1-432	Curdsville DP-Willis Mt. 115 kV	Active
AG1-440	Palmer Springs 115 kV	Active
AG1-441	Palmer Springs 115 kV	Active
AG1-445	Palmer Spring 115 kV	Active
AG1-446	Palmer Springs 115 kV	Active
AG1-451	Curdsville DP-Willis Mt. 115 kV	Active
AG1-539	Grit DP-Perth 115 kV	Active
AG1-546	Ebony-Elams Road 115 kV	Active
AG1-547	Mount Airy-Chatham 69 kV	Active
AG1-557	Curdsville DP 115 kV	Withdrawn

11.8 Contingency Descriptions

Contingency Name	Contingency Definition
DVP_P1-2: LN 31-A	CONTINGENCY 'DVP_P1-2: LN 31-A' OPEN BRANCH FROM BUS 314666 TO BUS 314712 CKT 1 /* 3ALTVSTA 115.00 - 3OTTER R 115.00 OPEN BRANCH FROM BUS 314694 TO BUS 314712 CKT 1 /* 3GRIT 115.00 - 3OTTER R 115.00 OPEN BRANCH FROM BUS 314694 TO BUS 942750 CKT 1 /* 3GRIT 115.00 - AE2-291 TAP 115.00 OPEN BUS 314694 /* ISLAND: 3GRIT 115.00 OPEN BUS 314712 /* ISLAND: 3OTTER R 115.00 END
DVP_P1-2: LN 556-D	CONTINGENCY 'DVP_P1-2: LN 556-D' OPEN BRANCH FROM BUS 966360 TO BUS 314936 CKT 1 /* AG1-055 TAP 500.00 - 8RAWLINGS 500.00 END
DVP_P1-2: LN 296-A	CONTINGENCY 'DVP_P1-2: LN 296-A' OPEN BRANCH FROM BUS 304070 TO BUS 927250 CKT 1 /* 6PERSON230 T230.00 - AC1-221 TAP 230.00 END
AEP_P1-2_#375_5201	CONTINGENCY 'AEP_P1-2_#375_5201' OPEN BRANCH FROM BUS 242687 TO BUS 242734 CKT 1 / 242687 05JOHNMT 138 242734 05NEWLDN 138 1 OPEN BRANCH FROM BUS 242687 TO BUS 242741 CKT 1 / 242687 05JOHNMT 138 242741 05OTTER 138 1 OPEN BRANCH FROM BUS 242741 TO BUS 314667 CKT 1 / 242741 05OTTER 138 314667 4ALTVSTA 138 1 END
DVP_P1-3: 6SEDGE HILL-TX#1	CONTINGENCY 'DVP_P1-3: 6SEDGE HILL-TX#1' OPEN BRANCH FROM BUS 314696 TO BUS 314697 CKT 1 /* 3SEDGE HILL 115.00 - 6SEDGE HILL 230.00 END
DVP_P1-3: 6SEDGE HILL-TX#2	CONTINGENCY 'DVP_P1-3: 6SEDGE HILL-TX#2' OPEN BRANCH FROM BUS 314696 TO BUS 314697 CKT 2 /* 3SEDGE HILL 115.00 - 6SEDGE HILL 230.00 END
Base Case	

Contingency Name	Contingency Definition
DVP_P1-2: LN 1016-D	CONTINGENCY 'DVP_P1-2: LN 1016-D' OPEN BRANCH FROM BUS 927260 TO BUS 314696 CKT 1 /* AC1-222 TAP 115.00 - 3SEdge HILL 115.00 END
DVP_P1-3: 4ALTVSTA-TX#4	CONTINGENCY 'DVP_P1-3: 4ALTVSTA-TX#4' OPEN BRANCH FROM BUS 314666 TO BUS 314667 CKT 2 /* 3ALTVSTA 115.00 - 4ALTVSTA 138.00 END
DVP_P1-2: LN 1016-A	CONTINGENCY 'DVP_P1-2: LN 1016-A' OPEN BRANCH FROM BUS 314688 TO BUS 927260 CKT 1 /* 3CRSTL HILL 115.00 - AC1-222 TAP 115.00 OPEN BUS 314688 /* ISLAND: 3CRSTL HILL 115.00 END

12 Short Circuit Analysis

The following Breakers are overdutied:

None.

12.1 System Reinforcements - Short Circuit

None.

13 Affected Systems

13.1 TVA

TVA Impacts to be determined during later study phases (as applicable).

13.2 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

14 Attachment 1: One Line Diagram