



Generation Interconnection

Feasibility Study Report

for

Queue Project AG1-532

FIELDS 34.5 KV

8.1 MW Capacity / 13.5 MW Energy

January 2021

Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	5
4	Point of Interconnection.....	6
5	Cost Summary.....	6
6	Transmission Owner Scope of Work.....	7
7	Transmission Owner Analysis.....	8
7.1	Power Flow Analysis.....	8
8	Interconnection Customer Requirements.....	8
8.1	System Protection.....	8
8.2	Compliance Issues and Interconnection Customer Requirements.....	8
8.3	Power Factor Requirements.....	9
9	Revenue Metering and SCADA Requirements.....	9
9.1	PJM Requirements.....	9
9.2	Meteorological Data Reporting Requirements.....	9
9.3	Interconnected Transmission Owner Requirements.....	10
10	Summer Peak - Load Flow Analysis.....	11
10.1	Generation Deliverability.....	12
10.2	Multiple Facility Contingency.....	12
10.3	Contribution to Previously Identified Overloads.....	12
10.4	Potential Congestion due to Local Energy Deliverability.....	12
10.5	System Reinforcements - Summer Peak Load Flow - Primary POI.....	14
10.6	Flow Gate Details.....	15
10.6.1	Index 1.....	16
10.6.2	Index 2.....	18
10.7	Queue Dependencies.....	21
10.8	Contingency Descriptions.....	23
11	Short Circuit Analysis.....	24
12	Affected Systems.....	25
12.1	TVA.....	25
12.2	Duke Energy Progress.....	25

13 Attachment 1: One Line Diagram26

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Dominion.

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in Greensville County, Virginia. The installed facilities will have a total capability of 13.5 MW with 8.1 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is December 12, 2022. This study does not imply a TO commitment to this in-service date.

Queue Number	AG1-532
Project Name	FIELDS 34.5 KV
State	Virginia
County	Greensville
Transmission Owner	Dominion
MFO	13.5
MWE	13.5
MWC	8.1
Fuel	Solar
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

AG1-532 will interconnect with the Dominion transmission system at the Purdy SW 115 kV substation.

5 Cost Summary

The AG1-532 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$ To be provided in the two-party IA with ITO
Total System Network Upgrade Costs	\$6,000,000 ¹
Total Costs	\$6,000,000

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 2016-36, 2016-25 I.R.B. (6/20/2016). If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

¹ This project currently causes and/or contributes to overloads of the Transmission System (see Summer Peak Load Flow Analysis section below) and therefore has potential to have cost allocation for the system reinforcements listed in the report. This will be re-evaluated in the System Impact phase. The results may vary with queue customers withdrawing from the queue and other generators deactivating over time. If a customer is the first to cause the need for a project (causes loading to exceed 100% of rating), then the customer is responsible. If a customer contributes to a facility that is already overloaded by a prior queue, then they may receive cost allocation.

6 Transmission Owner Scope of Work

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

7 Transmission Owner Analysis

Dominion assessed the impact of the proposed project for compliance with NERC Reliability Criteria on the Dominion Transmission System. The system was assessed using the summer 2024 AG1 case provided to Dominion by PJM.

When performing a generation analysis, Dominion's main analysis includes load flow study results following a single contingency event for both normal and stressed system conditions. Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion's Planning Criteria and interconnection requirements can be found in the Company's Facility Connection Requirements which are publicly available at: <http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically, in Planning Studies, NERC Planning Event 3 and 6 Contingency Conditions (Loss of generator, transmission circuit, transformer, shunt device, or Single Pole of a DC line followed by the loss of a generator, transmission circuit, transformer, shunt device or single pole of a DC line) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

7.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2024 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system and no further deficiencies were identified.

8 Interconnection Customer Requirements

8.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion's "Dominion Energy Electric Transmission Generator Interconnection Requirements" documented in Dominion's Facility Interconnection Requirements "Exhibit C" located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

8.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC's GSU transformer(s).
2. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection section noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
4. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

8.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

9 Revenue Metering and SCADA Requirements

9.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

9.2 Meteorological Data Reporting Requirements

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Back Panel temperature (Fahrenheit)
- Irradiance (Watts/meter²)
- Ambient air temperature (Fahrenheit) - (Accepted, not required)
- Wind speed (meters/second) - (Accepted, not required)

- Wind direction (decimal degrees from true north) - (Accepted, not required)

9.3 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

10 Summer Peak - Load Flow Analysis

The Queue Project AG1-532 was evaluated as a 13.5 MW (Capacity 8.1 MW) injection at the Purdy SW 115 kV substation in the Dominion area. Project AG1-532 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-532 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

10.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

10.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

10.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/D C	MW IMPACT
168575466	313725	6DRY BREAD	230.0	DVP	314583	6LAKEVEW	230.0	DVP	1	3144356SAPONY230940480AE2-033TAP2301	single	375.059997559	113.92	114.98	DC	4.0
168575467	313725	6DRY BREAD	230.0	DVP	314583	6LAKEVEW	230.0	DVP	1	DVP_P1-2: LN238-A	single	375.059997559	113.92	114.98	DC	4.0
169067429	314562	3CLUBHSE	115.0	DVP	314563	6CLUBHSE	230.0	DVP	1	DVP_P1-2: LN2201	single	182.641998291	236.2	238.6	DC	4.38
169067430	314562	3CLUBHSE	115.0	DVP	314563	6CLUBHSE	230.0	DVP	1	DVP_P1-2: LN130	single	182.641998291	191.02	194.54	DC	6.44
169067431	314562	3CLUBHSE	115.0	DVP	314563	6CLUBHSE	230.0	DVP	1	Base Case	single	176.81401062	174.88	177.61	DC	4.82

10.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
1685754 64	31372 5	6DRY BREAD	230. 0	DVP	31458 3	6LAKEVE W	230. 0	DVP	1	314435 6SAPO NY 230 940480 AE2- 033 TAP 230 1	operatio n	375.0599975 59	148.54	150.31	DC	6.66
1685754 65	31372 5	6DRY BREAD	230. 0	DVP	31458 3	6LAKEVE W	230. 0	DVP	1	DVP_P1 -2: LN 238-A	operatio n	375.0599975 59	148.54	150.31	DC	6.66
1690674 27	31456 2	3CLUBH SE	115. 0	DVP	31456 3	6CLUBHS E	230. 0	DVP	1	DVP_P1 -2: LN 2201	operatio n	182.6419982 91	293.24	297.24	DC	7.3
1690674 28	31456 2	3CLUBH SE	115. 0	DVP	31456 3	6CLUBHS E	230. 0	DVP	1	Base Case	operatio n	176.8140106 2	234.29	238.83	DC	8.03
1685755 42	31456 3	6CLUBH SE	230. 0	DVP	31372 5	6DRY BREAD	230. 0	DVP	1	314435 6SAPO NY 230 940480 AE2- 033 TAP 230 1	operatio n	375.0599975 59	132.24	134.02	DC	6.67

10.5 System Reinforcements - Summer Peak Load Flow - Primary POI

ID	Idx	Facility	Upgrade Description	Cost
168575467,168 575466	1	6DRY BREAD 230.0 kV - 6LAKEVEW 230.0 kV Ckt 1	<u>DVP</u> b3121 (11) : PJM Baseline Upgrade b3121. Rebuild Clubhouse-Lakeview 230 kV Line #254 with single-circuit wood pole equivalent structures at the current 230 kV standard with a minimum rating of 1047 MVA. The baseline project has a projected in-service date of 12/31/2024. Project Type : FAC Cost : \$0	\$0
169067431,169 067430,169067 429	2	3CLUBHSE 115.0 kV - 6CLUBHSE 230.0 kV Ckt 1	<u>DVP</u> n6114 (200) : Add additional 230/115 kV transformer at Clubhouse substation. Project Type : CON Cost : \$6,000,000 Time Estimate : 16-18 Months	\$6,000,000
			TOTAL COST	\$6,000,000¹

10.6 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

10.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168575467	313725	6DRY BREAD	DVP	314583	6LAKEVEW	DVP	1	DVP_P1-2: LN 238-A	single	375.06	113.92	114.98	DC	4.0

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
313506	AB1-173 C OP	12.0489	80/20	12.0489
313527	AB2-043 C	0.2911	80/20	0.2911
314429	3JTRSVLE	0.1505	80/20	0.1505
314572	3EMPORIA	1.0948	80/20	1.0948
314704	3LAWRENC	0.6548	80/20	0.6548
315158	1KERR 1	0.1517	80/20	0.1517
315159	1KERR 2	0.4247	80/20	0.4247
315160	1KERR 3	0.4247	80/20	0.4247
315161	1KERR 4	0.4247	80/20	0.4247
315162	1KERR 5	0.4247	80/20	0.4247
315163	1KERR 6	0.4247	80/20	0.4247
315164	1KERR 7	0.4247	80/20	0.4247
316087	AB2-174 C	2.3145	80/20	2.3145
316096	AB2-100 C1	4.0768	80/20	4.0768
316098	AB2-100 C2	4.0768	80/20	4.0768
316129	AC1-054 C	2.5570	80/20	2.5570
316131	AB2-060 C	0.8247	80/20	0.8247
923991	AB2-040 C O1	13.1226	80/20	13.1226
924301	AB2-077 C O1 (Suspended)	1.1296	80/20	1.1296
924311	AB2-078 C O1 (Suspended)	1.1296	80/20	1.1296
924321	AB2-079 C O1 (Suspended)	1.1296	80/20	1.1296
925611	AC1-036 C	0.1047	80/20	0.1047
935221	AD1-157 C	0.0759	80/20	0.0759
936265	AD2-033 C	6.3203	80/20	6.3203
936361	AD2-046 C O1	3.8168	80/20	3.8168
936485	AD2-063 C	8.0766	80/20	8.0766
938371	AE1-056 C	2.0731	80/20	2.0731
939181	AE1-148 C	3.8205	80/20	3.8205
940481	AE2-033 C	67.1808	80/20	67.1808
940661	AE2-053 O1	1.4150	80/20	1.4150
942451	AE2-258	1.3766	80/20	1.3766
942471	AE2-260 C O1	62.4253	80/20	62.4253
943911	AF1-059	27.2641	80/20	27.2641
946011	AF1-266	56.2356	80/20	56.2356
946281	AF1-292 C	4.3932	80/20	4.3932
946301	AF1-294 C	1.5201	80/20	1.5201
958211	AF2-115 C	0.8942	80/20	0.8942
958801	AF2-171 C	5.4000	80/20	5.4000
959311	AF2-222 C	7.4660	80/20	7.4660

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
960081	AF2-299 C	7.4043	80/20	7.4043
961791	AG1-021 C	0.7153	80/20	0.7153
961891	AG1-030 C	5.9139	80/20	5.9139
962041	AG1-048 C	4.4708	80/20	4.4708
963171	AG1-166 C	0.7153	80/20	0.7153
963181	AG1-167 C	0.7153	80/20	0.7153
963191	AG1-168 C	0.7153	80/20	0.7153
963201	AG1-169 C	0.7153	80/20	0.7153
963211	AG1-170 C	0.7153	80/20	0.7153
963301	AG1-179 C	11.5730	80/20	11.5730
963311	AG1-180	5.6386	80/20	5.6386
963321	AG1-181 C O1	8.1014	80/20	8.1014
963361	AG1-185 O1	3.9196	80/20	3.9196
963641	AG1-215 C	0.3338	80/20	0.3338
964111	AG1-272 C	1.1898	80/20	1.1898
964121	AG1-273 C	1.1898	80/20	1.1898
964131	AG1-274 C	1.1898	80/20	1.1898
964241	AG1-285 C O1	6.9023	80/20	6.9023
964791	AG1-342 C	1.3915	80/20	1.3915
964821	AG1-345 C	0.2871	80/20	0.2871
965191	AG1-384 C	1.1898	80/20	1.1898
965281	AG1-393 C	0.7153	80/20	0.7153
965451	AG1-413 C O1	11.4608	80/20	11.4608
965591	AG1-427 C	6.5163	80/20	6.5163
965601	AG1-428 C O1	9.6613	80/20	9.6613
965721	AG1-440 C	2.7747	80/20	2.7747
965731	AG1-441 C	2.7747	80/20	2.7747
965771	AG1-445	1.6032	80/20	1.6032
965781	AG1-446	1.6032	80/20	1.6032
966621	AG1-532 C	3.9983	80/20	3.9983
966751	AG1-546 C	5.5243	80/20	5.5243
CALDERWOOD	CALDERWOOD	0.0626	Confirmed LTF	0.0626
NY	NY	0.0160	Confirmed LTF	0.0160
PRAIRIE	PRAIRIE	0.1963	Confirmed LTF	0.1963
CHEOAH	CHEOAH	0.0646	Confirmed LTF	0.0646
COTTONWOOD	COTTONWOOD	0.2373	Confirmed LTF	0.2373
HAMLET	HAMLET	0.1923	Confirmed LTF	0.1923
GIBSON	GIBSON	0.0317	Confirmed LTF	0.0317
BLUEG	BLUEG	0.0920	Confirmed LTF	0.0920
TRIMBLE	TRIMBLE	0.0295	Confirmed LTF	0.0295
CATAWBA	CATAWBA	0.0753	Confirmed LTF	0.0753

10.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
169067429	314562	3CLUBHSE	DVP	314563	6CLUBHSE	DVP	1	DVP_P1-2: LN 2201	single	182.64	236.2	238.6	DC	4.38

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
313506	AB1-173 C OP	14.9250	80/20	14.9250
313527	AB2-043 C	0.3856	80/20	0.3856
313719	3CHESTNUT	0.5206	80/20	0.5206
314429	3JTRSVLE	0.1956	80/20	0.1956
314572	3EMPORIA	1.2299	80/20	1.2299
314582	3KELFORD	0.1483	80/20	0.1483
314589	3MURPHYS	0.0389	80/20	0.0389
314623	3WITAKRS	0.0846	80/20	0.0846
314704	3LAWRENC	0.7289	80/20	0.7289
315115	1S HAMPT1	0.4811	80/20	0.4811
315126	1ROARAP2	1.1971	80/20	1.1971
315128	1ROARAP4	1.1424	80/20	1.1424
315136	1ROSEMG1	0.9301	80/20	0.9301
315137	1ROSEMS1	0.5767	80/20	0.5767
315138	1ROSEMG2	0.4359	80/20	0.4359
315139	1GASTONA	1.4047	80/20	1.4047
315141	1GASTONB	1.4047	80/20	1.4047
315158	1KERR 1	0.2620	80/20	0.2620
315159	1KERR 2	0.7337	80/20	0.7337
315160	1KERR 3	0.7337	80/20	0.7337
315161	1KERR 4	0.7337	80/20	0.7337
315162	1KERR 5	0.7337	80/20	0.7337
315163	1KERR 6	0.7337	80/20	0.7337
315164	1KERR 7	0.7337	80/20	0.7337
315266	1PLYWOOD A	0.3917	80/20	0.3917
315606	3AA2-053SOLA	1.1660	80/20	1.1660
315607	3AA1-063SOLA	0.9971	80/20	0.9971
315608	3AA2-088SOLA	0.4761	80/20	0.4761
316020	AB2-059 C OP	0.5459	80/20	0.5459
316087	AB2-174 C	2.7447	80/20	2.7447
316096	AB2-100 C1	0.4277	80/20	0.4277
316098	AB2-100 C2	0.4277	80/20	0.4277
316103	AB2-015 C	2.5605	80/20	2.5605
316118	AC1-105 C	2.0148	80/20	2.0148
316129	AC1-054 C	5.7187	80/20	5.7187
316131	AB2-060 C	1.0922	80/20	1.0922
316140	AB2-099 C (Suspended)	0.2281	80/20	0.2281
920591	AA2-165 C	0.0699	80/20	0.0699
922922	AB1-081 C OP	0.4632	80/20	0.4632
923991	AB2-040 C O1	16.2549	80/20	16.2549
924301	AB2-077 C O1 (Suspended)	1.5130	80/20	1.5130

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
924311	AB2-078 C O1 (Suspended)	1.5130	80/20	1.5130
924321	AB2-079 C O1 (Suspended)	1.5130	80/20	1.5130
925591	AC1-034 C	2.2414	80/20	2.2414
925611	AC1-036 C	0.1376	80/20	0.1376
926070	AC1-086 C	10.0123	80/20	10.0123
926201	AC1-098 C	3.1031	80/20	3.1031
926211	AC1-099 C	1.0399	80/20	1.0399
927145	AC1-208 C	5.2586	80/20	5.2586
932631	AC2-084 C	4.4236	80/20	4.4236
934331	AD1-057 C O1	3.8417	80/20	3.8417
935221	AD1-157 C	0.0980	80/20	0.0980
936265	AD2-033 C	8.3234	80/20	8.3234
936361	AD2-046 C O1	6.2368	80/20	6.2368
936485	AD2-063 C	10.6713	80/20	10.6713
938371	AE1-056 C	2.6788	80/20	2.6788
939181	AE1-148 C	6.1781	80/20	6.1781
940571	AE2-044 C	1.4680	80/20	1.4680
940661	AE2-053 O1	2.2882	80/20	2.2882
941541	AE2-151 C (Withdrawn : 01/08/2021)	0.0630	80/20	0.0630
942451	AE2-258	1.8236	80/20	1.8236
943171	AE2-346 C	0.5473	80/20	0.5473
943911	AF1-059	31.0992	80/20	31.0992
944141	AF1-082	0.9437	80/20	0.9437
946281	AF1-292 C	4.8137	80/20	4.8137
946301	AF1-294 C	1.9760	80/20	1.9760
957521	AF2-046 C	7.4161	80/20	7.4161
958211	AF2-115 C	1.1624	80/20	1.1624
958801	AF2-171 C	7.0200	80/20	7.0200
959311	AF2-222 C	9.8000	80/20	9.8000
960081	AF2-299 C	8.1131	80/20	8.1131
961091	AF2-400 C	0.1383	80/20	0.1383
961681	AG1-008 C	7.4310	80/20	7.4310
961791	AG1-021 C	0.9299	80/20	0.9299
961891	AG1-030 C	7.7229	80/20	7.7229
961931	AG1-036 C	0.5625	80/20	0.5625
961941	AG1-037 C	0.1955	80/20	0.1955
962041	AG1-048 C	5.8118	80/20	5.8118
962331	AG1-082 C	0.7819	80/20	0.7819
962341	AG1-083 C	0.7819	80/20	0.7819
962351	AG1-084 C	0.6452	80/20	0.6452
962361	AG1-085 C	0.6452	80/20	0.6452
962441	AG1-093 C O1	5.3728	80/20	5.3728
962571	AG1-106 C	2.7843	80/20	2.7843
963171	AG1-166 C	0.9299	80/20	0.9299
963181	AG1-167 C	0.9299	80/20	0.9299
963191	AG1-168 C	0.9299	80/20	0.9299
963201	AG1-169 C	0.9299	80/20	0.9299
963211	AG1-170 C	0.9299	80/20	0.9299
963301	AG1-179 C	12.9655	80/20	12.9655
963311	AG1-180	6.3171	80/20	6.3171

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
963321	AG1-181 C O1	10.6630	80/20	10.6630
963361	AG1-185 O1	5.1590	80/20	5.1590
963641	AG1-215 C	0.4339	80/20	0.4339
964111	AG1-272 C	1.5637	80/20	1.5637
964121	AG1-273 C	1.5637	80/20	1.5637
964131	AG1-274 C	1.5637	80/20	1.5637
964241	AG1-285 C O1	9.1275	80/20	9.1275
964501	AG1-313 C O1	3.2212	80/20	3.2212
964791	AG1-342 C	1.9409	80/20	1.9409
964801	AG1-343 C	2.8707	80/20	2.8707
964821	AG1-345 C	0.3733	80/20	0.3733
965191	AG1-384 C	1.5637	80/20	1.5637
965281	AG1-393 C	0.9299	80/20	0.9299
965291	AG1-394 C	0.9982	80/20	0.9982
965451	AG1-413 C O1	13.0729	80/20	13.0729
965591	AG1-427 C	8.6159	80/20	8.6159
965601	AG1-428 C O1	10.8238	80/20	10.8238
965721	AG1-440 C	5.2753	80/20	5.2753
965731	AG1-441 C	5.2753	80/20	5.2753
965771	AG1-445	3.0480	80/20	3.0480
965781	AG1-446	3.0480	80/20	3.0480
966621	AG1-532 C	4.3810	80/20	4.3810
966751	AG1-546 C	12.7746	80/20	12.7746
966811	AG1-552 C	1.9007	80/20	1.9007
WEC	WEC	0.1181	Confirmed LTF	0.1181
LGEE	LGEE	0.2444	Confirmed LTF	0.2444
CPL	CPL	1.2353	Confirmed LTF	1.2353
CBM-W2	CBM-W2	4.9818	Confirmed LTF	4.9818
NY	NY	0.1526	Confirmed LTF	0.1526
TVA	TVA	0.9282	Confirmed LTF	0.9282
SIGE	SIGE	0.0771	Confirmed LTF	0.0771
CBM-S2	CBM-S2	13.8539	Confirmed LTF	13.8539
CBM-S1	CBM-S1	0.2329	Confirmed LTF	0.2329
MEC	MEC	0.6960	Confirmed LTF	0.6960
LAGN	LAGN	1.1515	Confirmed LTF	1.1515
CBM-W1	CBM-W1	4.9631	Confirmed LTF	4.9631

10.7 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AA1-063	Huntsville (Cabin Creek) 69kV	Withdrawn
AA2-053	Carolina-Jackson 115kV	In Service
AA2-088	Boykins-Handsome 115kV	In Service
AA2-165	Hornertown-Whitakers 115kV	In Service
AB1-081	Anaconda-Mayo Dunbar 115kV	In Service
AB1-173	Brink-Trego 115kV	Engineering and Procurement
AB2-015	Franklin 115kV	Engineering and Procurement
AB2-040	Brink 115kV	Engineering and Procurement
AB2-043	Chase City 115kV	Under Construction
AB2-059	Benson-Dunbar 115kV	Partially in Service - Under Construction
AB2-060	Chase City-Lunenburg 115kV	In Service
AB2-077	Buggs Island-Chase City 115kV	Suspended
AB2-078	Buggs Island-Chase City 115kV	Suspended
AB2-079	Buggs Island-Chase City 115kV	Suspended
AB2-099	Ahoskie 34.5kV	Suspended
AB2-100	Clubhouse-Lakeview 230kV	Under Construction
AB2-174	Emporia-Trego 115kV	In Service
AC1-034	Heartsease DP - Mayo Dunbar 115kV	Engineering and Procurement
AC1-036	Twittys Creek 34.5kV	Partially in Service - Under Construction
AC1-054	Kerr Dam-Eatons Ferry 115 kV	Engineering and Procurement
AC1-086	Thelma 230kV	Active
AC1-098	Dawson-South Justice 115kV	Engineering and Procurement
AC1-099	Dawson-South Justice 115kV	Engineering and Procurement
AC1-105	Halifax-Mt. Laurel 115kV	Engineering and Procurement
AC1-208	Cox-Whitakers 115kV	Engineering and Procurement
AC2-084	Dawson-South Justice 115kV	Active
AD1-057	Hornertown-Hathaway 230 kV	Active
AD1-157	South Creek 34.5 kV	Engineering and Procurement
AD2-033	Chase City-Lunenburg 115 kV	Active
AD2-046	Boydton DP-Kerr Dam 115 kV	Active
AD2-063	Central-Chase City 115kV	Active
AE1-056	Red House-South Creek 115 kV	Active
AE1-148	Kerr Dam-Ridge Rd 115 kV	Active
AE2-033	Clubhouse-Sappony 230 kV	Active
AE2-044	Anaconda-Dunbar 115 kV	Active
AE2-053	Kerr Dam-Ridge Road 115 kV	Active
AE2-151	Earleys 34.5kV	Withdrawn
AE2-258	Chase City 115 kV	Active
AE2-260	Clubhouse 230 kV	Active
AE2-346	Ahoskie 34.5 kV	Active
AF1-059	Brodnax-South Hill 115 kV	Active
AF1-082	Heartsease-Mayo Dunbar DP	Active
AF1-266	Clubhouse-Sapony 230 kV	Active

Queue Number	Project Name	Status
AF1-292	Fields 34.5kV	Active
AF1-294	Jetersville-Ponton 115 kV	Active
AF2-046	Tunis-Mapleton 115 kV	Active
AF2-115	Jetersville-Ponton 115 kV	Active
AF2-171	Madisonville 115 kV	Active
AF2-222	Madisonville DP-Twitty's Creek 115 kV	Active
AF2-299	Fields 34.5 kV	Active
AF2-400	Franklin 13.2 kV	Engineering and Procurement
AG1-008	Tunis-Mapleton 115 kV	Active
AG1-021	Jetersville-Ponton 115 kV	Active
AG1-030	Victoria DP-Martin DP 115 kV	Active
AG1-036	Tunis 34.5 kV	Active
AG1-037	Earlys 34.5 kV	Active
AG1-048	Jetersville-Ponton 115 kV	Active
AG1-082	Ahoskie 34.5 kV	Active
AG1-083	Ahoskie 34.5 kV	Active
AG1-084	Earlys 34.5 kV	Active
AG1-085	Earlys 34.5	Active
AG1-093	Halifax-Chase City 115 kV	Active
AG1-106	Thelma 230 kV	Active
AG1-166	Lone Pine 115 kV	Active
AG1-167	Lone Pine 115 kV	Active
AG1-168	Lone Pine 115 kV	Active
AG1-169	Lone Pine 115 kV	Active
AG1-170	Lone Pine 115 kV	Active
AG1-179	Brunswick 69 kV	Active
AG1-180	Brunswick 69 kV	Active
AG1-181	Pamplin-Chase City 115 kV	Active
AG1-185	Pamplin-Chase City 115 kV	Active
AG1-215	Fort Pickett 13.2 kV	Active
AG1-272	Twitty's Creek 115 kV	Active
AG1-273	Twitty's Creek 115 kV	Active
AG1-274	Twitty's Creek 115 kV	Active
AG1-285	Chase City-Central 115 kV	Active
AG1-313	Jackson DP-Occoneechee 115 kV	Active
AG1-342	Dryburg 115 kV	Active
AG1-343	Boykins-Murphy 115 kV	Active
AG1-345	Crewe 12.5 kV	Active
AG1-384	Twitty's Creek 115 kV	Active
AG1-393	Fort Pickett DP 34.5 kV	Active
AG1-394	Boykins 34.5 kV	Active
AG1-413	South Hill-Bordnax 115 kV	Active
AG1-427	Chase City-Drakes Branch 115 kV	Active
AG1-428	Danieltown 69 kV	Active
AG1-440	Palmer Springs 115 kV	Active
AG1-441	Palmer Springs 115 kV	Active
AG1-445	Palmer Spring 115 kV	Active
AG1-446	Palmer Springs 115 kV	Active
AG1-532	Fields 34.5 kV	Active
AG1-546	Ebony-Elams Road 115 kV	Active
AG1-552	Carolina 13.2 kV	Active

10.8 Contingency Descriptions

Contingency Name	Contingency Definition
Base Case	
DVP_P1-2: LN 130	CONTINGENCY 'DVP_P1-2: LN 130' OPEN BRANCH FROM BUS 314559 TO BUS 314600 CKT 1 /* 3CAROLNA 115.00 - 3PLHITP 115.00 OPEN BRANCH FROM BUS 314595 TO BUS 314600 CKT 1 /* 3PL HILL 115.00 - 3PLHITP 115.00 OPEN BRANCH FROM BUS 314600 TO BUS 314615 CKT 1 /* 3PLHITP 115.00 - 3SKIPPERS 115.00 OPEN BUS 314595 /* ISLAND: 3PL HILL 115.00 OPEN BUS 314600 /* ISLAND: 3PLHITP 115.00 END
DVP_P1-2: LN 2201	CONTINGENCY 'DVP_P1-2: LN 2201' OPEN BRANCH FROM BUS 313725 TO BUS 314563 CKT 1 /* 6DRY BREAD 230.00 - 6CLUBHSE 230.00 END
DVP_P1-2: LN 238-A	CONTINGENCY 'DVP_P1-2: LN 238-A' OPEN BRANCH FROM BUS 314282 TO BUS 314435 CKT 1 /* 6CARSON 230.00 - 6SAPONY 230.00 OPEN BRANCH FROM BUS 314435 TO BUS 940480 CKT 1 /* 6SAPONY 230.00 - AE2- 033 TAP 230.00 OPEN BUS 314435 /* ISLAND: 6SAPONY 230.00 OPEN BUS 923852 /* ISLAND: AB2-025 E 230.00 END
314435 6SAPONY 230 940480 AE2-033 TAP 230 1	CONTINGENCY '314435 6SAPONY 230 940480 AE2-033 TAP 230 1' OPEN BRANCH FROM BUS 314435 TO BUS 940480 CKT 1 END

11 Short Circuit Analysis

The following Breakers are overdutied:

None

12 Affected Systems

12.1 TVA

TVA Impacts to be determined during later study phases (as applicable).

12.2 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

13 Attachment 1: One Line Diagram