



Generation Interconnection

Feasibility Study Report

for

Queue Project AG1-559

CAROLINE PINES 22 KV

13.3 MW Capacity / 20 MW Energy

January 2021

Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	5
4	Point of Interconnection.....	6
4.1	Primary Point of Interconnection	6
4.2	Secondary Point of Interconnection.....	6
5	Cost Summary	6
6	Transmission Owner Scope of Work.....	7
7	Schedule.....	7
8	Transmission Owner Analysis.....	7
8.1	Power Flow Analysis	8
9	Interconnection Customer Requirements.....	8
9.1	System Protection.....	8
9.2	Compliance Issues and Interconnection Customer Requirements	8
9.3	Power Factor Requirements.....	9
10	Revenue Metering and SCADA Requirements	9
10.1	PJM Requirements	9
10.2	Meteorological Data Reporting Requirements	9
10.3	Interconnected Transmission Owner Requirements.....	9
11	Summer Peak - Load Flow Analysis	10
11.1	Generation Deliverability	10
11.2	Multiple Facility Contingency	10
11.3	Contribution to Previously Identified Overloads.....	10
11.4	Potential Congestion due to Local Energy Deliverability.....	11
11.5	System Reinforcements - Summer Peak Load Flow - Primary POI.....	13
11.6	Flow Gate Details.....	15
11.6.1	Index 1	16
11.6.2	Index 2	17
11.6.3	Index 3	18
11.6.4	Index 4	19
11.6.5	Index 5	20

11.7 Queue Dependencies21

11.8 Contingency Descriptions.....22

12 Short Circuit Analysis.....23

12.1 System Reinforcements - Short Circuit.....23

13 Affected Systems24

13.1 TVA.....24

13.2 Duke Energy Progress.....24

14 Attachment 1: One Line Diagram25

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Dominion.

The AG1-559 customer will be an interconnection to Rappahannock Electric Cooperative (REC) facilities. The Interconnection Customer (IC) will need to coordinate with REC for scope, cost and schedule for this physical interconnection. This PJM report identifies the effects on the transmission system. AG1-559 will interconnect within the Rappahannock Electric Cooperative (REC) system which interconnects with the Dominion transmission system at St. Johns DP 115 kV.

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed a Solar; Storage generating facility located in Hanover County, Virginia. The installed facilities will have a total capability of 20 MW with 13.3 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is October 21, 2022. This study does not imply a TO commitment to this in-service date.

Queue Number	AG1-559
Project Name	CAROLINE PINES 22 KV
State	Virginia
County	Hanover
Transmission Owner	Dominion
MFO	20
MWE	20
MWC	13.3
Fuel	Solar; Storage
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

4.1 Primary Point of Interconnection

The Primary Point of Interconnection (POI) for AG1-559 is a direct connection to Caroline Pines 22 kV within the Rappahannock Electric Cooperative (REC) system which interconnects with the Dominion transmission system at St. Johns DP-REC 115 kV.

Attachment 1 shows a one-line diagram of the proposed interconnection facilities.

4.2 Secondary Point of Interconnection

The secondary POI for AG1-559 is tapping the North Doswell – St. Johns 115 kV line within the Rappahannock Electric Cooperative (REC) system which interconnects with the Dominion transmission system at St. Johns DP-REC 115 kV. The primary and secondary POIs were both studied as an injection at the St. Johns DP 115 kV substation in the Dominion area. Refer to the analysis results for both the primary and secondary POIs in the “Summer Peak - Load Flow Analysis” section of this report.

5 Cost Summary

The AG1-559 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$ Costs from REC to be provided in the Interconnection Agreement
Total System Network Upgrade Costs	\$107,520,000 ¹
Total Costs	\$107,520,000 + Costs in separate IA

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 2016-36, 2016-25 I.R.B. (6/20/2016). If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

¹ This project currently causes and/or contributes to overloads of the Transmission System (see Summer Peak Load Flow Analysis section below) and therefore has potential to have cost allocation for the system reinforcements listed in the report. This will be re-evaluated in the System Impact phase. The results may vary with queue customers withdrawing from the queue and other generators deactivating over time. If a customer is the first to cause the need for a project (causes loading to exceed 100% of rating), then the customer is responsible. If a customer contributes to a facility that is already overloaded by a prior queue, then they may receive cost allocation.

6 Transmission Owner Scope of Work

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

7 Schedule

The estimated schedule for the Attachment Facilities, Direct Connection and Non-Direct Connection work is identified in the "Transmission Owner Scope of Work" section of this report.

The estimated schedule for the required Network Impact Reinforcements is identified in the "System Reinforcements" section of this report.

If the customer is ultimately responsible for network upgrades, then the schedule for those upgrades will be refined in future study phases. The customer would need to wait for those upgrades to be completed prior to commercial operation unless determined deliverable by an interim deliverability study. The elapsed time to complete any network upgrades is provided in the System Reinforcements table of this report¹.

8 Transmission Owner Analysis

Dominion assessed the impact of the proposed project for compliance with NERC Reliability Criteria on the Dominion Transmission System. The system was assessed using the summer 2024 AG1 case provided to Dominion by PJM.

When performing a generation analysis, Dominion's main analysis includes load flow study results following a single contingency event for both normal and stressed system conditions. Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion's Planning Criteria and interconnection requirements can be found in the Company's Facility Connection Requirements which are publicly available at: <http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically, in Planning Studies, NERC Planning Event 3 and 6 Contingency Conditions (Loss of generator, transmission circuit, transformer, shunt device, or Single Pole of a DC line followed by the loss of a generator, transmission circuit, transformer, shunt device or single pole of a DC line) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these

contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

8.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2024 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system and no further deficiencies were identified.

9 Interconnection Customer Requirements

9.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion’s “Dominion Energy Electric Transmission Generator Interconnection Requirements” documented in Dominion’s Facility Interconnection Requirements “Exhibit C” located at:

<https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

9.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion’s “Dominion’s Facility Interconnection Requirements” document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC’s GSU transformer(s).
2. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection section noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition (“SCADA”) equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
4. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion’s “Dominion’s Facility Interconnection Requirements” document located at:

<https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with

these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

9.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 Meteorological Data Reporting Requirements

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Back Panel temperature (Fahrenheit) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Irradiance (Watts/meter²) - (Required for plants with Maximum Facility Output of 3 MW or higher)
- Ambient air temperature (Fahrenheit) - (Accepted, not required)
- Wind speed (meters/second) - (Accepted, not required)
- Wind direction (decimal degrees from true north) - (Accepted, not required)

10.3 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

11 Summer Peak - Load Flow Analysis

The Queue Project AG1-559 was evaluated as a 20.0 MW (Capacity 13.3 MW) injection at the St. Johns DP 115 kV substation in the Dominion area. Project AG1-559 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-559 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/D C	MW IMPACT
168896541	314150	6STJOHN	230.0	DVP	939260	AE1-157 TAP	230.0	DVP	1	314222 6HANOVER 230 939750 AE1-206 TAP 230 1	single	1123.30004883	125.93	127.0	DC	11.93
168896621	314212	6FOUR RIVERS	230.0	DVP	939750	AE1-206 TAP	230.0	DVP	1	314197 6LDYSMITH CT 230 939260 AE1-157 TAP 230 1	single	1123.30004883	114.57	115.63	DC	11.93
168896444	314222	6HANOVER	230.0	DVP	314218	6ELMONT	230.0	DVP	1	314197 6LDYSMITH CT 230 939260 AE1-157 TAP 230 1	single	1123.30004883	137.13	138.19	DC	11.93
168896445	314222	6HANOVER	230.0	DVP	314218	6ELMONT	230.0	DVP	1	314150 6STJOHN 230 939260 AE1-157 TAP 230 1	single	1123.30004883	120.17	121.24	DC	11.93
169819993	939260	AE1-157 TAP	230.0	DVP	314197	6LDYSMITH CT	230.0	DVP	1	314222 6HANOVER 230 939750 AE1-206 TAP 230 1	single	1123.30004883	142.89	143.95	DC	11.93

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
1698199 95	93926 0	AE1-157 TAP	230. 0	DVP	31419 7	6LDYSMIT H CT	230. 0	DVP	1	314212 6FOUR RIVERS 230 939750 AE1-206 TAP 230 1	single	1123.300048 83	114.57	115.63	DC	11.93
1688964 29	93975 0	AE1-206 TAP	230. 0	DVP	31422 2	6HANOVE R	230. 0	DVP	1	314197 6LDYSMIT H CT 230 939260 AE1-157 TAP 230 1	single	1123.300048 83	142.89	143.95	DC	11.93
1688964 30	93975 0	AE1-206 TAP	230. 0	DVP	31422 2	6HANOVE R	230. 0	DVP	1	314150 6STJOHN 230 939260 AE1-157 TAP 230 1	single	1123.300048 83	125.93	127.0	DC	11.93

11.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
1688965 40	3141 50	6STJOHN	230. 0	DVP	9392 60	AE1-157 TAP	230. 0	DVP	1	314222 6HANOVE R 230 939750 AE1-206 TAP 230 1	operation	1123.30004 883	145.84	147.61	DC	19.89
1688966 98	3141 54	3STJOHNS	115. 0	DVP	3141 50	6STJOHN	230. 0	DVP	1	Base Case	operation	172.113998 413	109.52	121.14	DC	20.0
1688968 00	3141 96	6LADYSMI TH	230. 0	DVP	3149 11	8LADYSMI TH	500. 0	DVP	2	314222 6HANOVE R 230 939750 AE1-206 TAP 230 1	operation	848.349975 586	99.92	100.46	DC	7.39
1688968 03	3141 96	6LADYSMI TH	230. 0	DVP	3149 11	8LADYSMI TH	500. 0	DVP	1	314222 6HANOVE R 230 939750 AE1-206 TAP 230 1	operation	848.349975 586	99.92	100.46	DC	7.39

ID	FROM BUS#	FROM BUS	KV	FROM BUS AREA	TO BUS#	TO BUS	KV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/DC	MW IMPACT
168896530	314197	6LDYSMITH CT	230.0	DVP	314196	6LADYSMITH	230.0	DVP	1	3142226HANOVER 230939750AE1-206TAP 2301	operation	1151.5	147.23	148.03	DC	14.77
168896682	314197	6LDYSMITH CT	230.0	DVP	965440	AG1-412TAP	230.0	DVP	1	Base Case	operation	1103.56005859	99.74	100.01	DC	2.96
168896620	314212	6FOUR RIVERS	230.0	DVP	939750	AE1-206TAP	230.0	DVP	1	3141976LDYSMITH CT 230939260AE1-157TAP 2301	operation	1123.30004883	133.97	135.74	DC	19.89
168896442	314222	6HANOVER	230.0	DVP	314218	6ELMONT	230.0	DVP	1	3141976LDYSMITH CT 230939260AE1-157TAP 2301	operation	1123.30004883	166.63	168.4	DC	19.89
169819992	939260	AE1-157TAP	230.0	DVP	314197	6LDYSMITH CT	230.0	DVP	1	3142226HANOVER 230939750AE1-206TAP 2301	operation	1123.30004883	172.39	174.16	DC	19.89
168896427	939750	AE1-206TAP	230.0	DVP	314222	6HANOVER	230.0	DVP	1	3141976LDYSMITH CT 230939260AE1-157TAP 2301	operation	1123.30004883	172.39	174.16	DC	19.89

11.5 System Reinforcements - Summer Peak Load Flow - Primary POI

ID	Idx	Facility	Upgrade Description	Cost
168896621	2	6FOUR RIVERS 230.0 kV - AE1- 206 TAP 230.0 kV Ckt 1	<p><u>DVP:</u> dom-210 (1086) : Rebuild 2.4 miles of 230 kV Line 2032 from Four Rivers to AE1-206 Tap with 2-768 ACSS (@250 C). Replace Breaker, Wave trap, Relay (Secondary CT) and Line Lead at Four River 230 kV. Replace Breaker at AE1-206 230 kV generation station.</p> <p>Project Type : FAC Cost : \$6,320,000 Time Estimate : 36-40 Months</p>	\$6,320,000
169819993,169 819995	4	AE1-157 TAP 230.0 kV - 6LDYSMITH CT 230.0 kV Ckt 1	<p><u>DVP:</u> n6156 (1048) : Rebuild 7.8 miles of 230 kV Line 256 from AE1-157 Tap to Ladysmith CT with 2-768.2 ACSS 200C.</p> <p>Project Type : FAC Cost : \$19,500,000 Time Estimate : 30-36 Months</p> <p>dom-252 (1128) : Wreck and rebuild 7.9 miles of existing single circuit line 256 between Ladysmith CT to AE1-157 Tap 230 kV. Add new circuit between Ladysmith CT to AE1-157 Tap 230 kV, constructed as a double circuit line. Utilize 2-636 ACSR for all new and modified circuits. Add two breakers at Ladysmith CT and a breaker at AE1-157 Station.</p> <p>Project Type : CON Cost : \$23,350,000 Time Estimate : 36-40 Months</p>	\$42,850,000
168896541	1	6STJOHN 230.0 kV - AE1-157 TAP 230.0 kV Ckt 1	<p><u>DVP:</u> dom-069 (902) : Rebuild 4.45 miles of 230 kV Line 256 from St. John to AE1-157 Tap with 2-768.2 ACSS 200C.</p> <p>Project Type : FAC Cost : \$11,125,000 Time Estimate : 30-36 Months</p> <p>dom-248 (1124) : Rebuild 4.45 miles of 230 kV Line 256 from St. John to AE1-157 Tap with 2-768.2 ACSS 250C. Replace Line Lead at St Johns 230 kV.</p> <p>Project Type : FAC Cost : \$11,125,000 Time Estimate : 30-36 Months</p> <p>dom-285 (1161) : Rebuild 4.45 miles of 230 kV Line 256 from St. John to AE1-157 Tap with 2-768.2 ACSS 250C. Replace Line Switch and Line Lead at St. Johns terminal.</p> <p>Project Type : FAC Cost : \$6,925,000 Time Estimate : 30-36 Months</p>	\$29,175,000

ID	Idx	Facility	Upgrade Description	Cost
168896445,168 896444	3	6HANOVER 230.0 kV - 6ELMONT 230.0 kV Ckt 1	<p><u>DVP:</u> n6159 (1051) : Rebuild 3.19 miles of 230 kV Line 2032 from Hanover to Elmont with 2-768.2 ACSS 200C. Project Type : FAC Cost : \$4,785,000 Time Estimate : 30-36 Months</p> <p>dom-250 (1126) : Rebuild 3.19 miles of 230 kV Line 2032 from Hanover to Elmont with 2-768.2 ACSS 250C. Replace Line Switch, Wave trap and Relay (Secondary CT) at Elmont 230 kV. Project Type : FAC Cost : \$5,355,000 Time Estimate : 30-36 Months</p>	\$10,140,000
168896430,168 896429	5	AE1-206 TAP 230.0 kV - 6HANOVER 230.0 kV Ckt 1	<p><u>DVP:</u> n6158 (1050) : Rebuild 3.37 miles of 230 kV Line 2032 from AE1-206 Tap to Hanover with 2-768.2 ACSS 200C. Project Type : FAC Cost : \$5,055,000 Time Estimate : 30-36 Months</p> <p>dom-253 (1129) : Rebuild 3.37 miles of 230 kV Line 2032 from AE1-206 Tap to Hanover with 2-768.2 ACSS 250C. Replace Line Switch at Hanover 230 kV Project Type : FAC Cost : \$5,305,000 Time Estimate : 30-36 Months</p> <p>dom-399 (1275) : Wreck and Rebuild 3.37 miles of 230 kV Line2032 from AE1-206 Tap to Hanover as a double circuit (6 wire) with 2-636 ACSR on each circuit. Replace Line Switch at Hanover terminal. Project Type : FAC Cost : \$8,675,000 Time Estimate : 30-36 Months</p>	\$19,035,000
			TOTAL COST	\$107,520,000

11.6 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

11.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168896541	314150	6STJOHN	DVP	939260	AE1-157 TAP	DVP	1	314222 6HANOVER 230 939750 AE1-206 TAP 230 1	single	1123.3	125.93	127.0	DC	11.93

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
315043	1FOUR RIVERA	16.9462	80/20	16.9462
315044	1FOUR RIVERB	16.9462	80/20	16.9462
315045	1FOUR RIVERC	20.7121	80/20	20.7121
315046	1FOUR RIVERD	16.9462	80/20	16.9462
315047	1FOUR RIVERE	16.9462	80/20	16.9462
315048	1FOUR RIVERF	20.7121	80/20	20.7121
315051	1AA1-145 CT1	26.6746	80/20	26.6746
315052	1AA1-145 CT2	26.6746	80/20	26.6746
939755	AE1-206 C	170.0680	80/20	170.0680
942191	AE2-231 C O1	26.2561	80/20	26.2561
946001	AF1-265	149.1825	80/20	149.1825
957411	AF2-035 C	47.7384	80/20	47.7384
960091	AF2-300 C	11.9346	80/20	11.9346
963341	AG1-183 C	35.3264	80/20	35.3264
963381	AG1-187	14.4011	80/20	14.4011
963621	AG1-213 C	3.9782	80/20	3.9782
966711	AG1-541 C	31.8256	80/20	31.8256
966881	AG1-559 C	11.9346	80/20	11.9346
CALDERWOOD	CALDERWOOD	0.2709	Confirmed LTF	0.2709
NY	NY	0.3014	Confirmed LTF	0.3014
PRAIRIE	PRAIRIE	1.4077	Confirmed LTF	1.4077
CHEOAH	CHEOAH	0.2728	Confirmed LTF	0.2728
COTTONWOOD	COTTONWOOD	1.1445	Confirmed LTF	1.1445
HAMLET	HAMLET	0.3147	Confirmed LTF	0.3147
GIBSON	GIBSON	0.2976	Confirmed LTF	0.2976
BLUEG	BLUEG	0.9461	Confirmed LTF	0.9461
TRIMBLE	TRIMBLE	0.3033	Confirmed LTF	0.3033
CATAWBA	CATAWBA	0.1908	Confirmed LTF	0.1908

11.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168896621	314212	6FOUR RIVERS	DVP	939750	AE1-206 TAP	DVP	1	314197 6LDYSMITH CT 230 939260 AE1-157 TAP 230 1	single	1123.3	114.57	115.63	DC	11.93

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
315043	1FOUR RIVERA	16.9462	80/20	16.9462
315044	1FOUR RIVERB	16.9462	80/20	16.9462
315045	1FOUR RIVERC	20.7121	80/20	20.7121
315046	1FOUR RIVERD	16.9462	80/20	16.9462
315047	1FOUR RIVERE	16.9462	80/20	16.9462
315048	1FOUR RIVERF	20.7121	80/20	20.7121
315051	1AA1-145 CT1	26.6746	80/20	26.6746
315052	1AA1-145 CT2	26.6746	80/20	26.6746
939261	AE1-157 C O1	77.3760	80/20	77.3760
939271	AE1-158 C O1	78.9673	80/20	78.9673
942191	AE2-231 C O1	26.2561	80/20	26.2561
957411	AF2-035 C	47.7384	80/20	47.7384
957551	AF2-049 C	34.3120	80/20	34.3120
960091	AF2-300 C	11.9346	80/20	11.9346
963341	AG1-183 C	35.3264	80/20	35.3264
963381	AG1-187	14.4011	80/20	14.4011
963621	AG1-213 C	3.9782	80/20	3.9782
966711	AG1-541 C	31.8256	80/20	31.8256
966881	AG1-559 C	11.9346	80/20	11.9346
CALDERWOOD	CALDERWOOD	0.2709	Confirmed LTF	0.2709
NY	NY	0.3014	Confirmed LTF	0.3014
PRAIRIE	PRAIRIE	1.4077	Confirmed LTF	1.4077
CHEOAH	CHEOAH	0.2728	Confirmed LTF	0.2728
COTTONWOOD	COTTONWOOD	1.1445	Confirmed LTF	1.1445
HAMLET	HAMLET	0.3147	Confirmed LTF	0.3147
GIBSON	GIBSON	0.2976	Confirmed LTF	0.2976
BLUEG	BLUEG	0.9461	Confirmed LTF	0.9461
TRIMBLE	TRIMBLE	0.3033	Confirmed LTF	0.3033
CATAWBA	CATAWBA	0.1908	Confirmed LTF	0.1908

11.6.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168896444	314222	6HANOVER	DVP	314218	6ELMONT	DVP	1	314197 6LDYSMITH CT 230 939260 AE1-157 TAP 230 1	single	1123.3	137.13	138.19	DC	11.93

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
315043	1FOUR RIVERA	16.9462	80/20	16.9462
315044	1FOUR RIVERB	16.9462	80/20	16.9462
315045	1FOUR RIVERC	20.7121	80/20	20.7121
315046	1FOUR RIVERD	16.9462	80/20	16.9462
315047	1FOUR RIVERE	16.9462	80/20	16.9462
315048	1FOUR RIVERF	20.7121	80/20	20.7121
315051	1AA1-145 CT1	26.6746	80/20	26.6746
315052	1AA1-145 CT2	26.6746	80/20	26.6746
939261	AE1-157 C O1	77.3760	80/20	77.3760
939271	AE1-158 C O1	78.9673	80/20	78.9673
939755	AE1-206 C	170.0680	80/20	170.0680
942191	AE2-231 C O1	26.2561	80/20	26.2561
946001	AF1-265	149.1825	80/20	149.1825
957411	AF2-035 C	47.7384	80/20	47.7384
957551	AF2-049 C	34.3120	80/20	34.3120
960091	AF2-300 C	11.9346	80/20	11.9346
963341	AG1-183 C	35.3264	80/20	35.3264
963381	AG1-187	14.4011	80/20	14.4011
963621	AG1-213 C	3.9782	80/20	3.9782
966711	AG1-541 C	31.8256	80/20	31.8256
966881	AG1-559 C	11.9346	80/20	11.9346
CALDERWOOD	CALDERWOOD	0.2709	Confirmed LTF	0.2709
NY	NY	0.3014	Confirmed LTF	0.3014
PRAIRIE	PRAIRIE	1.4077	Confirmed LTF	1.4077
CHEOAH	CHEOAH	0.2728	Confirmed LTF	0.2728
COTTONWOOD	COTTONWOOD	1.1445	Confirmed LTF	1.1445
HAMLET	HAMLET	0.3147	Confirmed LTF	0.3147
GIBSON	GIBSON	0.2976	Confirmed LTF	0.2976
BLUEG	BLUEG	0.9461	Confirmed LTF	0.9461
TRIMBLE	TRIMBLE	0.3033	Confirmed LTF	0.3033
CATAWBA	CATAWBA	0.1908	Confirmed LTF	0.1908

11.6.4 Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
169819993	939260	AE1-157 TAP	DVP	314197	6LDYSMITH CT	DVP	1	314222 6HANOVER 230 939750 AE1-206 TAP 230 1	single	1123.3	142.89	143.95	DC	11.93

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
315043	1FOUR RIVERA	16.9462	80/20	16.9462
315044	1FOUR RIVERB	16.9462	80/20	16.9462
315045	1FOUR RIVERC	20.7121	80/20	20.7121
315046	1FOUR RIVERD	16.9462	80/20	16.9462
315047	1FOUR RIVERE	16.9462	80/20	16.9462
315048	1FOUR RIVERF	20.7121	80/20	20.7121
315051	1AA1-145 CT1	26.6746	80/20	26.6746
315052	1AA1-145 CT2	26.6746	80/20	26.6746
939261	AE1-157 C O1	77.3760	80/20	77.3760
939271	AE1-158 C O1	78.9673	80/20	78.9673
939755	AE1-206 C	170.0680	80/20	170.0680
942191	AE2-231 C O1	26.2561	80/20	26.2561
946001	AF1-265	149.1825	80/20	149.1825
957411	AF2-035 C	47.7384	80/20	47.7384
957551	AF2-049 C	34.3120	80/20	34.3120
960091	AF2-300 C	11.9346	80/20	11.9346
963341	AG1-183 C	35.3264	80/20	35.3264
963381	AG1-187	14.4011	80/20	14.4011
963621	AG1-213 C	3.9782	80/20	3.9782
966711	AG1-541 C	31.8256	80/20	31.8256
966881	AG1-559 C	11.9346	80/20	11.9346
CALDERWOOD	CALDERWOOD	0.2709	Confirmed LTF	0.2709
NY	NY	0.3014	Confirmed LTF	0.3014
PRAIRIE	PRAIRIE	1.4077	Confirmed LTF	1.4077
CHEOAH	CHEOAH	0.2728	Confirmed LTF	0.2728
COTTONWOOD	COTTONWOOD	1.1445	Confirmed LTF	1.1445
HAMLET	HAMLET	0.3147	Confirmed LTF	0.3147
GIBSON	GIBSON	0.2976	Confirmed LTF	0.2976
BLUEG	BLUEG	0.9461	Confirmed LTF	0.9461
TRIMBLE	TRIMBLE	0.3033	Confirmed LTF	0.3033
CATAWBA	CATAWBA	0.1908	Confirmed LTF	0.1908

11.6.5 Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168896429	939750	AE1-206 TAP	DVP	314222	6HANOVER	DVP	1	314197 6LDYSMITH CT 230 939260 AE1-157 TAP 230 1	single	1123.3	142.89	143.95	DC	11.93

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
315043	1FOUR RIVERA	16.9462	80/20	16.9462
315044	1FOUR RIVERB	16.9462	80/20	16.9462
315045	1FOUR RIVERC	20.7121	80/20	20.7121
315046	1FOUR RIVERD	16.9462	80/20	16.9462
315047	1FOUR RIVERE	16.9462	80/20	16.9462
315048	1FOUR RIVERF	20.7121	80/20	20.7121
315051	1AA1-145 CT1	26.6746	80/20	26.6746
315052	1AA1-145 CT2	26.6746	80/20	26.6746
939261	AE1-157 C O1	77.3760	80/20	77.3760
939271	AE1-158 C O1	78.9673	80/20	78.9673
939755	AE1-206 C	170.0680	80/20	170.0680
942191	AE2-231 C O1	26.2561	80/20	26.2561
946001	AF1-265	149.1825	80/20	149.1825
957411	AF2-035 C	47.7384	80/20	47.7384
957551	AF2-049 C	34.3120	80/20	34.3120
960091	AF2-300 C	11.9346	80/20	11.9346
963341	AG1-183 C	35.3264	80/20	35.3264
963381	AG1-187	14.4011	80/20	14.4011
963621	AG1-213 C	3.9782	80/20	3.9782
966711	AG1-541 C	31.8256	80/20	31.8256
966881	AG1-559 C	11.9346	80/20	11.9346
CALDERWOOD	CALDERWOOD	0.2709	Confirmed LTF	0.2709
NY	NY	0.3014	Confirmed LTF	0.3014
PRAIRIE	PRAIRIE	1.4077	Confirmed LTF	1.4077
CHEOAH	CHEOAH	0.2728	Confirmed LTF	0.2728
COTTONWOOD	COTTONWOOD	1.1445	Confirmed LTF	1.1445
HAMLET	HAMLET	0.3147	Confirmed LTF	0.3147
GIBSON	GIBSON	0.2976	Confirmed LTF	0.2976
BLUEG	BLUEG	0.9461	Confirmed LTF	0.9461
TRIMBLE	TRIMBLE	0.3033	Confirmed LTF	0.3033
CATAWBA	CATAWBA	0.1908	Confirmed LTF	0.1908

11.7 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AA1-145	Four Rivers 230kV	In Service
AE1-157	Ladysmith CT-St. Johns 230 kV	Active
AE1-158	Ladysmith CT-St. Johns 230 kV	Active
AE1-206	Four Rivers-Hanover 230 kV	Active
AE2-231	St. Johns 115 kV	Active
AF1-265	Four Rivers-Hanover 230 kV	Active
AF2-035	St. Johns 115 kV	Active
AF2-049	Ladysmith CT-St. Johns 230 kV	Active
AF2-300	St. Johns 115 kV	Active
AG1-183	St. Johns DP-REC 115 kV	Active
AG1-187	St. Johns DP-REC 115 kV	Active
AG1-213	St Johns 13.2 kV	Active
AG1-541	St. Johns 115 kV	Active
AG1-559	Caroline Pines 22 kV	Active

11.8 Contingency Descriptions

Contingency Name	Contingency Definition
314197 6LDYSMITH CT 230 939260 AE1-157 TAP 230 1	CONTINGENCY '314197 6LDYSMITH CT 230 939260 AE1-157 TAP 230 1' OPEN BRANCH FROM BUS 314197 TO BUS 939260 CKT 1 END
314212 6FOUR RIVERS 230 939750 AE1-206 TAP 230 1	CONTINGENCY '314212 6FOUR RIVERS 230 939750 AE1-206 TAP 230 1' OPEN BRANCH FROM BUS 314212 TO BUS 939750 CKT 1 END
Base Case	
314222 6HANOVER 230 939750 AE1-206 TAP 230 1	CONTINGENCY '314222 6HANOVER 230 939750 AE1-206 TAP 230 1' OPEN BRANCH FROM BUS 314222 TO BUS 939750 CKT 1 END
314150 6STJOHN 230 939260 AE1-157 TAP 230 1	CONTINGENCY '314150 6STJOHN 230 939260 AE1-157 TAP 230 1' OPEN BRANCH FROM BUS 314150 TO BUS 939260 CKT 1 END

12 Short Circuit Analysis

The following Breakers are overdutied:

None.

12.1 System Reinforcements - Short Circuit

None.

13 Affected Systems

13.1 TVA

TVA Impacts to be determined during later study phases (as applicable).

13.2 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

14 Attachment 1: One Line Diagram