



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 80 MW Injection at Morgantown 230kV bus

There were no network impacts for the injection of 80 MW into the Morgantown 230kV bus.