



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource using Burlington #7 Capacity Injection Rights .

Network Impacts - 168 MW Injection

Network impacts for the injection of 168 MW into the Burlington 138 kV bus were evaluated for 2004 summer peak conditions. Based on the power flow analysis performed, no network upgrade requirements were identified.