



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 550 MW Injection

Network impacts for the injection of 550 MW into the two Morgantown-Talbert/Oak Grove 230 kV circuits were evaluated for 2004 summer peak conditions. Based on the power flow analysis performed, no network upgrade requirements were identified.