



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts -2.1 MW Injection at Freehold 34.5kV

Potential network impacts for the increased injection of 2.1 MW at Freehold 34.5kV substation were evaluated for summer peak conditions in 2004.

As an energy only facility there is no need for any network upgrades