



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 9.9 MW Injection at Gould St. 34.5kV-13kV Substation

There were no network impacts for the injection of 9.9 MW into the Gould St. 34.5kV-13kV substation.