



# Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

## Network Impacts - 6.8 MW Injection at Oak Grove 13.8kV bus

There were no network impacts for the injection of 6.8 MW into the Oak Grove 13.8kV bus.