



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 36 MW Injection at Conowingo 230kV bus

Network impacts for the injection of 36 MW into the Conowingo 230kV Bus were evaluated for 2004 summer peak conditions. Based on power flow analysis performed, no network requirements have been identified.