



# Generation Interconnections

## **Generation Interconnection**

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

## **Network Impacts - 436 MW Injection**

Network impacts for the injection of 436 MW, using Capacity Interconnection Rights for Linden Units #1, #2, and #3, into Linden 138kV bus was evaluated for 2004 summer peak conditions. There were no identified network upgrade requirements.