



Generation Interconnections

This analysis was completed to assess the potential reliability impact for a new generator interconnecting to the PJM system as a Capacity Resource.

Network Impacts - 550 MW Injection

Network impacts for the injection of 550 MW into the four Morgantown/Hawkins Gate - Talbert/Oak Grove 230 kV circuits were evaluated for 2004 summer peak conditions. Based on the power flow analysis performed the following network impacts were identified:

NETWORK VIOLATIONS

Normal System

- No worst case overloads.
Facility overloads were identified, but a greater overload for those facilities occurred for a contingency condition reported below.

Single Contingency

- 124% overload on the C03 project - Talbert (23086) 230 kV circuit for the outage involving the parallel (23085) 230 kV circuit from the #C3 project to Talbert. The project contributes approximately 162 MW to the overloaded facility whose rating is 692 MVA. Note that according to an extrapolation of these figures, a conventional breaker and a half bus arrangement will still result in this circuit being overloaded with one of the combined cycle units off-line. The cost to reinforce this facility is **\$9,000,000**. The time required to construct this reinforcement is **36 to 48 months**.
- 124% overload on the #C3 project - Talbert (23085) 230 kV circuit for the outage involving the parallel (23086) 230 kV circuit from the #C3 project to Talbert. The project contributes approximately 162 MW to the overloaded facility whose rating is 692 MVA. Note that according to an extrapolation of these figures, a conventional breaker and a half bus arrangement will still result in this circuit being overloaded with one of the combined cycle units off-line. The cost to reinforce this facility is **\$9,000,000**. The time required to construct this reinforcement is **36 to 48 months**.

Double Circuit Tower Circuit Outages (MAAC Criteria IIC)

- 117% overload on the Oak Grove - Burtonsville (23045) 230 kV circuit for the double circuit tower line outage involving the Chalk Point - Bowie (23063/54) 230 kV circuit and the Oak Grove - Burtonsville (23042) 230 kV circuit. The project contributes approximately 108 MW to

the overloaded facility whose rating is 730 MVA. The cost to reinforce this facility is **\$17,000,000**. The time required to construct this reinforcement is **36 to 48 months**.

- 113% overload on the Oak Grove - Burtonsville (23042) 230 kV circuit for the double circuit tower line outage involving the Chalk Point - Bowie (23065) 230 kV circuit and the Oak Grove - Burtonsville (23045) 230 kV circuit. The project contributes approximately 108 MW to the overloaded facility whose rating is 730 MVA. The cost to reinforce this facility is \$17,000,000. The time required to construct this reinforcement is 36 to 48 months.

In addition to the network impacts shown above, a short circuit screening was performed. The results are primarily the same for each alternative.

SHORT CIRCUIT ANALYSIS

All of the eight Oak Grove 230 kV circuit breakers on the Oak Grove - Ritchie 230 kV circuits are over-dutied with fault currents between 51 kA and 53 kA versus a 50 kA interrupting rating. The cost to replace these circuit breakers with new 63 kA circuit breakers is \$4,800,000. The time required to replace these breakers is 18 months.

STABILITY ANALYSIS

Not performed. Stability analysis will be performed during the Impact Study for this project.