



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts -3.75 MW Increased Injection at the Somerset 34.5kV substation

Potential network impacts for the injection of 3.75 MW into the Somerset 34.5 kV substation were evaluated for summer peak conditions in 2004.

The system, as planned, was evaluated for compliance with reliability criteria. There are no network upgrades required for this project.