

## **Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.**

### **Network Impacts - 8 MW Injection**

Network impacts for the injection of 8 MW into the Blue Ball 69 kV Bus were evaluated. No network impacts were identified.