

Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an Energy-only resource.

Network Impacts - 25 MW Injection

Network impacts for the injection of 25 MW into the NIH 13.8kV (PEPCO Substation 167) Bus were evaluated. No network impacts were identified.