



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 190 MW Injection

Project D14 is using existing capacity interconnection rights of 175MW for Hay Road unit #4.

Network impacts for the injection of 190 MW into the Red Lion 69 kV Bus were evaluated. No network impacts were identified.