



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 39 MW Injection

Network impacts for the injection of 26 MW into the Edgemoor 138kV bus and 13 MW into the Edgemoor 69 kV Bus were evaluated. No network impacts were identified.