



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 2.5 MW Injection

Network impacts for the injection of 2.5 MW into Bethlehem Steel 33kV bus was evaluated for 2004 summer peak conditions. There were no identified network upgrade requirements.