



# Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an Energy-only resource.

## Network Impacts - 9 MW Injection

Network impacts for the injection of 9 MW into the Kiamensi 34.5kV Bus were evaluated. No network impacts were identified.