



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.

Network Impacts - 16 MW Injection

Injection of 16 MW into the Dickerson (Station "H") 230kV substation was evaluated for network impacts. No network impacts were identified.