



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.

Network Impacts - 6 MW Injection

Injection of 6 MW into the Chalk Point (Station "E") 230kV substation was evaluated for network impacts. No network impacts were identified.