

Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.

Network Impacts - 10MW Injection

Injection of 10 MW into the Perryman 115kV substation was evaluated for network impacts. There were no network impacts identified.