

## **Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.**

### **Network Impacts - 70MW Injection**

Injection of 70 MW into the Peach Bottom 500kV substation was evaluated for network impacts. There were no network impacts identified.