

Generation Interconnection

(Queue #H6 Chichester 25 MW)

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.

Network Impacts - 25 MW Capacity Injection

Capacity injection of 25 MW into the Chichester – Edgemoor (220-43) and Chichester – Claymont (220-39) 230kV lines was evaluated to determine Network Impacts. There were no network upgrade requirements identified.