

Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an Energy-only resource.

Network Impacts - 9 MW “Energy-Only” Injection

Network impacts for the “Energy-Only” injection of 9 MW into the Dolfield 33kV Bus were evaluated. No network impacts were identified.