

# Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an capacity resource.

## Network Impacts -1060 MW Injection into the TMI-Peach Bottom 500kV transmission line (H14)

### Network Impacts

The #H14 project was studied as 1060MW capacity injection into the TMI – Peach Bottom 500kV substation. Project # H14 was evaluated for compliance with reliability criteria for summer peak conditions in 2006. Potential network impacts were as follows:

### Generator Deliverability

1. The TMI 500/230 kV transformer is contingency overloaded at **105%** of the emergency rating (911 MVA) for outage of the Peach Bottom – H14 500 kV circuit. The H14 project contributes approximately 261 MW to the loading on this circuit.

### Multiple Facility Contingency – Tower Line Outages (MAAC Criteria IIC)

No identified problems.

### Short Circuit

Contributes to the overdutied condition of eleven (11) 500kV circuit breakers at Peach Bottom 500kV substation.

### New System Reinforcements

The overload of the TMI 500/230kV transformer can be alleviated by the installation of a second 500/230kV transformer at the substation.

The estimated cost to add the transformer and a 500kV and 230kV circuit breaker for termination of the transformer into the busses is estimated to cost \$13.0 million and take 2 years to complete.

### Contribution to Previously Identified System Reinforcements

The H14 project will contribute to the cost of the following previously identified network reinforcements:

1. Install a new 500 kV circuit breaker at Conastone substation. The project contributes approximately **136 MW**. The total cost is estimated at \$1.4 and it is expected to take 2 years to complete.
2. Replace or upgrade eleven (11) 500kV circuit breakers at Peach Bottom 500kV substation. The total cost for replacement is \$7.8 million

Cost allocation percentages are not provided as part of the Feasibility Study analysis, however, cost allocation will be provided during the Impact Study evaluations.