

Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.

Network Impacts - 3.5 MW Capacity Injection

Network impacts for the Capacity injection of 3.5 MW into the Oak Grove 13.8kV feeder 14166 were evaluated. No network impacts were identified.