

#11 Ontario 7.5 MW Energy-Only  
**Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an Energy-Only resource.**

**Network Impacts - 7.5 MW Energy Injection**

Energy injection of 7.5 MW into the Ontario 23 kV circuit #25 was evaluated to determine Network Impacts. No potential network upgrade requirements were identified.