

## **Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an “Energy-Only” resource.**

### **Network Impacts - 6 MW Capacity Injection**

Capacity injection of 6 MW into the Whiteoak Sub 153 13.8kV bus was evaluated to determine Network Impacts. There are no network upgrade requirements.