

Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a “Energy-Only” resource.

Network Impacts - 1.7 MW “Energy-Only” Injection

Energy-Only injection of 1.7 MW into the Greenwich Pumphouse 2.4kV bus was evaluated to determine Network Impacts. There are no network upgrade requirements.