

#110 Bethesda (Sub 6) 2 MW  
**Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.**

**Network Impacts - 2 MW Capacity Injection**

Capacity injection of 2 MW into the Bethesda 13.8kV bus was evaluated to determine Network Impacts. No potential network upgrade requirements determined.