

#14 Bustleton 7 MW

Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.

Network Impacts - 7 MW Capacity Injection

Capacity injection of 7 MW into Bustleton 138kV bus was evaluated to determine Network Impacts. No potential network upgrade requirements were identified.