

#J5 Huron 8 MW

## **Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.**

### **Network Impacts - 8 MW Capacity Injection**

Capacity injection of 8 MW into the Huron 69 kV bus was evaluated to determine Network Impacts. No potential network upgrade requirements were identified.