

#J8 Whiteoak 6 MW

## **Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.**

### **Network Impacts - 6 MW Capacity Injection**

Capacity injection of 6 MW into 69 kV lines 69139 and 69141 was evaluated to determine Network Impacts. No potential network upgrade requirements were identified.