

## **Generator Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system.**

### ***Network Impacts***

There were no Network Impacts identified for the interconnection of an 8MW Energy Resource at Salem 69kV.