

(K06 Easton 5)

## **Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an Energy Resource.**

### **Network Impacts - 5 MW Capacity Injection**

The **K06** project was studied as a **5 MW Capacity** injection into the Easton 69kV bus to determine compliance with reliability criteria for summer peak conditions in 2007. There were no potential network impacts identified.