

(K07 Easton 5)

Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an Energy Resource.

Network Impacts - 5 MW Capacity Injection

The **K07** project was studied as a **5 MW Capacity** injection into the Easton 69kV bus to determine compliance with reliability criteria for summer peak conditions in 2007. There were no potential network impacts identified.