

Network Impacts

The #K19 project was studied as a 13.2 MW status change from energy to capacity to determine compliance with reliability criteria for summer peak conditions in 2007. Potential network impacts were as follows:

Generator Deliverability

No identified problems.

Contribution to Previously Identified System Reinforcements

None.