

#L02 Pleasantville 1.4 MW
Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.

Network Impacts - 1.4 MW Capacity Injection

Capacity injection of 1.4 MW into the Pleasantville 13 kV bus was evaluated to determine Network Impacts. There were no potential network upgrade requirements determined.