

**#N07 Monterey 69 kV
Generation Interconnection**

Network Impacts

The #N07 project was studied as a total injection of 38 MW (7.6 MW of capacity) into the Durbin 138 kV substation. Project #N07 was evaluated for compliance with reliability criteria for summer peak conditions in 2008. Potential network impacts were as follows:

Generator Deliverability

No problems were identified.

Multiple Facility Contingency – Tower Line Outages

No problems were identified.

Contribution to Previously Identified Overloads

None.

New System Reinforcements

None required.

Contribution to Previously Identified System Reinforcements

None.

Short Circuit

No breaker replacements were identified.

COSTS

Contribution to Previously Identified System Reinforcements;

None.

Costs for System Reinforcements

None.